DEPARTMENT OF HEALTH AND HUMAN SERVICES CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/29/2023 FORM APPROVED OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	` ′	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01		(X3) DATE SURVEY COMPLETED	
		155806	B. WING			R 03/03/2023	
NAME OF PROVIDER OR SUPPLIER				STREET ADDRESS, C	ITY, STATE, ZIP CODE	1 00.0	0.2020
WELLBROOKE OF WABASH				20 JOHN KISSINGER DRIVE			
				WABASH, IN 46992			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)			(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS		{K 0	00}			
	A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 02/09/23 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a). Survey Date: 03/03/23 Facility Number: 012993 Provider Number: 155806 AIM Number: 201208210 At this Life Safety Code Survey, Wellbrooke of Wabash was found in compliance with the Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.90(a). The facility has 70 certified beds. At the time of survey the census was 63. Quality Review completed on 03/06/23						

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE (X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.