

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/04/2025
FORM APPROVED
OMB NO. 0938-0391

| | | | | | |
|--|---|--|--|--|--|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155780 | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____ | | (X3) DATE SURVEY COMPLETED R 02/03/2025 |
| NAME OF PROVIDER OR SUPPLIER HOMESTEAD HEALTHCARE CENTER | | | STREET ADDRESS, CITY, STATE, ZIP CODE 7465 MADISON AVE INDIANAPOLIS, IN 46227 | | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | | (X5) COMPLETION DATE |
| {E 000} | Initial Comments A Post Survey Revisit (PSR) to the Emergency Preparedness Survey conducted on 12/12/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73. Survey Date: 02/03/25 Facility Number: 012225 Provider Number: 155780 AIM Number: 200983560 At this PSR survey, Homestead Healthcare Center was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73. The facility has 88 certified beds. At the time of the survey, the census was 53. | {E 000} | | | |
| {K 000} | Quality Review completed on 02/03/25 INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 12/12/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a). Survey Date: 02/03/25 Facility Number: 012225 Provider Number: 155780 AIM Number: 200983560 At this PSR survey, Homestead Healthcare Center was found in compliance with | {K 000} | | | |

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/04/2025
FORM APPROVED
OMB NO. 0938-0391

| | | | | | |
|--|---|--|--|----------------------------|--|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155780 | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____ | | (X3) DATE SURVEY COMPLETED R 02/03/2025 |
| NAME OF PROVIDER OR SUPPLIER HOMESTEAD HEALTHCARE CENTER | | | STREET ADDRESS, CITY, STATE, ZIP CODE 7465 MADISON AVE INDIANAPOLIS, IN 46227 | | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETION DATE | |
| {K 000} | <p>Continued From page 1</p> <p>Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one-story facility was determined to be of Type III (200) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and in all areas open to the corridor. The facility has battery operated smoke detectors installed in all resident sleeping rooms except in Room 502 which has a smoke detector hard wired to the facility's fire alarm system. The facility has a capacity of 88 and had a census of 53 at the time of this visit.</p> <p>All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered except for one detached storage shed.</p> <p>Quality Review completed on 02/03/25</p> | {K 000} | | | |