

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/23/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155207		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R-C 05/20/2025	
NAME OF PROVIDER OR SUPPLIER MAJESTIC CARE OF NEW HAVEN				STREET ADDRESS, CITY, STATE, ZIP CODE 1201 DALY DRIVE NEW HAVEN, IN 46774			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS A Post Survey Revisit (PSR) to the investigation of Complaint Number IN00456495 conducted on 04/02/25 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a). Complaint Number #IN00456495 - Corrected. This visit was in conjunction with the Life Safety Code Recertification PSR that exited on 05/20/25. Survey Date: 05/20/25 Facility Number: 000114 Provider Number: 155207 AIM Number: 100266640 At this PSR survey, Majestic Care of Haven Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This one-story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, areas open to the corridors and single station battery operated smoke detectors in the resident rooms. The facility is partially protected by a Type II EES 60KW diesel powered generator. The facility has a capacity of 120 and had a census of 70 at the time of this survey.			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155207	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R-C 05/20/2025
NAME OF PROVIDER OR SUPPLIER MAJESTIC CARE OF NEW HAVEN			STREET ADDRESS, CITY, STATE, ZIP CODE 1201 DALY DRIVE NEW HAVEN, IN 46774		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	Continued From page 1 All areas where the residents have customary access were sprinklered. All areas providing facility services were sprinklered which the exception of a detached building housing the emergency generator and used for storage of maintenance equipment. Quality Review completed on 05/22/25	{K 000}			