

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 12/05/2024
FORM APPROVED
OMB NO. 0938-0391

| | | | | | | | |
|--|---|--|--|---|--|--|----------------------------|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155727 | | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____ | | (X3) DATE SURVEY COMPLETED R 12/03/2024 | |
| NAME OF PROVIDER OR SUPPLIER STONEBRIDGE HEALTH CAMPUS | | | | STREET ADDRESS, CITY, STATE, ZIP CODE 3100 SHAWNEE DR S BEDFORD, IN 47421 | | | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | | | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | | (X5) COMPLETION DATE |
| {E 000} | Initial Comments | | | {E 000} | | | |
| {K 000} | <p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 10/30/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 12/03/24</p> <p>Facility Number: 003924 Provider Number: 155727 AIM Number: 200472040</p> <p>At this PSR Life Safety Code survey, Stonebridge Health Campus was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code, (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility was determined to be of Type V (111) construction and was sprinklered. The facility has a fire alarm system with hard wired smoke detectors in the corridors, spaces open to the corridors and all resident sleeping rooms. The facility has a capacity of 68 and had a census of 63 at the time of this PSR survey.</p> <p>All areas where residents have customary access were sprinklered and all areas providing facility services were sprinklered.</p> <p>Quality Review completed on 12/04/24</p> | | | {K 000} | | | |

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

| | | | | | |
|---|--|---|--|----------------------------|--|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155727 | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____ | | (X3) DATE SURVEY COMPLETED R 12/03/2024 |
| NAME OF PROVIDER OR SUPPLIER STONEBRIDGE HEALTH CAMPUS | | | STREET ADDRESS, CITY, STATE, ZIP CODE 3100 SHAWNEE DR S BEDFORD, IN 47421 | | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETION DATE | |
| | | | | | |