

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/22/2025  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155220</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>05/20/2025</b>
NAME OF PROVIDER OR SUPPLIER  <b>DYER NURSING AND REHABILITATION CENTER</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>601 SHEFFIELD AVE</b> <b>DYER, IN 46311</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{E 000}	Initial Comments  A Post Survey Revisit (PSR) to the PSR survey that exited on 04/29/2025 to the Emergency Preparedness Survey that exited on 03/17/2025 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.  Survey Date: 05/20/2025  Facility Number: 000125 Provider Number: 155220 AIM Number: 100266740  At this PSR, Dyer Nursing and Rehabilitation Center was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73 The facility has 161 certified beds. At the time of the survey, the census was 121.	{E 000}			
{K 000}	Quality Review completed on 05/21/25 INITIAL COMMENTS  A Post Survey Revisit (PSR) to the PSR survey that exited on 04/29/2025 to the Life Safety Code Recertification and State Licensure Survey that exited on 03/17/2025 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).  Survey Date: 05/20/2025  Facility Number: 000125 Provider Number: 155220 AIM Number: 100266740  At this PSR, Dyer Nursing and Rehabilitation	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/22/2025  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155220</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>05/20/2025</b>
NAME OF PROVIDER OR SUPPLIER  <b>DYER NURSING AND REHABILITATION CENTER</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>601 SHEFFIELD AVE</b> <b>DYER, IN 46311</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1</p> <p>Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one-story facility was determined to be of Type V (111) construction and fully sprinklered. The facility has a fire alarm system with hard wired smoke detection in resident rooms, in corridors and in spaces open to the corridors. The facility has a capacity of 161 and had a census of 121 at the time of this survey.</p> <p>All areas where residents have customary access and all areas providing facility services were sprinklered.</p> <p>Quality Review completed on 05/21/25</p>	{K 000}			