

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/15/2024
FORM APPROVED
OMB NO. 0938-0391

| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155338 | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____ | (X3) DATE SURVEY COMPLETED R 10/10/2024 |
|---|--|--|--|
| NAME OF PROVIDER OR SUPPLIER MAJESTIC CARE OF AVON | | STREET ADDRESS, CITY, STATE, ZIP CODE 445 S COUNTY ROAD 525 E AVON, IN 46123 | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) |
| {K 000} | <p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 08/26/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 10/10/24</p> <p>Facility Number: 000231 Provider Number: 155338 AIM Number: 100267900</p> <p>At this Life Safety Code survey, Majestic Care of Avon was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), and 410 IAC 16.2. Building 0101, the original building, and Building 0202, which consisted of the Therapy Care Unit (TCU) wing, were surveyed using Chapter 19, Existing Health Care Occupancies.</p> <p>This one-story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and in all areas open to the corridor. The facility has battery operated smoke detectors installed in 63 of 78 resident sleeping rooms and has smoke detectors hard wired to the fire alarm system installed in 15 of 78 resident sleeping rooms. The facility has a capacity of 140 and had a census of 84 at the time of this survey.</p> <p>All areas where the residents have customary</p> | {K 000} | |

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/15/2024
FORM APPROVED
OMB NO. 0938-0391

| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155338 | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____ | (X3) DATE SURVEY COMPLETED R 10/10/2024 | |
|--|---|--|--|--|----------------------------|
| NAME OF PROVIDER OR SUPPLIER MAJESTIC CARE OF AVON | | | STREET ADDRESS, CITY, STATE, ZIP CODE 445 S COUNTY ROAD 525 E AVON, IN 46123 | | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETION DATE |
| {K 000} | Continued From page 1 access were sprinklered and all areas providing facility services were sprinklered. Quality Review completed on 10/11/24 | | {K 000} | | |