

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/29/2023
FORM APPROVED
OMB NO. 0938-0391

| | | | | | |
|---|---|--|--|--|--|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155489 | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____ | | (X3) DATE SURVEY COMPLETED R 08/28/2023 |
| NAME OF PROVIDER OR SUPPLIER PARKER HEALTH CARE & REHABILITATION CENTER | | | STREET ADDRESS, CITY, STATE, ZIP CODE 359 RANDOLPH ST PARKER CITY, IN 47368 | | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | | (X5) COMPLETION DATE |
| {E 000} | Initial Comments A Post Survey Revisit (PSR) to the Emergency Preparedness Survey conducted on 07/10/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73. Survey Date: 08/28/23 Facility Number: 000419 Provider Number: 155489 AIM Number: 100273190 At this PSR Emergency Preparedness survey, Parker Health Care and Rehabilitation Center was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73. The facility has 89 certified beds. At the time of the PSR survey, the census was 60. | {E 000} | | | |
| {K 000} | Quality Review completed on 08/28/23 INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 07/10/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a). Survey Date: 08/28/23 Facility Number: 000419 Provider Number: 155489 AIM Number: 100273190 At this PSR Life Safety Code survey, Parker | {K 000} | | | |

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/29/2023
FORM APPROVED
OMB NO. 0938-0391

| | | | | | |
|---|--|--|--|----------------------------|--|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155489 | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____ | | (X3) DATE SURVEY COMPLETED R 08/28/2023 |
| NAME OF PROVIDER OR SUPPLIER PARKER HEALTH CARE & REHABILITATION CENTER | | | STREET ADDRESS, CITY, STATE, ZIP CODE 359 RANDOLPH ST PARKER CITY, IN 47368 | | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETION DATE | |
| {K 000} | <p>Continued From page 1</p> <p>Health Care & Rehabilitation Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one-story facility was determined to be of Type V (111) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors, and hard-wired smoke detectors in all resident sleeping rooms. The facility has one hall which is assisted living, the presence of a 2 hour rated occupancy separation wall could not be verified and the double door set did not latch, therefore the entire facility was surveyed. The facility has a capacity of 89 and had a census of 60 at the time of this PSR visit.</p> <p>All areas providing facility services were sprinkled and all areas where residents have customary access were sprinkled.</p> <p>Quality Review completed on 08/28/23</p> | {K 000} | | | |