

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/02/2025  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155210</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b>  <b>06/30/2025</b>
NAME OF PROVIDER OR SUPPLIER  <b>WILLOWS OF GREENSBURG</b>			STREET ADDRESS, CITY, STATE, ZIP CODE  <b>410 PARK RD</b> <b>GREENSBURG, IN 47240</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{E 000}	Initial Comments  A Post Survey Revisit (PSR) to the Emergency Preparedness Survey that exited on 04/29/25 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.  Survey Date: 06/30/25  Facility Number: 000117 Provider Number: 155210 AIM Number: 100266460  At this PSR survey, Willows of Greensburg was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73  The facility has 100 certified beds. At the time of the survey, the census was 59.  Quality Review completed on 07/01/25	{E 000}			
{K 000}	INITIAL COMMENTS  A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey that exited on 04/29/25 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).  Survey Date: 06/30/25  Facility Number: 000117 Provider Number: 155210 AIM Number: 100266460  At this PSR survey, Willows of Greensburg was found in compliance with Requirements for	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/02/2025  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155210</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>06/30/2025</b>
NAME OF PROVIDER OR SUPPLIER  <b>WILLOWS OF GREENSBURG</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>410 PARK RD</b> <b>GREENSBURG, IN 47240</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 1  Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.  This one-story facility was determined to be of Type V (000) construction and fully sprinkled. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors and battery-operated smoke detectors in all resident sleeping rooms. The facility has a capacity of 100 and had a census of 59 at the time of this PSR visit.  All areas where residents have customary access were sprinkled and all areas providing facility services were sprinkled.	{K 000}			
{K 361} SS=E	Quality Review completed on 07/01/25 Corridors - Areas Open to Corridor CFR(s): NFPA 101  Corridors - Areas Open to Corridor Spaces (other than patient sleeping rooms, treatment rooms and hazardous areas), waiting areas, nurse's stations, gift shops, and cooking facilities, open to the corridor are in accordance with the criteria under 18.3.6.1 and 19.3.6.1. 18.3.6.1, 19.3.6.1 This REQUIREMENT is not met as evidenced by:	{K 361}			
{K 521} SS=F	HVAC CFR(s): NFPA 101	{K 521}	TEMPORARY WAIVER APPROVED UNTIL 07/21/25		

PRINTED: 07/02/2025  
FORM APPROVED  
OMB NO. 0938-0391

FORM CMS-2567(02-99) Previous Versions Obsolete      Event ID: T19W22      Facility ID: 000117      If continuation sheet Page 3 of 3