

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/09/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155582	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 07/01/2024
NAME OF PROVIDER OR SUPPLIER WATERS OF WAKARUSA SKILLED NURSING FACILITY, THE			STREET ADDRESS, CITY, STATE, ZIP CODE 300 N WASHINGTON ST WAKARUSA, IN 46573		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{E 000}	Initial Comments A Post Survey Revisit (PSR) to the Emergency Preparedness Survey conducted on 05/01/24 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73. Survey Date: 07/01/24 Facility Number: 000521 Provider Number: 155582 AIM Number: 100266980 At this PSR, The Waters of Wakarusa Skilled Nursing Facility was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73 The facility has 133 certified beds. 109 are dually certified for Medicare and Medicaid; 24 are certified for Medicare only. At the time of the survey, the census was 87.	{E 000}			
{K 000}	Quality Review completed on 07/08/24 INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 05/01/24 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a). Survey Date: 07/01/24 Facility Number: 000521 Provider Number: 155582 AIM Number: 100266980	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/09/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155582	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 07/01/2024
NAME OF PROVIDER OR SUPPLIER WATERS OF WAKARUSA SKILLED NURSING FACILITY, THE			STREET ADDRESS, CITY, STATE, ZIP CODE 300 N WASHINGTON ST WAKARUSA, IN 46573		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1</p> <p>At this PSR, The Waters of Wakarusa Skilled Nursing Facility was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and in areas open to the corridors. 73 resident rooms were provided with battery operated smoke detectors. The facility is partially protected by a diesel-powered 230 kW emergency generator. The facility has 133 certified beds. 109 are dually certified for Medicare and Medicaid; 24 are certified for Medicare only. At the time of the survey, the census was 87.</p> <p>Quality Review completed on 07/08/24</p>	{K 000}			