

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/24/2023  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155847</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b>  <b>01/20/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>SILVER MEMORIES HEALTH CARE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>6996 SOUTH US421</b> <b>VERSAILLES, IN 47042</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{E 000}	Initial Comments  A Post Survey Revisit (PSR) to the Emergency Preparedness Survey conducted on 11/28/22 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.  Survey Date: 01/20/23  Facility Number: 000483 Provider Number: 155847 AIM Number: 100273470  At this PSR survey to the Emergency Preparedness survey, Silver Memories Health Care was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73.  The facility has 29 certified beds. At the time of the survey, the census was 28.  Quality Review completed on 01/23/23	{E 000}			
{K 000}	INITIAL COMMENTS  A Post Survey Revisit (PSR) to the Life Safety Recertification and State Licensure Survey conducted on 11/28/22 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).  Survey Date: 01/20/23  Facility Number: 000483 Provider Number: 155847 AIM Number: 100273470  At this PSR survey, Silver Memories Health Care	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/24/2023  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155847</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>01/20/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>SILVER MEMORIES HEALTH CARE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>6996 SOUTH US421</b> <b>VERSAILLES, IN 47042</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1</p> <p>was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This two story facility was determined to be of Type V (111) construction and fully sprinkled. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors, and has battery operated smoke detection in 9 of 11 resident sleeping rooms. The facility has smoke detection harwired to the fire alarm system in Rooms 10 and 11. The facility has a capacity of 29 and had a census of 28 at the time of this visit.</p> <p>All areas where the residents have customary access were sprinkled and all areas providing facility services were sprinkled.</p> <p>Quality Review completed on 01/23/23</p>	{K 000}			