

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/05/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155162	X2) MULTIPLE CONSTRUCTION A. BUILDING: -- B. WING: _____	X3) DATE SURVEY COMPLETED 06/15/2023
--------------------------------------------------	-------------------------------------------------------------	----------------------------------------------------------------	-----------------------------------------

NAME OF PROVIDER OR SUPPLIER  AUTUMN RIDGE REHABILITATION CENTRE	STREET ADDRESS, CITY, STATE, ZIP COD 600 WASHINGTON AVE WABASH, IN 46992
------------------------------------------------------------------------	--------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
E 0000  Bldg. --	<p>An Emergency Preparedness Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.</p> <p>Survey Date: 06/15/23</p> <p>Facility Number: 000081 Provider Number: 155162 AIM Number: 100289570</p> <p>At this Emergency Preparedness survey, Autumn Ridge Rehabilitation Centre was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73. The facility has a capacity of 75 and had a census of 36 at the time of this survey.</p> <p>Quality Review completed on 06/19/23</p>	E 0000		
K 0000  Bldg. 01	<p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 06/15/2023</p> <p>Facility Number: 000081 Provider Number: 155162 AIM Number: 100289570</p> <p>At this Life Safety Code survey, Autumn Ridge Rehabilitation Centre was found not in compliance with Requirements for Participation in</p>	K 0000	Please review for paper compliance.	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
Elizabeth Patton	Executive Director	07/01/2023

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosed days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155162	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 06/15/2023
--------------------------------------------------	-------------------------------------------------------------	--------------------------------------------------------------	-----------------------------------------

NAME OF PROVIDER OR SUPPLIER  AUTUMN RIDGE REHABILITATION CENTRE	STREET ADDRESS, CITY, STATE, ZIP COD 600 WASHINGTON AVE WABASH, IN 46992
------------------------------------------------------------------------	--------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0223 SS=E Bldg. 01	<p>Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This three story facility was determined to be of Type II 111 construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, areas open to the corridors and battery powered smoke detectors in the resident sleeping rooms. The facility has a capacity of 75 and had a census of 36 at the time of this survey.</p> <p>All areas where the residents have customary access were sprinklered. All areas providing facility services were sprinklered.</p> <p>Quality Review completed on 06/19/23</p> <p>NFPA 101 Doors with Self-Closing Devices Doors with Self-Closing Devices Doors in an exit passageway, stairway enclosure, or horizontal exit, smoke barrier, or hazardous area enclosure are self-closing and kept in the closed position, unless held open by a release device complying with 7.2.1.8.2 that automatically closes all such doors throughout the smoke compartment or entire facility upon activation of: * Required manual fire alarm system; and * Local smoke detectors designed to detect smoke passing through the opening or a required smoke detection system; and * Automatic sprinkler system, if installed; and * Loss of power. 18.2.2.2.7, 18.2.2.2.8, 19.2.2.2.7, 19.2.2.2.8 Based on observation and interview, the facility</p>	K 0223	It is the intent of this provider to	07/07/2023

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155162	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED  06/15/2023
--------------------------------------------------	-----------------------------------------------------------------	--------------------------------------------------------------	---------------------------------------------

NAME OF PROVIDER OR SUPPLIER  AUTUMN RIDGE REHABILITATION CENTRE	STREET ADDRESS, CITY, STATE, ZIP COD 600 WASHINGTON AVE WABASH, IN 46992
------------------------------------------------------------------------	--------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>failed to ensure 1 of 1 therapy horizontal exit door is self-closing and kept in the closed position, unless held open by a release device complying with 7.2.1.8.2. This deficient practice could affect up to 5 residents and staff in the therapy room.</p> <p>Findings include:</p> <p>Based on observations during a tour of the facility with the Maintenance Director (MD) on 06/15/23 at 1:55 p.m., the therapy horizontal exit door was held open by a chain. The door from therapy was self-closing, but there was a chain attached to the wall and the door not allowing the door to close. Based on interview at the time of observation, the MD agreed the door was held open with a device that would not release with the fire alarm. The MD disconnected the chain from the door which allowed the door to close.</p> <p>This finding was reviewed with the Administrator and MD at the exit conference.</p> <p>3.1-19(b)</p>		<p>maintain compliance with the regulations for means of ensure horizontal exit door is self-closing and kept in the closed position, unless held open by a release device.</p> <p><b>What corrective action(s) will be accomplished for those residents found to have been affected by the deficient practice;</b> The chain attached to the wall was removed. Staff educated on not holding door open with objects. <b>How other residents having the potential to be affected by the same deficient practice will be identified and what corrective action(s) will be taken;</b> All residents had the potential to be affected by this deficient practice. <b>What measures will be put into place and what systemic changes will be made to ensure that the deficient practice does not recur;</b> The Maintenance Supervisor or designee will complete an in-house audit of all doors to ensure further compliance.</p> <p><b>How the corrective action(s) will be monitored to ensure the deficient practice will not recur, i.e., what quality assurance program will be put into place;and</b> On going compliance with this</p>	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155162	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED  06/15/2023
--------------------------------------------------	-----------------------------------------------------------------	--------------------------------------------------------------	---------------------------------------------

NAME OF PROVIDER OR SUPPLIER  AUTUMN RIDGE REHABILITATION CENTRE	STREET ADDRESS, CITY, STATE, ZIP COD 600 WASHINGTON AVE WABASH, IN 46992
------------------------------------------------------------------------	--------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0300 SS=F Bldg. 01	NFPA 101 Protection - Other Protection - Other List in the REMARKS section any LSC Section 18.3 and 19.3 Protection requirements that are not addressed by the provided K-tags, but are deficient. This		corrective action will be monitored via facility QAPI program, with meetings being held monthly, and is overseen by the Executive Director.  Maintenance Supervisor or designee will document on the Facility Doors K223 QAPI tool on weekly x 4 weeks, monthly x 3 months, and quarterly there after until compliance is achieved. If Threshold of 90% is not met an action plan will be developed to ensure compliance.  <b>By what date the systemic changes for each deficiency will be completed. After submitting an acceptable Plan of Correction, if it is determined that the correction will not be completed by the date previously submitted, The Division needs to be contacted as soon as possible. The facility will need to submit an amended plan of correction with the updated plan of correction date.</b> <b>7/7/23</b>  <b>Please review for paper compliance.</b>	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155162	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 06/15/2023
--------------------------------------------------	-------------------------------------------------------------	--------------------------------------------------------------	-----------------------------------------

NAME OF PROVIDER OR SUPPLIER  AUTUMN RIDGE REHABILITATION CENTRE	STREET ADDRESS, CITY, STATE, ZIP COD 600 WASHINGTON AVE WABASH, IN 46992
------------------------------------------------------------------------	--------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	------------------------------------------------------------------------------------------------------------------------	---------------	-----------------------------------------------------------------------------------------------------------------	----------------------

	<p>information, along with the applicable Life Safety Code or NFPA standard citation, should be included on Form CMS-2567. Based on observation and interview; the facility failed to ensure all battery operated smoke alarms in resident rooms were maintained. NFPA 101 in 4.6.12.3 states existing life safety features obvious to the public, if not required by the Code, shall be maintained. NFPA 72, National Fire Alarm and Signaling Code, 2010 Edition, Section 29.10 states fire-warning equipment shall be maintained and tested in accordance with the manufacturer's published instructions and per the requirements of Chapter 14. Section 14.2.1.1.1 Inspection, testing, and maintenance programs shall satisfy the requirements of this Code and conform to the equipment manufacturer's published instructions. Section 14.4.8.1 states unless otherwise recommended by the manufacturer's published instructions, single- and multiple-station smoke alarms shall be replaced when they fail to respond to operability tests but shall not remain in service longer than 10 years from the date of manufacture. This deficient practice could affect all residents, staff, and visitors.</p> <p>Findings include:</p> <p>Based on observation and interview; the facility failed to ensure all battery operated smoke alarms in resident rooms were manufactured within the past 10 years. Based on observation of battery operated smoke alarms in resident rooms it was indicated the manufacture date was more than 10 years old. Based on interview with the Maintenance Director (MD), he was unaware of the manufactured date of the smoke alarms. MD indicated he would check every battery operated smoke alarm in all residents' rooms for manufacture date and replace if necessary.</p>	K 0300	<p><b>What corrective action(s) will be accomplished for those residents found to have been affected by the deficient practice;</b> The battery-operated smoke alarms have been replaced. <b>How other residents having the potential to be affected by the same deficient practice will be identified and what corrective action(s) will be taken;</b> All residents had the potential to be affected by this deficient practice. <b>What measures will be put into place and what systemic changes will be made to ensure that the deficient practice does not recur;</b> The Maintenance Supervisor or designee will complete an in-house audit of all battery operated smoke alarms to ensure further compliance. Maintenance Supervisor or designee will complete inspection/monitoring monthly as part of the monthly battery powered detector testing currently done via a Tel's task.</p> <p><b>How the corrective action(s) will be monitored to ensure the deficient practice will not recur, i.e., what quality</b></p>	07/07/2023
--	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155162	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED 06/15/2023
--------------------------------------------------	-------------------------------------------------------------	--------------------------------------------------------------	-----------------------------------------

NAME OF PROVIDER OR SUPPLIER  AUTUMN RIDGE REHABILITATION CENTRE	STREET ADDRESS, CITY, STATE, ZIP COD 600 WASHINGTON AVE WABASH, IN 46992
------------------------------------------------------------------------	--------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0355 SS=D Bldg. 01	<p>This finding was reviewed with the Administrator and MD at the exit conference.</p> <p>3.1-19(c)</p> <p>NFPA 101 Portable Fire Extinguishers Portable Fire Extinguishers Portable fire extinguishers are selected, installed, inspected, and maintained in</p>		<p><b>assurance program will be put into place;and</b></p> <p>On going compliance with this corrective action will be monitored via facility QAPI program, with meetings being held monthly, and is overseen by the Executive Director.</p> <p>Maintenance Supervisor or designee will document on the K300 QAPI tool on weekly x 4 weeks, monthly x 3 months, and quarterly there after until compliance is achieved.</p> <p>If Threshold of 90% is not met an action plan will be developed to ensure compliance.</p> <p><b>By what date the systemic changes for each deficiency will be completed. After submitting an acceptable Plan of Correction, if it is determined that the correction will not be completed by the date previously submitted, The Division needs to be contacted as soon as possible. The facility will need to submit an amended plan of correction with the updated plan of correction date.</b></p> <p>7/7/22</p> <p>Please review for paper compliance.</p>	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155162	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED  06/15/2023
--------------------------------------------------	-----------------------------------------------------------------	--------------------------------------------------------------	---------------------------------------------

NAME OF PROVIDER OR SUPPLIER  AUTUMN RIDGE REHABILITATION CENTRE	STREET ADDRESS, CITY, STATE, ZIP COD 600 WASHINGTON AVE WABASH, IN 46992
------------------------------------------------------------------------	--------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>accordance with NFPA 10, Standard for Portable Fire Extinguishers. 18.3.5.12, 19.3.5.12, NFPA 10</p> <p>Based on observation and interview, the facility failed to inspect 1 of 1 portable fire extinguishers on the patio each month. NFPA 10, Standard for Portable Fire Extinguishers, Section 7.2.1.2 states fire extinguishers shall be inspected either manually or by means of an electronic device / system at a minimum of 30-day intervals. Section 7.2.2 states periodic inspection or electronic monitoring of fire extinguishers shall include a check of at least the following items:</p> <ol style="list-style-type: none"> <li>(1) Location in designated place</li> <li>(2) No obstruction to access or visibility</li> <li>(3) Pressure gauge reading or indicator in the operable range or position</li> <li>(4) Fullness determined by weighing or hefting for self expelling-type extinguishers, cartridge-operated extinguishers, and pump tanks</li> <li>(5) Condition of tires, wheels, carriage, hose, and nozzle for wheeled extinguishers</li> <li>(6) Indicator for nonrechargeable extinguishers using push-to-test pressure indicators.</li> </ol> <p>Section 7.2.4.1 states personnel making manual inspections shall keep records of all fire extinguishers inspected, including those found to require corrective action. Section 7.2.4.3 requires where at least monthly manual inspections are conducted, the date the manual inspection was performed and the initials of the person performing the inspection shall be recorded. Section 7.2.4.4 requires where manual inspections are conducted, records for manual inspections shall be kept on a tag or label attached to the fire extinguisher, on an inspection checklist maintained on file, or by an electronic method. Section 7.2.4.5 requires records shall be kept to demonstrate that at least the last 12 monthly inspections have been performed. This deficient</p>	K 0355	<p><b>What corrective action(s) will be accomplished for those residents found to have been affected by the deficient practice;</b></p> <p>The fire extinguisher located on the patio was inspected immediately and was found to be in proper working condition.</p> <p><b>How other residents having the potential to be affected by the same deficient practice will be identified and what corrective action(s) will be taken;</b></p> <p>All residents had the potential to be affected by this deficient practice.</p> <p><b>What measures will be put into place and what systemic changes will be made to ensure that the deficient practice does not recur;</b></p> <p>The Maintenance Supervisor or designee will complete an in-house audit of all fire extinguishers to ensure further compliance.</p> <p>The Maintenance Supervisor or designee will complete inspection/monitoring at monthly as part of the monthly fire extinguisher inspection currently done via a Tels task.</p> <p><b>How the corrective action(s) will be monitored to ensure the deficient practice will not</b></p>	07/07/2023

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155162	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED  06/15/2023
--------------------------------------------------	-----------------------------------------------------------------	--------------------------------------------------------------	---------------------------------------------

NAME OF PROVIDER OR SUPPLIER  AUTUMN RIDGE REHABILITATION CENTRE	STREET ADDRESS, CITY, STATE, ZIP COD 600 WASHINGTON AVE WABASH, IN 46992
------------------------------------------------------------------------	--------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0511 SS=E Bldg. 01	<p>practice could affect staff and residents in the area of the patio.</p> <p>Findings include:</p> <p>Based on observation during a tour of the facility with the Maintenance Director (MD) on 06/15/23 at 1:55 p.m., the monthly inspection tag on the fire extinguisher located on the patio lacked documentation of a monthly inspection from September 2022 through May 2023. Based on interview at the time of observation, the MD confirmed the fire extinguisher located on the patio was missing the September 2022 - May 2023 monthly inspection.</p> <p>This finding was reviewed with the Administrator and MD at the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Utilities - Gas and Electric Utilities - Gas and Electric</p>		<p><b>recur, i.e., what quality assurance program will be put into place;and</b></p> <p>On going compliance with this corrective action will be monitored via facility QAPI program, with meetings being held monthly, and is overseen by the Executive Director.</p> <p>Maintenance Supervisor or designee will document on the Fire extinguishers K355 QAPI tool on weekly x 4 weeks, monthly x 3 months, and quarterly there after until compliance is achieved.</p> <p>If Threshold of 90% is not met an action plan will be developed to ensure compliance.</p> <p><b>By what date the systemic changes for each deficiency will be completed. After submitting an acceptable Plan of Correction, if it is determined that the correction will not be completed by the date previously submitted, The Division needs to be contacted as soon as possible. The facility will need to submit an amended plan of correction with the updated plan of correction date.</b></p> <p>7/7/23</p> <p><b>Please review for paper compliance.</b></p>	



STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155162	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED  06/15/2023
--------------------------------------------------	-----------------------------------------------------------------	--------------------------------------------------------------	---------------------------------------------

NAME OF PROVIDER OR SUPPLIER  AUTUMN RIDGE REHABILITATION CENTRE	STREET ADDRESS, CITY, STATE, ZIP COD 600 WASHINGTON AVE WABASH, IN 46992
------------------------------------------------------------------------	--------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	------------------------------------------------------------------------------------------------------------------------	---------------	-----------------------------------------------------------------------------------------------------------------	----------------------

	<p>Equipment using gas or related gas piping complies with NFPA 54, National Fuel Gas Code, electrical wiring and equipment complies with NFPA 70, National Electric Code. Existing installations can continue in service provided no hazard to life. 18.5.1.1, 19.5.1.1, 9.1.1, 9.1.2</p> <p>Based on observation and interview, the facility failed to ensure 1 of 1 electrical junction boxes in the attic above resident room 319 was protected. NFPA 70, 2011 Edition. Article 406.5 (F) Exposed Terminals, Receptacles shall be enclosed so that live wiring terminals are not exposed to contact. This deficient practice could affect 10 residents in the area of room 319.</p> <p>Findings include:</p> <p>Based on observation during a tour of the facility with the Maintenance Director (MD) on 06/15/23 at 12:40 p.m., in the attic above room 319 there was an electrical junction box with exposed wires because there was no cover. Based on interview at the time of observation, the MD acknowledged the aforementioned condition and confirmed that exposed wiring was visible.</p> <p>This finding was reviewed with the Administrator and MD at the exit conference.</p> <p>3.1-19(b)</p>	K 0511	<p><b>What corrective action(s) will be accomplished for those residents found to have been affected by the deficient practice;</b> The cover was replaced on the electrical junction box. <b>How other residents having the potential to be affected by the same deficient practice will be identified and what corrective action(s) will be taken;</b> All residents had the potential to be affected by this deficient practice. <b>What measures will be put into place and what systemic changes will be made to ensure that the deficient practice does not recur;</b> The Maintenance Supervisor or designee will complete an in-house audit of all electrical junction boxes to ensure further compliance.</p> <p><b>How the corrective action(s) will be monitored to ensure the deficient practice will not recur, i.e., what quality assurance program will be put into place;and</b> On going compliance with this</p>	07/07/2023
--	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155162	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED  06/15/2023
--------------------------------------------------	-----------------------------------------------------------------	--------------------------------------------------------------	---------------------------------------------

NAME OF PROVIDER OR SUPPLIER  AUTUMN RIDGE REHABILITATION CENTRE	STREET ADDRESS, CITY, STATE, ZIP COD 600 WASHINGTON AVE WABASH, IN 46992
------------------------------------------------------------------------	--------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0920 SS=E Bldg. 01	NFPA 101 Electrical Equipment - Power Cords and Extens Electrical Equipment - Power Cords and Extension Cords Power strips in a patient care vicinity are only used for components of movable patient-care-related electrical equipment		corrective action will be monitored via facility QAPI program, with meetings being held monthly, and is overseen by the Executive Director. Maintenance Supervisor or designee will document on the Electrical boxes K511 QAPI tool on weekly x 4 weeks, monthly x 3 months, and quarterly there after until compliance is achieved. If Threshold of 90% is not met an action plan will be developed to ensure compliance. <b>By what date the systemic changes for each deficiency will be completed. After submitting an acceptable Plan of Correction, if it is determined that the correction will not be completed by the date previously submitted, The Division needs to be contacted as soon as possible. The facility will need to submit an amended plan of correction with the updated plan of correction date. 7/7/23 Please review for paper compliance.</b>	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155162	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED  06/15/2023
--------------------------------------------------	-----------------------------------------------------------------	--------------------------------------------------------------	---------------------------------------------

NAME OF PROVIDER OR SUPPLIER  AUTUMN RIDGE REHABILITATION CENTRE	STREET ADDRESS, CITY, STATE, ZIP COD 600 WASHINGTON AVE WABASH, IN 46992
------------------------------------------------------------------------	--------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	------------------------------------------------------------------------------------------------------------------------	---------------	-----------------------------------------------------------------------------------------------------------------	----------------------

	<p>(PCREE) assemblies that have been assembled by qualified personnel and meet the conditions of 10.2.3.6. Power strips in the patient care vicinity may not be used for non-PCREE (e.g., personal electronics), except in long-term care resident rooms that do not use PCREE. Power strips for PCREE meet UL 1363A or UL 60601-1. Power strips for non-PCREE in the patient care rooms (outside of vicinity) meet UL 1363. In non-patient care rooms, power strips meet other UL standards. All power strips are used with general precautions. Extension cords are not used as a substitute for fixed wiring of a structure. Extension cords used temporarily are removed immediately upon completion of the purpose for which it was installed and meets the conditions of 10.2.4. 10.2.3.6 (NFPA 99), 10.2.4 (NFPA 99), 400-8 (NFPA 70), 590.3(D) (NFPA 70), TIA 12-5</p> <p>1. Based on observation and interview, the facility failed to ensure 1 of 1 power strip was not used as a substitute for fixed wiring to provide power equipment with a high current draw. NFPA-70/2011, 400.8 state unless specifically permitted in 400.7 flexible cords and cables shall not be used for (1) as a substitute for fixed wiring. This deficient practice could affect up to 2 residents in resident room 326.</p> <p>Findings include:</p> <p>Based on observation during a tour of the facility with the Maintenance Director (MD) on 06/15/23 at 2:20 p.m., a refrigerator (high power draw equipment) was plugged into and supplied power by a power strip in resident room 326. Based on interview at the time of observation, the Maintenance Director acknowledged a power strip was supplying power to high power draw</p>	K 0920	<p><b>What corrective action(s) will be accomplished for those residents found to have been affected by the deficient practice;</b></p> <p>The refrigerator was plugged into the wall and the power strip was removed immediately. All lamps with built in plug ins were removed immediately from rooms.</p> <p><b>How other residents having the potential to be affected by the same deficient practice will be identified and what corrective action(s) will be taken;</b></p> <p>All residents had the potential to be affected by this deficient practice.</p> <p><b>What measures will be put into place and what systemic</b></p>	07/07/2023
--	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155162	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED  06/15/2023
--------------------------------------------------	-----------------------------------------------------------------	--------------------------------------------------------------	---------------------------------------------

NAME OF PROVIDER OR SUPPLIER  AUTUMN RIDGE REHABILITATION CENTRE	STREET ADDRESS, CITY, STATE, ZIP COD 600 WASHINGTON AVE WABASH, IN 46992
------------------------------------------------------------------------	--------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>equipment. The power strip was removed by the MD at the time of discovery.</p> <p>This finding was reviewed with the Administrator and MD at the exit conference.</p> <p>3.1-19(b)</p> <p>2. Based on observation and interview, the facility failed to ensure 11 resident rooms did not use flexible cords as a substitute for fixed wiring. LSC 9.1.2 requires electrical wiring and equipment shall be in accordance with NFPA 70, National Electrical Code. NFPA 70, 2011 Edition, Article 400.8 requires that, unless specifically permitted, flexible cords and cables shall not be used as a substitute for fixed wiring of a structure. This deficient practice affects up to 15 residents and staff.</p> <p>Findings include:</p> <p>Based on observation on 06/15/23 with the Administrator and Maintenance Director (MD) during a tour of the facility between the hours of 2:00 p.m. and 2:40 p.m., the following was discovered:</p> <p>a) two lamps in resident room #312 had a powered plug in the base that made them an extension cord.</p> <p>b) two lamps in resident room #313 had a powered plug in the base that made them an extension cord.</p> <p>c) two lamps in resident room #314 had a powered plug in the base that made them an extension cord.</p> <p>d) two lamps in resident room #315 had a powered plug in the base that made them an extension cord.</p> <p>e) two lamps in resident room #316 had a powered</p>		<p><b>changes will be made to ensure that the deficient practice does not recur;</b> The Maintenance Supervisor or designee will complete an in-house audit of all rooms to ensure further compliance.</p> <p><b>How the corrective action(s) will be monitored to ensure the deficient practice will not recur, i.e., what quality assurance program will be put into place;and</b> On going compliance with this corrective action will be monitored via facility QAPI program, with meetings being held monthly, and is overseen by the Executive Director. Maintenance Supervisor or designee will document on the refrigerators and lamps K920 QAPI tool on weekly x 4 weeks, monthly x 3 months, and quarterly there after until compliance is achieved. If Threshold of 90% is not met an action plan will be developed to ensure compliance.</p> <p><b>By what date the systemic changes for each deficiency will be completed. After submitting an acceptable Plan of Correction, if it is determined that the correction will not be completed by the date previously submitted, The Division needs to be contacted as soon as possible. The facility</b></p>	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  155162	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	X3) DATE SURVEY COMPLETED  06/15/2023
--------------------------------------------------	-----------------------------------------------------------------	--------------------------------------------------------------	---------------------------------------------

NAME OF PROVIDER OR SUPPLIER  AUTUMN RIDGE REHABILITATION CENTRE	STREET ADDRESS, CITY, STATE, ZIP CODE 600 WASHINGTON AVE WABASH, IN 46992
------------------------------------------------------------------------	---------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
	<p>plug in the base that made them an extension cord.</p> <p>f) two lamps in resident room #317 had a powered plug in the base that made them an extension cord.</p> <p>g) two lamps in resident room #318 had a powered plug in the base that made them an extension cord.</p> <p>h) two lamps in resident room #319 had a powered plug in the base that made them an extension cord.</p> <p>i) two lamps in resident room #320 had a powered plug in the base that made them an extension cord.</p> <p>j) one lamp in resident room #325 had a powered plug in the base that made it an extension cord.</p> <p>k) one lamp in resident room #344 had a powered plug in the base that made it an extension cord.</p> <p>Based on interview at the time of each observation, the Administrator and MD acknowledged each instance of extension cord usage and immediately started removing them from each of the resident rooms.</p> <p>This finding was reviewed with the Administrator and MD at the exit conference.</p> <p>3.1-19(b)</p>		<p><b>will need to submit an amended plan of correction with the updated plan of correction date.</b></p> <p><b>7/7/23</b></p> <p><b>Please review for paper compliance.</b></p>	