

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/29/2024  
FORM APPROVED  
OMB NO. 0938-0391

|   |   |  |  |  |  |  |                            |
|---|---|--|--|--|--|--|----------------------------|
| STATEMENT OF DEFICIENCIES<br>AND PLAN OF CORRECTION                                   |   | (X1) PROVIDER/SUPPLIER/CLIA<br>IDENTIFICATION NUMBER:<br><br><b>155679</b> |  | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING <b>01</b><br><br>B. WING _____                       |  | (X3) DATE SURVEY<br>COMPLETED<br><br><b>R</b><br><br><b>08/23/2024</b> |                            |
| NAME OF PROVIDER OR SUPPLIER<br><br><b>BETHLEHEM WOODS NURSING AND REHABILITATION</b> |   |  |  | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>4430 ELSDALE DR</b><br><b>FORT WAYNE, IN 46835</b> |  |  |                            |
| (X4) ID<br>PREFIX<br>TAG  | SUMMARY STATEMENT OF DEFICIENCIES<br>(EACH DEFICIENCY MUST BE PRECEDED BY FULL<br>REGULATORY OR LSC IDENTIFYING INFORMATION)  |  |  | ID<br>PREFIX<br>TAG  | PROVIDER'S PLAN OF CORRECTION<br>(EACH CORRECTIVE ACTION SHOULD BE<br>CROSS-REFERENCED TO THE APPROPRIATE<br>DEFICIENCY) |  | (X5)<br>COMPLETION<br>DATE |
| {K 000}   | <p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 07/25/24 was conducted by the Indiana Department of Health in accordance 42 CFR Subpart 483.90(a).</p> <p>Survey Date: 08/23/24</p> <p>Facility Number: 000260<br/>Provider Number: 155679<br/>AIM Number: 100267820</p> <p>At this PSR survey, Bethlehem Woods Nursing and Rehabilitation Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, areas open to the corridors and battery operated smoke detectors in the resident rooms. The facility has a capacity of 90 and had a census of 85 at the time of this survey.</p> <p>All areas where the residents have customary access were sprinklered. All areas providing facility services were sprinklered, except a maintenance shed used to store maintenance supplies and a shed used for storage of paperwork.</p> |  |  | {K 000}  |  |  |                            |

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

|   |  |  |  |                            |  |
|---|--|--|--|----------------------------|--|
| STATEMENT OF DEFICIENCIES<br>AND PLAN OF CORRECTION                                   |  | (X1) PROVIDER/SUPPLIER/CLIA<br>IDENTIFICATION NUMBER:<br><br><b>155679</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING <b>01</b><br><br>B. WING _____   |                            | (X3) DATE SURVEY<br>COMPLETED<br><br><b>R</b><br><b>08/23/2024</b> |
| NAME OF PROVIDER OR SUPPLIER<br><br><b>BETHLEHEM WOODS NURSING AND REHABILITATION</b> |  |  | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>4430 ELSDALE DR</b><br><b>FORT WAYNE, IN 46835</b>                           |                            |  |
| (X4) ID<br>PREFIX<br>TAG  | SUMMARY STATEMENT OF DEFICIENCIES<br>(EACH DEFICIENCY MUST BE PRECEDED BY FULL<br>REGULATORY OR LSC IDENTIFYING INFORMATION) | ID<br>PREFIX<br>TAG  | PROVIDER'S PLAN OF CORRECTION<br>(EACH CORRECTIVE ACTION SHOULD BE<br>CROSS-REFERENCED TO THE APPROPRIATE<br>DEFICIENCY) | (X5)<br>COMPLETION<br>DATE |  |
| {K 000}   | Continued From page 1<br>Quality Review completed on 08/28/24  | {K 000}  |  |                            |  |