

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/11/2023  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155582</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>05/10/2023</b>	
NAME OF PROVIDER OR SUPPLIER  <b>WATERS OF WAKARUSA SKILLED NURSING FACILITY, THE</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>300 N WASHINGTON ST</b> <b>WAKARUSA, IN 46573</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A 2nd Post Survey Revisit (PSR) was conducted for the 1st PSR survey that was exited on 04/17/23 for the Life Safety Code Recertification survey that exited on 02/28/23 by the Indiana Department of Health in accordance to 42 CFR 483.90(a)</p> <p>This visit was in conjunction with a PSR to the Life Safety Code Complaint Investigation Survey conducted on 04/19/23.</p> <p>Survey Date: 05/10/23</p> <p>Facility Number: 000521 Provider Number: 155582 AIM Number: 100266980</p> <p>At this Life Safety Code PSR, The Waters of Wakarusa Skilled Nursing Facility was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and in areas open to the corridors. 73 resident rooms were provided with battery operated smoke detectors. The facility is partially protected by a diesel-powered 230 kW emergency generator. The facility has 133 certified beds. 109 are dually certified for Medicare and Medicaid; 24 are certified for Medicare only. At the time of the</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/11/2023  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155582</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>05/10/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>WATERS OF WAKARUSA SKILLED NURSING FACILITY, THE</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>300 N WASHINGTON ST</b> <b>WAKARUSA, IN 46573</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	Continued From page 1 survey, the census was 103.  Quality Review completed on 05/10/23	{K 000}			