

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 0000 Bldg. --	<p>An Emergency Preparedness Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73.</p> <p>Survey Date: 09/26/23</p> <p>Facility Number: 000128 Provider Number: 155223 AIM Number: 100289650</p> <p>At this Emergency Preparedness survey, The Waters of Covington was found not in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73.</p> <p>The facility has 119 certified beds. At the time of the survey, the census was 94.</p> <p>Quality Review completed on 09/27/23</p>			E 0000			
E 0039 SS=F Bldg. --	<p>403.748(d)(2), 416.54(d)(2), 418.113(d)(2), 441.184(d)(2), 482.15(d)(2), 483.475(d)(2), 483.73(d)(2), 484.102(d)(2), 485.625(d)(2), 485.68(d)(2), 485.727(d)(2), 485.920(d)(2), 486.360(d)(2), 491.12(d)(2), 494.62(d)(2)</p> <p>EP Testing Requirements</p> <p>§416.54(d)(2), §418.113(d)(2), §441.184(d)(2), §460.84(d)(2), §482.15(d)(2), §483.73(d)(2), §483.475(d)(2), §484.102(d)(2), §485.68(d)(2), §485.625(d)(2), §485.727(d)(2), §485.920(d)(2), §491.12(d)(2), §494.62(d)(2).</p> <p>*[For ASCs at §416.54, CORFs at §485.68, OPO, "Organizations" under §485.727, CMHCs at §485.920, RHCs/FQHCs at</p>						

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Jerod Williams

HFA

10/09/2023

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>§491.12, and ESRD Facilities at §494.62]:</p> <p>(2) Testing. The [facility] must conduct exercises to test the emergency plan annually. The [facility] must do all of the following:</p> <p>(i) Participate in a full-scale exercise that is community-based every 2 years; or (A) When a community-based exercise is not accessible, conduct a facility-based functional exercise every 2 years; or (B) If the [facility] experiences an actual natural or man-made emergency that requires activation of the emergency plan, the [facility] is exempt from engaging in its next required community-based or individual, facility-based functional exercise following the onset of the actual event.</p> <p>(ii) Conduct an additional exercise at least every 2 years, opposite the year the full-scale or functional exercise under paragraph (d)(2) (i) of this section is conducted, that may include, but is not limited to the following: (A) A second full-scale exercise that is community-based or individual, facility-based functional exercise; or (B) A mock disaster drill; or (C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the [facility's] response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the [facility's] emergency plan, as needed.</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING: -- B. WING: --		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>*[For Hospices at 418.113(d):]</p> <p>(2) Testing for hospices that provide care in the patient's home. The hospice must conduct exercises to test the emergency plan at least annually. The hospice must do the following:</p> <p>(i) Participate in a full-scale exercise that is community based every 2 years; or</p> <p>(A) When a community based exercise is not accessible, conduct an individual facility based functional exercise every 2 years; or</p> <p>(B) If the hospice experiences a natural or man-made emergency that requires activation of the emergency plan, the hospital is exempt from engaging in its next required full scale community-based exercise or individual facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional exercise every 2 years, opposite the year the full-scale or functional exercise under paragraph (d)(2)(i) of this section is conducted, that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or a facility based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(3) Testing for hospices that provide inpatient care directly. The hospice must conduct exercises to test the emergency plan twice per year. The hospice must do the following:</p> <p>(i) Participate in an annual full-scale exercise</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual facility-based functional exercise; or</p> <p>(B) If the hospice experiences a natural or man-made emergency that requires activation of the emergency plan, the hospice is exempt from engaging in its next required full-scale community based or facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional annual exercise that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or a facility based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop led by a facilitator that includes a group discussion using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the hospice's response to and maintain documentation of all drills, tabletop exercises, and emergency events and revise the hospice's emergency plan, as needed.</p> <p>*[For PRFTs at §441.184(d), Hospitals at §482.15(d), CAHs at §485.625(d):]</p> <p>(2) Testing. The [PRTF, Hospital, CAH] must conduct exercises to test the emergency plan twice per year. The [PRTF, Hospital, CAH] must do the following:</p> <p>(i) Participate in an annual full-scale exercise that is community-based; or</p> <p>(A) When a community-based exercise is not</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>accessible, conduct an annual individual, facility-based functional exercise; or</p> <p>(B) If the [PRTF, Hospital, CAH] experiences an actual natural or man-made emergency that requires activation of the emergency plan, the [facility] is exempt from engaging in its next required full-scale community based or individual, facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an [additional] annual exercise or and that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or individual, a facility-based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the [facility's] response to and maintain documentation of all drills, tabletop exercises, and emergency events and revise the [facility's] emergency plan, as needed.</p> <p>*[For PACE at §460.84(d):]</p> <p>(2) Testing. The PACE organization must conduct exercises to test the emergency plan at least annually. The PACE organization must do the following:</p> <p>(i) Participate in an annual full-scale exercise that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise; or</p> <p>(B) If the PACE experiences an actual natural</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>or man-made emergency that requires activation of the emergency plan, the PACE is exempt from engaging in its next required full-scale community based or individual, facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional exercise every 2 years opposite the year the full-scale or functional exercise under paragraph (d)(2)(i) of this section is conducted that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or individual, a facility based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the PACE's response to and maintain documentation of all drills, tabletop exercises, and emergency events and revise the PACE's emergency plan, as needed.</p> <p>*[For LTC Facilities at §483.73(d):]</p> <p>(2) The [LTC facility] must conduct exercises to test the emergency plan at least twice per year, including unannounced staff drills using the emergency procedures. The [LTC facility, ICF/IID] must do the following:</p> <p>(i) Participate in an annual full-scale exercise that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise.</p> <p>(B) If the [LTC facility] facility experiences an actual natural or man-made emergency that</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155223	X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 09/26/2023
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE			STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	<p>requires activation of the emergency plan, the LTC facility is exempt from engaging its next required a full-scale community-based or individual, facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional annual exercise that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or an individual, facility based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the [LTC facility] facility's response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the [LTC facility] facility's emergency plan, as needed.</p> <p>*[For ICF/IIDs at §483.475(d)]:</p> <p>(2) Testing. The ICF/IID must conduct exercises to test the emergency plan at least twice per year. The ICF/IID must do the following:</p> <p>(i) Participate in an annual full-scale exercise that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise; or.</p> <p>(B) If the ICF/IID experiences an actual natural or man-made emergency that requires activation of the emergency plan, the ICF/IID is exempt from engaging in its next required full-scale community-based or individual,</p>				

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>facility-based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional annual exercise that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or an individual, facility-based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the ICF/IID's response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the ICF/IID's emergency plan, as needed.</p> <p>*[For HHAs at §484.102]</p> <p>(d)(2) Testing. The HHA must conduct exercises to test the emergency plan at least annually. The HHA must do the following:</p> <p>(i) Participate in a full-scale exercise that is community-based; or</p> <p>(A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise every 2 years; or.</p> <p>(B) If the HHA experiences an actual natural or man-made emergency that requires activation of the emergency plan, the HHA is exempt from engaging in its next required full-scale community-based or individual, facility based functional exercise following the onset of the emergency event.</p> <p>(ii) Conduct an additional exercise every 2</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>years, opposite the year the full-scale or functional exercise under paragraph (d)(2)(i) of this section is conducted, that may include, but is not limited to the following:</p> <p>(A) A second full-scale exercise that is community-based or an individual, facility-based functional exercise; or</p> <p>(B) A mock disaster drill; or</p> <p>(C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the HHA's response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the HHA's emergency plan, as needed.</p> <p>*[For OPOs at §486.360]</p> <p>(d)(2) Testing. The OPO must conduct exercises to test the emergency plan. The OPO must do the following:</p> <p>(i) Conduct a paper-based, tabletop exercise or workshop at least annually. A tabletop exercise is led by a facilitator and includes a group discussion, using a narrated, clinically relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. If the OPO experiences an actual natural or man-made emergency that requires activation of the emergency plan, the OPO is exempt from engaging in its next required testing exercise following the onset of the emergency event.</p> <p>(ii) Analyze the OPO's response to and maintain documentation of all tabletop exercises, and emergency events, and revise</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>the [RNHCI's and OPO's] emergency plan, as needed.</p> <p>*[RNCHIs at §403.748]: (d)(2) Testing. The RNHCI must conduct exercises to test the emergency plan. The RNHCI must do the following: (i) Conduct a paper-based, tabletop exercise at least annually. A tabletop exercise is a group discussion led by a facilitator, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. (ii) Analyze the RNHCI's response to and maintain documentation of all tabletop exercises, and emergency events, and revise the RNHCI's emergency plan, as needed. Based on record review and interview, the facility failed to conduct exercises to test the emergency plan at least twice per year, including unannounced staff drills using the emergency procedures. The LTC facility must do the following: (i) Participate in an annual full-scale exercise that is community-based; or a. When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise. b. If the LTC facility experiences an actual natural or man-made emergency that requires activation of the emergency plan, the LTC facility is exempt from engaging its next required full-scale community-based or individual, facility-based full-scale functional exercise for 1 year following the onset of the actual event. (ii) Conduct an additional exercise that may include, but is not limited to the following: a. A second full-scale exercise that is community-based or an individual, facility-based</p>			E 0039	<p>DISCLAIMER STATEMENT: Preparation and/or execution of this plan of correction in general, or this corrective action in particular, does not constitute an admission or agreement by this facility of the facts alleged or conclusions set forth in this statement of deficiencies. The plan of correction and specific corrective actions are prepared and/or executed in compliance with state and federal laws. This plan of correction constitutes a written allegation of substantial compliance with Federal Medicare and Medicaid requirements.</p> <p>E039 – It is the intent of the facility to ensure to conduct</p>		10/02/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>functional exercise.</p> <p>b. A mock disaster drill; or</p> <p>c. A tabletop exercise or workshop that is led by a facilitator that includes a group discussion, using a narrated, clinically relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.</p> <p>(iii) Analyze the LTC facility's response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the LTC facility's emergency plan, as needed in accordance with 42 CFR 483.73(d)(2). This deficient practice could affect all occupants.</p> <p>Findings include:</p> <p>Based on review of the facility's Emergency Preparedness Plan on 09/26/23 at 1:28 p.m., documentation of a table top drill was available for review but the facility could not provide documentation of: a full-scale exercise that is community-based or an individual, facility-based functional exercise, a mock disaster drill, or workshop that is led by a facilitator that includes a group discussion, using a narrated, clinically relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. Based on interview at the time of record review, the Maintenance Director agreed that another emergency drill or exercise could not be located for review as of the time of this survey.</p> <p>This finding was reviewed with the facility Administrator, Maintenance Director, and the Regional Property personnel during the exit conference.</p>				<p>exercises to test the emergency plan at least twice per year, including unannounced staff drills using the emergency procedures to meet set standards.</p> <p>1 CORRECTIVE ACTIONS TAKEN:</p> <p>a On 10/2/2023 the Administrator and the Maintenance Supervisor/designee conducted a full scale drill that is community based or an individual, facility-based functional exercise, a mock disaster drill or workshop that is led by a facilitator that includes a group discussion, using a narrated, clinically relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan to meet set standards.</p> <p>2 ALL OTHERS WITH POTENTIAL TO BE AFFECTED:</p> <p>a All residents and all staff and visitors have the potential to be affected but none were.</p> <p>3 MEASURES TO PREVENT REOCCURRENCE:</p> <p>a On 9/27/2023 the Administrator in-serviced the DON/Maintenance Supervisor/designee on the requirement to ensure to conduct exercises to test the emergency plan at least twice per year, including unannounced staff drills using the emergency procedures to meet set standards.</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223	X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 09/26/2023
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE			STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
			<p>b DON/Maintenance Supervisor/designee will work with the Administrator to ensure to conduct exercises to test the emergency plan at least twice per year, including unannounced staff drills using the emergency procedures to meet set standards. If any issues are discovered, they will be addressed and resolved immediately.</p> <p>c The Administrator will monitor adherence to the Emergency Preparedness Policy Manual and validate the documentation is in place.</p> <p>4 MONITORING CORRECTIVE ACTION:</p> <p>a At least annually to ensure compliance, the Administrator and DON/Maintenance Supervisor/designee will review the Emergency Preparedness Policy Manual and conduct required exercises and make changes as necessary to meet set standards. Those reviews will be documented as appropriate. The Administrator will present the training results at the Quality Assurance/Performance Improvement (QA/PI) meeting. Results and system components will be reviewed by the QA/PI Committee with subsequent plans of correction developed and implemented as deemed necessary to ensure compliance is maintained.</p> <p>This plan of correction constitutes our credible</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING: -- B. WING: --		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 0041 SS=C Bldg. --	<p>482.15(e), 483.73(e), 485.625(e) Hospital CAH and LTC Emergency Power §482.15(e) Condition for Participation: (e) Emergency and standby power systems. The hospital must implement emergency and standby power systems based on the emergency plan set forth in paragraph (a) of this section and in the policies and procedures plan set forth in paragraphs (b)(1) (i) and (ii) of this section.</p> <p>§483.73(e), §485.625(e) (e) Emergency and standby power systems. The [LTC facility and the CAH] must implement emergency and standby power systems based on the emergency plan set forth in paragraph (a) of this section.</p> <p>§482.15(e)(1), §483.73(e)(1), §485.625(e)(1) Emergency generator location. The generator must be located in accordance with the location requirements found in the Health Care Facilities Code (NFPA 99 and Tentative Interim Amendments TIA 12-2, TIA 12-3, TIA 12-4, TIA 12-5, and TIA 12-6), Life Safety Code (NFPA 101 and Tentative Interim Amendments TIA 12-1, TIA 12-2, TIA 12-3, and TIA 12-4), and NFPA 110, when a new structure is built or when an existing structure or building is renovated.</p> <p>482.15(e)(2), §483.73(e)(2), §485.625(e)(2) Emergency generator inspection and testing. The [hospital, CAH and LTC facility] must implement the emergency power system</p>				<p>allegation of compliance with all regulatory requirements. Our date of compliance is 10/2/2023.</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>inspection, testing, and [maintenance] requirements found in the Health Care Facilities Code, NFPA 110, and Life Safety Code.</p> <p>482.15(e)(3), §483.73(e)(3), §485.625(e)(3) Emergency generator fuel. [Hospitals, CAHs and LTC facilities] that maintain an onsite fuel source to power emergency generators must have a plan for how it will keep emergency power systems operational during the emergency, unless it evacuates.</p> <p>*[For hospitals at §482.15(h), LTC at §483.73(g), and CAHs §485.625(g):] The standards incorporated by reference in this section are approved for incorporation by reference by the Director of the Office of the Federal Register in accordance with 5 U.S.C. 552(a) and 1 CFR part 51. You may obtain the material from the sources listed below. You may inspect a copy at the CMS Information Resource Center, 7500 Security Boulevard, Baltimore, MD or at the National Archives and Records Administration (NARA). For information on the availability of this material at NARA, call 202-741-6030, or go to: http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html. If any changes in this edition of the Code are incorporated by reference, CMS will publish a document in the Federal Register to announce the changes. (1) National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169, www.nfpa.org, 1.617.770.3000. (i) NFPA 99, Health Care Facilities Code, 2012 edition, issued August 11, 2011.</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>(ii) Technical interim amendment (TIA) 12-2 to NFPA 99, issued August 11, 2011.</p> <p>(iii) TIA 12-3 to NFPA 99, issued August 9, 2012.</p> <p>(iv) TIA 12-4 to NFPA 99, issued March 7, 2013.</p> <p>(v) TIA 12-5 to NFPA 99, issued August 1, 2013.</p> <p>(vi) TIA 12-6 to NFPA 99, issued March 3, 2014.</p> <p>(vii) NFPA 101, Life Safety Code, 2012 edition, issued August 11, 2011.</p> <p>(viii) TIA 12-1 to NFPA 101, issued August 11, 2011.</p> <p>(ix) TIA 12-2 to NFPA 101, issued October 30, 2012.</p> <p>(x) TIA 12-3 to NFPA 101, issued October 22, 2013.</p> <p>(xi) TIA 12-4 to NFPA 101, issued October 22, 2013.</p> <p>(xiii) NFPA 110, Standard for Emergency and Standby Power Systems, 2010 edition, including TIAs to chapter 7, issued August 6, 2009..</p> <p>Based on record review and interview, the facility failed to implement the emergency power system inspection, testing, and maintenance requirements found in the Health Care Facilities Code, NFPA 110, and Life Safety Code in accordance with 42 CFR 483.73(e)(2). This deficient practice could affect all occupants.</p> <p>Findings include:</p> <p>Based on record review with the Maintenance Director on 09/26/23 from 11:48 a.m. to 1:52 p.m., the facility did not have a letter from their natural gas provider indicating the natural gas was from a reliable source. Based on interview with the Maintenance Director at the time of record review,</p>			E 0041	<p>DISCLAIMER STATEMENT: Preparation and/or execution of this plan of correction in general, or this corrective action in particular, does not constitute an admission or agreement by this facility of the facts alleged or conclusions set forth in this statement of deficiencies. The plan of correction and specific corrective actions are prepared and/or executed in compliance with state and federal laws. This plan of correction constitutes a written allegation</p>		09/27/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>he stated the fuel source for the 20kW emergency generator was natural gas and confirmed that a letter of reliability from the natural gas provider was not available for review at the time of the survey.</p> <p>This finding was reviewed with the Administrator, Maintenance Director and Regional Property personnel at the exit conference.</p>				<p>of substantial compliance with Federal Medicare and Medicaid requirements.</p> <p>E041– It is the intent of the facility to ensure to implement the emergency power system inspection, testing and maintenance requirements found in the Health Care Facilities Code, NFPA 110, and Life Safety Code in accordance with 42 CFR 483.73 (e)(2) to meet set standards.</p> <p>1 CORRECTIVE ACTIONS TAKEN:</p> <p>a On 9/27/2023 the Maintenance Supervisor/Administrator obtained a letter from their natural gas provider indicating the natural gas is from a reliable source and documented the information in the facilities Life Safety Binder to meet set standards.</p> <p>2 ALL OTHERS WITH POTENTIAL TO BE AFFECTED:</p> <p>a All residents and all staff and visitors have the potential to be affected but none were.</p> <p>3 MEASURES TO PREVENT REOCCURRENCE:</p> <p>a On 9/27/2023 the Administrator in-serviced the Maintenance Supervisor/designee on the requirement to have a letter from their natural gas provider indicating the natural gas is from a reliable source on file to meet set standards.</p> <p>b The Maintenance</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223	X2) MULTIPLE CONSTRUCTION A. BUILDING -- B. WING _____		X3) DATE SURVEY COMPLETED 09/26/2023
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE			STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 0000			<p>Supervisor/designee will ensure to have a letter from their natural gas provider indicating the natural gas is from a reliable source on file to meet set standards.</p> <p>c The Administrator will monitor adherence to the Emergency Preparedness Policy Manual and validate the documentation is in place.</p> <p>4 MONITORING</p> <p>CORRECTIVE ACTION:</p> <p>a The Administrator and Maintenance Supervisor/designee will review the Emergency Preparedness Policy Manual to ensure it includes a letter from their natural gas provider to meet set standards. Those reviews will be documented as appropriate. The Administrator will present the training results at the Quality Assurance/ Performance Improvement (QA/PI) meeting. Results and system components will be reviewed by the QA/PI Committee with subsequent plans of correction developed and implemented as deemed necessary to ensure compliance is maintained.</p> <p>This plan of correction constitutes our credible allegation of compliance with all regulatory requirements. Our date of compliance is 9/27/2023.</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
Bldg. 01	<p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Date: 09/26/23</p> <p>Facility Number: 000128 Provider Number: 155223 AIM Number: 100289650</p> <p>At this Life Safety Code survey, The Waters of Covington was found not in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one-story facility was determined to be of Type V (000) construction and fully sprinkled. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors, and battery-operated smoke detectors in all resident sleeping rooms. The facility has a capacity of 119 and had a census of 94 at the time of this visit.</p> <p>All areas where residents have customary access were sprinkled and all areas providing facility services were sprinkled except for two detached storage sheds and a detached Garage which were not sprinklered.</p> <p>Quality Review completed on 09/27/23</p>			K 0000			
K 0300 SS=E	NFPA 101 Protection - Other						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
Bldg. 01	<p>Protection - Other</p> <p>List in the REMARKS section any LSC Section 18.3 and 19.3 Protection requirements that are not addressed by the provided K-tags, but are deficient. This information, along with the applicable Life Safety Code or NFPA standard citation, should be included on Form CMS-2567.</p> <p>1. Based on observation and interview; the facility failed to ensure all battery operated smoke alarms in resident rooms were maintained. NFPA 101 in 4.6.12.3 states existing life safety features obvious to the public, if not required by the Code, shall be maintained. NFPA 72, National Fire Alarm and Signaling Code, 2010 Edition, Section 29.10 states fire-warning equipment shall be maintained and tested in accordance with the manufacturer's published instructions and per the requirements of Chapter 14. Section 14.2.1.1.1 Inspection, testing, and maintenance programs shall satisfy the requirements of this Code and conform to the equipment manufacturer's published instructions. Section 14.4.8.1 states unless otherwise recommended by the manufacturer's published instructions, single- and multiple-station smoke alarms shall be replaced when they fail to respond to operability tests but shall not remain in service longer than 10 years from the date of manufacture. This deficient practice could affect all residents, staff, and visitors.</p> <p>Findings include:</p> <p>Based on observation during a tour of the facility with the Maintenance Director on 09/26/23 from 10:04 a.m. to 11:45 p.m.; the battery operated smoke alarms in resident rooms #48 and #22 had a manufacture date of July 20, 2005. Based on interview with the Maintenance Director, he was unaware of the manufactured date of the smoke</p>			K 0300	<p>DISCLAIMER STATEMENT: Preparation and/or execution of this plan of correction in general, or this corrective action in particular, does not constitute an admission or agreement by this facility of the facts alleged or conclusions set forth in this statement of deficiencies. The plan of correction and specific corrective actions are prepared and/or executed in compliance with state and federal laws. This plan of correction constitutes a written allegation of substantial compliance with Federal Medicare and Medicaid requirements.</p> <p>K300– It is the intent of the facility to ensure all battery-operated smoke alarms in resident rooms are maintained and to ensure documentation for the preventative maintenance of battery-operated smoke alarms in resident rooms is complete to meet set standards.</p> <p>1 CORRECTIVE ACTIONS TAKEN: a On 10/9/2023 the Maintenance Supervisor/designee</p>		10/09/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>alarms and that they are to be replaced after 10 years. The Maintenance Director stated he has been installing newer battery operated smoke alarms in resident rooms when they have failed. During the tour of the facility, there were two different models of battery operated smoke alarms installed in resident rooms. The Maintenance Director stated about half of the 69 resident rooms had the model of smoke alarms installed with the July 20, 2005 manufacture date.</p> <p>This finding was discussed with Administrator, Maintenance Director and Regional Property personnel at the exit conference.</p> <p>2. Based on record review, interview and observation, the facility failed to ensure documentation for the preventative maintenance of 69 of 69 battery operated smoke alarms in resident rooms was complete. NFPA 101 in 4.6.12.3 states existing life safety features obvious to the public, if not required by the Code, shall be maintained. NFPA 72, 29.10 Maintenance and Tests. Fire-warning equipment shall be maintained and tested in accordance with the manufacturer's published instructions and per the requirements of Chapter 14. NFPA 72, 14.2.1.1.1 Inspection, testing, and maintenance programs shall satisfy the requirements of this Code and conform to the equipment manufacturer's published instructions. This deficient practice could affect all residents, staff, and visitors.</p> <p>Findings include:</p> <p>Based on review of the Battery Operated Smoke Detector Maintenance Logs on 09/26/23 from 11:48 a.m. to 1:52 p.m. with the Maintenance Director present, the resident room battery operated smoke alarms were tested on a monthly</p>				<p>replaced the battery-operated smoke alarms, including the batteries, in resident rooms 48 & 22 that had manufacture dates of 7-20-05 and checked all other battery powered smoke alarms in the building and replaced any others that were not meeting manufacturer's guidelines to meet set standards. The Administrator verified the work on 10/9/2023 .</p> <p>b On 9/27/2023 the Administrator inserviced the Maintenance Supervisor/designee on the requirement that all battery-operated smoke detectors must be tested per manufacture's guidelines and documentation retained at the facility to meet set standards.</p> <p>c On 10/9/2023 the Maintenance Supervisor/designee tested all battery-operated smoke detectors including room 42 and documented the results in the facilities Life Safety Binder to meet set standards. The Administrator verified the work on 10/9/2023 .</p> <p>2 ALL OTHERS WITH POTENTIAL TO BE AFFECTED:</p> <p>a All residents and all staff and visitors have the potential to be affected but none were.</p> <p>3 MEASURES TO PREVENT REOCCURRENCE:</p> <p>a Maintenance Supervisor/designee will ensure all battery-operated smoke alarms are maintained and tested per</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>basis during the past twelve months. Based on observation with the Maintenance Director during a tour of the facility, the battery operated smoke detector located in resident room #42 was a Kidde model i9050 manufactured May 2017 and requires weekly testing. Based on interview at the time of review and observation, the Maintenance Director stated that all battery-operated smoke detectors in the facility are tested monthly and confirmed that manufacturers instructions of the one in resident room #42 called for weekly testing. The Maintenance Director stated he has installed the same model of battery operated smoke detector as in room #42 in other resident rooms as the older smoke detectors fail, but has not kept track of which rooms have different detectors. The Maintenance Director stated he would start performing testing as required by manufacture's instruction.</p> <p>This finding was reviewed with the Administrator, Maintenance Director and Regional Property personnel at the exit conference.</p> <p>3.1-19(c)</p>				<p>manufactures guidelines and will document the results on the Battery-Operated Smoke Detector Maintenance Log to be filed in the Life Safety Binder as a part of the facility's Preventive Maintenance Program. If any issues are discovered, they will be addressed and resolved immediately. The Maintenance Supervisor/designee will review with the Administrator the inspection results.</p> <p>b The Administrator will monitor adherence to the Preventative Maintenance schedule and validate the Preventative Maintenance documentation is in place.</p> <p>4 MONITORING</p> <p>CORRECTIVE ACTION:</p> <p>a The inspection results will be presented by the Maintenance Supervisor/designee to the Administrator monthly and the Administrator will present the inspection results at the monthly Quality Assurance/Performance Improvement (QA/PI) meeting. Inspection results and system components will be reviewed by the QA/PI Committee with subsequent plans of correction developed and implemented as deemed necessary to ensure compliance is maintained.</p> <p>This plan of correction constitutes our credible allegation of compliance with all regulatory requirements. Our date of compliance is</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0321 SS=E Bldg. 01	<p>NFPA 101 Hazardous Areas - Enclosure Hazardous Areas - Enclosure Hazardous areas are protected by a fire barrier having 1-hour fire resistance rating (with 3/4 hour fire rated doors) or an automatic fire extinguishing system in accordance with 8.7.1 or 19.3.5.9. When the approved automatic fire extinguishing system option is used, the areas shall be separated from other spaces by smoke resisting partitions and doors in accordance with 8.4. Doors shall be self-closing or automatic-closing and permitted to have nonrated or field-applied protective plates that do not exceed 48 inches from the bottom of the door. Describe the floor and zone locations of hazardous areas that are deficient in REMARKS. 19.3.2.1, 19.3.5.9</p> <p>Area Automatic Sprinkler Separation N/A a. Boiler and Fuel-Fired Heater Rooms b. Laundries (larger than 100 square feet) c. Repair, Maintenance, and Paint Shops d. Soiled Linen Rooms (exceeding 64 gallons) e. Trash Collection Rooms (exceeding 64 gallons) f. Combustible Storage Rooms/Spaces (over 50 square feet) g. Laboratories (if classified as Severe Hazard - see K322) Based on observation and interview, the facility failed to ensure 1 of 1 filing room with a large amount of combustible storage and greater than</p>			K 0321	<p>10/9/2023.</p> <p>DISCLAIMER STATEMENT: Preparation and/or execution of this plan of correction in</p>		10/09/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>50 square feet was protected as a hazardous area. This deficient practice could affect 10 residents in the area of Fountain Wing nurse station.</p> <p>Findings include:</p> <p>Based on observation during a tour of the facility with the Maintenance Director on 09/26/23 at 1:30 p.m., the filing room, located across the corridor from Fountain Wing nurse station contained over 50 plastic boxes full of paper files, 5 filing cabinets and was greater than 50 square feet making this a hazardous area. The filing room was not protected as a hazardous area because the corridor door to the room was not equipped with a self closing device. Based on interview at the time of observation, the Maintenance Director agreed the filing room contained a large amount of combustible storage, was larger than 50 square feet, and the corridor door to the room did not have a self-closing device.</p> <p>The finding was reviewed with the Administrator, the Maintenance Director and Regional Property personnel during the exit conference.</p> <p>3.1-19(b)</p>				<p>general, or this corrective action in particular, does not constitute an admission or agreement by this facility of the facts alleged or conclusions set forth in this statement of deficiencies. The plan of correction and specific corrective actions are prepared and/or executed in compliance with state and federal laws. This plan of correction constitutes a written allegation of substantial compliance with Federal Medicare and Medicaid requirements.</p> <p>K321– It is the intent of the facility to ensure filing room with a large amount of combustible storage and greater than 50 square feet is protected as a hazardous area to meet set standards.</p> <p>1 CORRECTIVE ACTIONS TAKEN:</p> <p>a On 9/27/2023 the Maintenance Supervisor/designee installed a self-closing device on the filing room door to meet set standards. The Administrator verified the work on 10/9/2023.</p> <p>2 ALL OTHERS WITH POTENTIAL TO BE AFFECTED:</p> <p>a All residents and all staff and visitors have the potential to be affected but none were.</p> <p>3 MEASURES TO PREVENT REOCCURRENCE:</p> <p>a On 9/27/2023 the Administrator in-serviced the</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE			STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
			<p>Maintenance Supervisor/designee on the requirement to ensure hazardous areas are equipped with a self-closing device to meet set standards.</p> <p>b Maintenance Supervisor/designee will inspect all hazardous area doors to ensure they have a self-closing device as a part of the facility's monthly Preventive Maintenance Program and document those inspection results as appropriate. If any issues are discovered, they will be addressed and resolved immediately. The Maintenance Supervisor/designee will review with the Administrator the inspection results.</p> <p>c The Administrator will monitor adherence to the Preventative Maintenance schedule and validate the Preventative Maintenance documentation is in place.</p> <p>4 MONITORING</p> <p>CORRECTIVE ACTION:</p> <p>a The inspection results will be presented by the Maintenance Supervisor/designee to the Administrator monthly and the Administrator will present the inspection results at the monthly Quality Assurance/Performance Improvement (QA/PI) meeting. Inspection results and system components will be reviewed by the QA/PI Committee with subsequent plans of correction developed and implemented as</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE			STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 0353 SS=F Bldg. 01	<p>NFPA 101 Sprinkler System - Maintenance and Testing Sprinkler System - Maintenance and Testing Automatic sprinkler and standpipe systems are inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintaining of Water-based Fire Protection Systems. Records of system design, maintenance, inspection and testing are maintained in a secure location and readily available.</p> <p>a) Date sprinkler system last checked</p> <p>b) Who provided system test</p> <p>c) Water system supply source</p> <p>Provide in REMARKS information on coverage for any non-required or partial automatic sprinkler system. 9.7.5, 9.7.7, 9.7.8, and NFPA 25 1. Based on observation and interview, the facility failed to ensure 1 of 1 sprinkler systems were provided with spare sprinklers, a spare sprinkler cabinet and a sprinkler wrench on the premises. NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems, 2011 Edition, Section 5.4.1.4 states a supply of spare sprinklers (never fewer than six) shall be maintained on the premises so that any sprinklers that have been operated or damaged in</p>	K 0353	<p>deemed necessary to ensure compliance is maintained. This plan of correction constitutes our credible allegation of compliance with all regulatory requirements. Our date of compliance is 10/9/2023.</p> <p>DISCLAIMER STATEMENT: Preparation and/or execution of this plan of correction in general, or this corrective action in particular, does not constitute an admission or agreement by this facility of the facts alleged or conclusions set forth in this statement of deficiencies. The plan of</p>	10/27/2023	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>any way can be promptly replaced. The sprinklers shall correspond to the types and temperature ratings of the sprinklers on the property. The sprinklers shall be kept in a cabinet located where the temperature in which they are subjected will at no time exceed 100 degrees Fahrenheit. A special sprinkler wrench shall be provided and kept in the cabinet to be used in the removal and installation of sprinklers. This deficient practice could affect all residents and staff in the facility.</p> <p>Findings include:</p> <p>Based on observations and interview during a tour of the facility with the Maintenance Director on 09/26/23 at 10:28 a.m., there was one spare sprinkler cabinet in the riser room. Six spare sprinklers were sitting loose in the box and five were secured in holders. Based on interview at the time of the observation, the Maintenance Director agreed the spare sprinkler cabinet had spare sprinklers not in protected slots.</p> <p>This finding was reviewed with the Administrator, Maintenance Director and Regional Property personnel at the exit conference.</p> <p>2. Based on observation and interview, the facility failed to ensure sprinkler heads in the facility were not loaded or covered with foreign material in accordance with LSC 9.7.5. NFPA 25, 2011 edition, at 5.2.1.1.1 sprinklers shall not show signs of leakage; shall be free of corrosion, foreign materials, paint, and physical damage; and shall be installed in the correct orientation (e.g., up-right, pendent, or sidewall). Furthermore, at 5.2.1.1.2 any sprinkler that shows signs of any of the following shall be replaced: (1) Leakage (2) Corrosion (3) Physical Damage (4) Loss of fluid in the glass bulb heat responsive element (5)</p>				<p>correction and specific corrective actions are prepared and/or executed in compliance with state and federal laws. This plan of correction constitutes a written allegation of substantial compliance with Federal Medicare and Medicaid requirements.</p> <p>K353 – It is the intent of the facility to ensure to document sprinkler systems are provided with spare sprinklers, a spare sprinkler cabinet and a sprinkler wrench on the premises and to ensure sprinkler heads in the facility are not loaded or covered with foreign material in accordance with LSC 9.7.5 to meet set standards.</p> <p>1.CORRECTIVE ACTIONS TAKEN:</p> <p>1.On 10/5/2023 the Maintenance Supervisor/designee secured the six spare sprinklers in protected slots that were sitting loose in the box to meet set standards. The Administrator verified the work on 10/9/2023.</p> <p>2.On 10/5/2023 the facilities certified sprinkler contractor ordered the sprinkler heads in the 1. housekeeping closet by resident room 50 that was green in color and showing signs of corrosion 2. In the housekeeping closet by Fountain wing nurse station that was green in color and</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>Loading (6) Painting unless painted by the sprinkler manufacturer. This deficient practice could affect staff and up to 8 residents.</p> <p>Findings include:</p> <p>Based on observations and interview during a tour of the facility with the Maintenance Director on 09/26/23 between 10:04 a.m. and 11:45 a.m., the following was noted:</p> <p>1) the sprinkler head in the housekeeping closet by resident room 50 was green on color and showed signs of corrosion.</p> <p>2) the sprinkler head in the housekeeping closet by Fountain Wing nurse station was green in color and showed signs of corrosion.</p> <p>This finding was reviewed with the Administrator, Maintenance Director and Regional Property personnel at the exit conference.</p> <p>3.1-19(b)</p>				<p>showed signs of corrosion to meet set standards. The Administrator verified sprinklers were ordered on 10/9/2023.</p> <p>2.ALL OTHERS WITH POTENTIAL TO BE AFFECTED:</p> <p>1.All residents and all staff and visitors have the potential to be affected but none were.</p> <p>3.MEASURES TO PREVENT REOCCURRENCE:</p> <p>1.On 9/27/2023 the Administrator in-serviced the Maintenance Supervisor/designee on the requirement that the spare sprinkler heads must be in protected slots and the sprinkler heads must be maintained and not loaded or covered with corrosion to meet set standards.</p> <p>2.Maintenance Supervisor/designee will ensure the spare sprinkler heads must be in protected slots and the sprinkler heads must be maintained and not loaded or covered with corrosion as a part of the facility's monthly Preventive Maintenance Program and document those inspection results as appropriate. If any issues are discovered, they will be addressed and resolved immediately. The Maintenance Supervisor/designee will review with the Administrator the inspection results.</p> <p>3.The Administrator will monitor adherence to the Preventative Maintenance schedule and validate the</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE			STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 0363 SS=D Bldg. 01	NFPA 101 Corridor - Doors Corridor - Doors Doors protecting corridor openings in other than required enclosures of vertical openings, exits, or hazardous areas resist the passage of smoke and are made of 1 3/4 inch solid-bonded core wood or other material capable of resisting fire for at least 20 minutes. Doors in fully sprinklered smoke compartments are only required to resist the passage of smoke. Corridor doors and doors to rooms containing flammable or combustible materials have positive latching		Preventative Maintenance documentation is in place. 4.MONITORING CORRECTIVE ACTION: 1.The inspection results will be presented by the Maintenance Supervisor/designee to the Administrator monthly and the Administrator will present the inspection results at the monthly Quality Assurance/Performance Improvement (QA/PI) meeting. Inspection results and system components will be reviewed by the QA/PI Committee with subsequent plans of correction developed and implemented as deemed necessary to ensure compliance is maintained. This plan of correction constitutes our credible allegation of compliance with all regulatory requirements. Our date of compliance is by 10/27/2023.		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>hardware. Roller latches are prohibited by CMS regulation. These requirements do not apply to auxiliary spaces that do not contain flammable or combustible material. Clearance between bottom of door and floor covering is not exceeding 1 inch. Powered doors complying with 7.2.1.9 are permissible if provided with a device capable of keeping the door closed when a force of 5 lbf is applied. There is no impediment to the closing of the doors. Hold open devices that release when the door is pushed or pulled are permitted. Nonrated protective plates of unlimited height are permitted. Dutch doors meeting 19.3.6.3.6 are permitted. Door frames shall be labeled and made of steel or other materials in compliance with 8.3, unless the smoke compartment is sprinklered. Fixed fire window assemblies are allowed per 8.3. In sprinklered compartments there are no restrictions in area or fire resistance of glass or frames in window assemblies.</p> <p>19.3.6.3, 42 CFR Parts 403, 418, 460, 482, 483, and 485</p> <p>Show in REMARKS details of doors such as fire protection ratings, automatics closing devices, etc.</p> <p>Based on observation and interview, the facility failed to ensure 1 of 69 resident room corridor doors were provided with a means suitable for keeping the door closed, had no impediment to closing, latching and would resist the passage of smoke. This deficient practice could affect 2 residents.</p> <p>Findings include:</p> <p>Based on observation with the Maintenance</p>			K 0363	<p>DISCLAIMER STATEMENT: Preparation and/or execution of this plan of correction in general, or this corrective action in particular, does not constitute an admission or agreement by this facility of the facts alleged or conclusions set forth in this statement of deficiencies. The plan of correction and specific</p>		09/27/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>Director on 09/26/23 during a tour of the facility at 10:12 a.m., the corridor door to resident room 29 did not latch into the frame when tested. Based on interview at the time of observation, the Maintenance Director agreed the corridor door would not latch into the door frame.</p> <p>This finding was reviewed with the Administrator, Maintenance Director and Regional Property personnel at the exit conference.</p> <p>3.1-19(b)</p>				<p>corrective actions are prepared and/or executed in compliance with state and federal laws. This plan of correction constitutes a written allegation of substantial compliance with Federal Medicare and Medicaid requirements.</p> <p>K363 – It is the intent of the facility to ensure resident room corridor doors are provided with a means suitable for keeping the door closed, have no impediment to closing, latching and will resist the passage of smoke to meet set standards.</p> <p>1 CORRECTIVE ACTIONS TAKEN: a On 9/27/2023 the Maintenance Supervisor/designee repaired the corridor door to resident room 29 so the door would close and latch fully into the frame to meet set standards. The Administrator verified the work on 10/9/2023.</p> <p>2 ALL OTHERS WITH POTENTIAL TO BE AFFECTED: a All residents and all staff and visitors have the potential to be affected but none were. The Maintenance Supervisor/designee inspected all corridor doors to ensure they close and latch fully into the frame and found no other negative findings.</p> <p>3 MEASURES TO PREVENT REOCCURRENCE: a On 9/27/2023 the</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE			STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
			<p>Administrator in-serviced the Maintenance Supervisor/designee and all staff on the requirement that corridor doors must close and latch fully into the frame to meet set standards.</p> <p>b Maintenance Supervisor/designee will inspect all corridor doors throughout the facility monthly to ensure they close and latch fully into the frame as a part of the facility's Preventive Maintenance Program and document those inspection results as appropriate. If any issues are discovered, they will be addressed and resolved immediately. The Maintenance Supervisor/designee will review with the Administrator the inspection results.</p> <p>c The Administrator will monitor adherence to the Preventative Maintenance schedule and validate the Preventative Maintenance documentation is in place.</p> <p>4 MONITORING</p> <p>CORRECTIVE ACTION:</p> <p>a The inspection results will be presented by the Maintenance Supervisor/designee to the Administrator monthly and the Administrator will present the inspection results at the monthly Quality Assurance/Performance Improvement (QA/PI) meeting. Inspection results and system components will be reviewed by the QA/PI Committee with subsequent plans of correction</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE			STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 0511 SS=F Bldg. 01	<p>NFPA 101 Utilities - Gas and Electric Utilities - Gas and Electric Equipment using gas or related gas piping complies with NFPA 54, National Fuel Gas Code, electrical wiring and equipment complies with NFPA 70, National Electric Code. Existing installations can continue in service provided no hazard to life. 18.5.1.1, 19.5.1.1, 9.1.1, 9.1.2 Based on record review and interview, the facility failed to ensure that the emergency generator had a reliable source of fuel in accordance with the requirements of NFPA 101 - 2012 edition, Section 19.5.1.1, 9.1, 9.1.3.1 and NFPA 110, 2010 Edition, 5.1. LSC section 9.1.3.1 states emergency generators shall be installed, tested and maintained in accordance with NFPA 110, Standard for Emergency and Standby Power Systems, 2010 Edition. Section 5.1.1 states the following energy sources shall be permitted to be used for the emergency power supply (EPS): (1) Liquid petroleum products at atmospheric pressure (2) Liquefied petroleum gas (liquid or vapor withdrawal) (3) Natural or synthetic gas Exception: For Level 1 installations in locations where the probability of interruption of off-site fuel supplies is high, on-site storage of an</p>	K 0511	<p>developed and implemented as deemed necessary to ensure compliance is maintained. This plan of correction constitutes our credible allegation of compliance with all regulatory requirements. Our date of compliance is 9/27/2023.</p> <p>DISCLAIMER STATEMENT: Preparation and/or execution of this plan of correction in general, or this corrective action in particular, does not constitute an admission or agreement by this facility of the facts alleged or conclusions set forth in this statement of deficiencies. The plan of correction and specific corrective actions are prepared and/or executed in compliance with state and federal laws. This plan of correction constitutes a written allegation of substantial compliance with Federal Medicare and Medicaid requirements. K511 – It is the intent of the</p>	09/27/2023	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023

FORM APPROVED

OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>alternate energy source sufficient to allow full output of the EPSS to be delivered for the class specified shall be required, with the provision for automatic transfer from the primary energy source to the alternate energy source.</p> <p>A.5.1.1 states examples of probability of interruption could include the following: earthquake, flood damage, or a demonstrated utility unreliability. This deficient practice could affect all residents.</p> <p>Findings include:</p> <p>Based on record review with the Maintenance Director on 09/26/23 from 11:48 a.m. to 1:52 p.m., the facility did not have a letter from their natural gas provider indicating the natural gas was from a reliable source. Based on interview with the Maintenance Director at the time of record review, he stated the fuel source for the 20kW emergency generator was natural gas and confirmed that a letter of reliability from the natural gas provider was not available for review at the time of the survey.</p> <p>This finding was reviewed with the Administrator, Maintenance Director and Regional Property personnel at the exit conference.</p> <p>3.1-19(b)</p>				<p>facility to ensure the emergency generator has a reliable source of fuel in accordance with the requirements of NFPA 101 – 2012 edition, section 19.5.1.1, 9.1, 9.1.3.1 and NFPA 110, 2010 edition, 5.1 to meet set standards.</p> <p>1 CORRECTIVE ACTIONS TAKEN:</p> <p>a On 9/27/2023 the Maintenance Supervisor/Administrator obtained a letter from their natural gas provider indicating the natural gas is from a reliable source and documented the information in the facilities Life Safety Binder to meet set standards.</p> <p>2 ALL OTHERS WITH POTENTIAL TO BE AFFECTED:</p> <p>a All residents and all staff and visitors have the potential to be affected but none were.</p> <p>3 MEASURES TO PREVENT REOCCURRENCE:</p> <p>a On 9/27/2023 the Administrator in-serviced the Maintenance Supervisor/designee on the requirement to have a letter from their natural gas provider on file indicating the natural gas is from a reliable source to meet set standards.</p> <p>b The Maintenance Supervisor/designee will ensure to have a letter from their natural gas provider indicating the natural gas is from a reliable source on file as a part of the facility's monthly Preventive Maintenance</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE			STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 0761 SS=E Bldg. 01	1. Based on observation, records review, and	K 0761	<p>Program. If any issues are discovered, they will be addressed and resolved immediately. The Maintenance Supervisor/designee will review with the Administrator the inspection results.</p> <p>c The Administrator will monitor adherence to the Preventative Maintenance schedule and validate the Preventative Maintenance documentation is in place.</p> <p>4.MONITORING CORRECTIVE ACTION:</p> <p>a. The inspection results will be presented by the Maintenance Supervisor/designee to the Administrator monthly and the Administrator will present the inspection results at the monthly Quality Assurance/Performance Improvement (QA/PI) meeting. Inspection results and system components will be reviewed by the QA/PI Committee with subsequent plans of correction developed and implemented as deemed necessary to ensure compliance is maintained.</p> <p>This plan of correction constitutes our credible allegation of compliance with all regulatory requirements. Our date of compliance is 9/27/2023.</p> <p>DISCLAIMER STATEMENT:</p>	09/27/2023	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>interview, the facility failed to ensure annual inspection and testing of 1 of 1 fire door assemblies on the oxygen transfilling room door were completed in accordance with LSC 19.1.1.4.1.1. Communicating openings in dividing fire barriers required by 19.1.1.4.1 shall be permitted only in corridors and shall be protected by approved self-closing fire door assemblies. (See also Section 8.3.) LSC 8.3.3.1 Openings required to have a fire protection rating by Table 8.3.4.2 shall be protected by approved, listed, labeled fire door assemblies and fire window assemblies and their accompanying hardware, including all frames, closing devices, anchorage, and sills in accordance with the requirements of NFPA 80, Standard for Fire Doors and Other Opening Protectives, except as otherwise specified in this Code. NFPA 80 5.2.1 states fire door assemblies shall be inspected and tested not less than annually, and a written record of the inspection shall be signed and kept for inspection by the AHJ. NFPA 80, 5.2.3.1 states functional testing of fire door and window assemblies shall be performed by individuals with knowledge and understanding of the operating components of the type of door being subject to testing. NFPA 80, 5.2.4.1 states fire door assemblies shall be visually inspected from both sides to assess the overall condition of door assembly.</p> <p>NFPA 80, 5.2.4.2 states as a minimum, the following items shall be verified:</p> <p>(1) No open holes or breaks exist in surfaces of either the door or frame.</p> <p>(2) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.</p> <p>(3) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order with no visible signs of</p>				<p>Preparation and/or execution of this plan of correction in general, or this corrective action in particular, does not constitute an admission or agreement by this facility of the facts alleged or conclusions set forth in this statement of deficiencies. The plan of correction and specific corrective actions are prepared and/or executed in compliance with state and federal laws. This plan of correction constitutes a written allegation of substantial compliance with Federal Medicare and Medicaid requirements.</p> <p>K761 – It is the intent of the facility to ensure annual inspection and testing of all fire door assemblies are completed in accordance of LSC 19.1.1.4.1.1 and to ensure fire door assemblies are maintained in accordance with LSC 19.1.1.4.1.1 to meet set standards.</p> <p>1 CORRECTIVE ACTIONS TAKEN:</p> <p>a On 9/27/2023 the Maintenance Supervisor/designee conducted the annual inspection of the oxygen transfilling room door assembly and documented the inspection results on the Annual Door Inspections log to meet set standards. The Administrator verified the inspection and documentation on</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>damage.</p> <p>(4) No parts are missing or broken.</p> <p>(5) Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7.</p> <p>(6) The self-closing device is operational; that is, the active door completely closes when operated from the fully open position.</p> <p>(7) If a coordinator is installed, the inactive leaf closes before the active leaf.</p> <p>(8) Latching hardware operates and secures the door when it is in the closed position.</p> <p>(9) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame.</p> <p>(10) No field modifications to the door assembly have been performed that void the label.</p> <p>(11) Gasketing and edge seals, where required, are inspected to verify their presence and integrity. This deficient practice could affect at least 10 residents and staff.</p> <p>Findings include:</p> <p>Based on record review with the Maintenance Director on 09/26/23 from 11:48 a.m. to 1:52 p.m., no annual inspection of the oxygen transfilling room door assembly was available for review. Based on observation during the tour between 10:04 a.m. and 11:45 a.m., there was an oxygen transfilling room near the activity room with a one and a half hour fire rated door. Based on interview at the time of records review, the Maintenance Director stated that he was unaware that the oxygen transfilling room fire door needed to be inspected annually.</p> <p>This finding was reviewed with the Administrator, Maintenance Director, and Regional Property personnel at the exit conference.</p>				<p>10/9/2023.</p> <p>b On 9/27/2023 the Maintenance Supervisor/designee removed the paint from the fire resistance rating labels affixed to both doors in the corridor door set by the beauty shop to meet set standards. The Administrator verified the work on 10/9/2023.</p> <p>2 ALL OTHERS WITH POTENTIAL TO BE AFFECTED:</p> <p>a All residents and all staff and visitors have the potential to be affected but none were.</p> <p>3 MEASURES TO PREVENT REOCCURRENCE:</p> <p>a On 9/27/2023 the Administrator/corporate Property Manager inserviced the Maintenance Supervisor/designee on the requirement that annual testing & inspections of fire door assemblies, including the door to the oxygen transfilling room, must be conducted, and documented on the Annual Door Inspections log and fire resistance rating labels affixed to doors must be maintained and not painted to meet set standards.</p> <p>b Maintenance Supervisor/designee will ensure to conduct the annual inspection of fire door assemblies, including the door to the oxygen transfilling room and document those inspection results as appropriate and will ensure to maintain fire resistance labels affixed to doors</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>2. Based on observation and interview; the facility failed to ensure 1 of 10 fire door assemblies were maintained in accordance with LSC 19.1.1.4.1.1. Communicating openings in dividing fire barriers required by 19.1.1.4.1 shall be permitted only in corridors and shall be protected by approved self-closing fire door assemblies. (See also Section 8.3.) LSC 8.3.3.1 Openings required to have a fire protection rating by Table 8.3.4.2 shall be protected by approved, listed, labeled fire door assemblies and fire window assemblies and their accompanying hardware, including all frames, closing devices, anchorage, and sills in accordance with the requirements of NFPA 80, Standard for Fire Doors and Other Opening Protectives, except as otherwise specified in this Code. NFPA 80 5.2.1 states fire door assemblies shall be inspected and tested not less than annually, and a written record of the inspection shall be signed and kept for inspection by the AHJ. NFPA 80, 5.2.4.1 states fire door assemblies shall be visually inspected from both sides to assess the overall condition of door assembly.</p> <p>NFPA 80, 5.2.4.2 states as a minimum, the following items shall be verified:</p> <p>(1) No open holes or breaks exist in surfaces of either the door or frame.</p> <p>(2) Glazing, vision light frames, and glazing beads are intact and securely fastened in place, if so equipped.</p> <p>(3) The door, frame, hinges, hardware, and noncombustible threshold are secured, aligned, and in working order with no visible signs of damage.</p> <p>(4) No parts are missing or broken.</p> <p>(5) Door clearances do not exceed clearances listed in 4.8.4 and 6.3.1.7.</p> <p>(6) The self-closing device is operational; that is, the active door completely closes when operated</p>				<p>and ensure there is no paint or any other material obstructing the fire resistance labels to meet set standards. If any issues are discovered, they will be addressed and resolved immediately. The Maintenance Supervisor/designee will review with the Administrator the inspection results.</p> <p>c The Administrator will monitor adherence to the Preventative Maintenance schedule and validate the Preventative Maintenance documentation is in place.</p> <p>4 MONITORING</p> <p>CORRECTIVE ACTION:</p> <p>a The inspection results will be presented by the Maintenance Supervisor/designee to the Administrator monthly and the Administrator will present the inspection results at the monthly Quality Assurance/Performance Improvement (QA/PI) meeting. Inspection results and system components will be reviewed by the QA/PI Committee with subsequent plans of correction developed and implemented as deemed necessary to ensure compliance is maintained.</p> <p>This plan of correction constitutes our credible allegation of compliance with all regulatory requirements. Our date of compliance is 9/27/2023.</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 0911 SS=E Bldg. 01	<p>from the full open position.</p> <p>(7) If a coordinator is installed, the inactive leaf closes before the active leaf.</p> <p>(8) Latching hardware operates and secures the door when it is in the closed position.</p> <p>(9) Auxiliary hardware items that interfere or prohibit operation are not installed on the door or frame.</p> <p>(10) No field modifications to the door assembly have been performed that void the label.</p> <p>(11) Gasketing and edge seals, where required, are inspected to verify their presence and integrity.</p> <p>This deficient practice could affect over 15 residents, staff and visitors.</p> <p>Findings include:</p> <p>Based on observation with the Maintenance Director during a tour of the facility at 10:17 a.m. on 09/26/23, the fire resistance rating labels affixed to both doors in the corridor door set by the beauty shop were painted. Based on interview at the time of the observation, the Maintenance Director confirmed the fire resistance rating labels on the doors were painted.</p> <p>This finding was reviewed with the Administrator, Maintenance Director and Regional Property personnel during the exit conference.</p> <p>3.1-19(b)</p> <p>NFPA 101 Electrical Systems - Other Electrical Systems - Other List in the REMARKS section any NFPA 99 Chapter 6 Electrical Systems requirements that are not addressed by the provided K-Tags, but are deficient. This information, along with the applicable Life Safety Code or</p>						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>NFPA standard citation, should be included on Form CMS-2567. Chapter 6 (NFPA 99) Based on observation and interview, the facility failed to ensure access and working space was maintained in enclosures housing electrical panels in the entry/lounge area mechanical room. NFPA 99, Health Care Facilities Code, 2012 Edition, Section 6.3.2.1 states electrical installation shall be in accordance with NFPA 70, National Electric Code. NFPA 70, 2011 Edition, Article 110.26 states access and working space shall be provided and maintained about all electrical equipment to permit ready and safe operation and maintenance of such equipment. Working space for equipment operating at 600 volts, nominal, or less and likely to require examination, adjustment, servicing, or maintenance while energized shall comply with the dimensions of 110.26(A) (1), (2) and (3). 110.26(A)(1) states the depth of the working space in the direction of live parts shall not be less than that specified in Table 110.26(A) (1) which the minimum clear distance is 3 feet. 110.26(A) (2) states the width of the working space in front of the electrical equipment shall be the width of the equipment or 762 mm (30 in.), whichever is greater. In all cases, the workspace shall permit at least a 90-degree opening of equipment doors or hinged panels. 110.26(A)(3) states the workspace shall be clear and extend from the grade, floor, or platform to a height of 6'2 feet or the height of the equipment, whichever is greater. Article 110.26(B) states the working space required by this section shall not be used for storage. This deficient practice could affect staff in the vicinity of the entry/lounge area.</p> <p>Findings include:</p> <p>Based on observations during a tour of the facility</p>			K 0911	<p>DISCLAIMER STATEMENT: Preparation and/or execution of this plan of correction in general, or this corrective action in particular, does not constitute an admission or agreement by this facility of the facts alleged or conclusions set forth in this statement of deficiencies. The plan of correction and specific corrective actions are prepared and/or executed in compliance with state and federal laws. This plan of correction constitutes a written allegation of substantial compliance with Federal Medicare and Medicaid requirements. K911 - It is the intent of the facility to ensure access and working space is maintained in enclosures housing electrical panels in the entry/lounge area mechanical room to meet set standards.</p> <p>1 CORRECTIVE ACTIONS TAKEN: a On 9/28/2023 the Maintenance Supervisor/designee removed the items stored in front of the electrical panels in the mechanical room to meet set standards. The Administrator verified the removal of the items on 10/9/2023.</p> <p>2 ALL OTHERS WITH</p>		10/10/2023

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223		X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023	
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 1600 E LIBERTY ST COVINGTON, IN 47932			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
	<p>with the Maintenance Director on 09/26/23 at 10:37 a.m., the mechanical room by the employee time clock had three electrical panels, generator transfer switch that were blocked from access with four flatscreen televisions and other items stored in front of the panels. Based on interview at the time of the observation, the Maintenance Director agreed items were stored within the working space in front of the electrical panels.</p> <p>The finding was reviewed with the Administrator, Maintenance Director and Regional Property personnel during the exit conference.</p> <p>3.1-19(b)</p>				<p>POTENTIAL TO BE AFFECTED:</p> <p>a All residents and all staff and visitors have the potential to be affected but none were. On 9/27/2023 the Maintenance Supervisor/designee inspected all other areas and found no other negative findings.</p> <p>3 MEASURES TO PREVENT REOCCURRENCE:</p> <p>a On 10/10/2023 the Administrator in-serviced the Maintenance Supervisor/designee and all other staff on the requirement that nothing is to impede access to workspaces including electrical power panels to meet set standards.</p> <p>b Maintenance Supervisor/designee will inspect all electrical power panels throughout the facility weekly to ensure there are no impediments to accessing the panels as a part of the facility's Preventive Maintenance Program and document those inspection results as appropriate. If any issues are discovered, they will be addressed and resolved immediately. The Maintenance Supervisor/designee will review with the Administrator the inspection results.</p> <p>c The Administrator will monitor adherence to the Preventative Maintenance schedule and validate the Preventative Maintenance documentation is in place.</p> <p>4 MONITORING</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/13/2023
FORM APPROVED
OMB NO. 0938-039

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER 155223	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING		X3) DATE SURVEY COMPLETED 09/26/2023
NAME OF PROVIDER OR SUPPLIER WATERS OF COVINGTON, THE			STREET ADDRESS, CITY, STATE, ZIP COD 1600 E LIBERTY ST COVINGTON, IN 47932		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIE (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
			CORRECTIVE ACTION: a The inspection results will be presented by the Maintenance Supervisor/designee to the Administrator monthly and the Administrator will present the inspection results at the monthly Quality Assurance/Performance Improvement (QA/PI) meeting. Inspection results and system components will be reviewed by the QA/PI Committee with subsequent plans of correction developed and implemented as deemed necessary to ensure compliance is maintained. This plan of correction constitutes our credible allegation of compliance with all regulatory requirements. Our date of compliance is 10/10/2023.		