DEPARTMENT OF HEALTH AND HUMAN SERVICES CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/13/2023 FORM APPROVED OMB NO. 0938-0391

| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: | 1 ' ' | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 | | | (X3) DATE SURVEY COMPLETED | |
|---|--|--|--------------------|--|---|-----------------|-------------------------------|--|
| | | 155265 | B. WING | B. WING | | 07/10/2023 | | |
| NAME OF PROVIDER OR SUPPLIER WEDGEWOOD HEALTHCARE CENTER | | | | STREET ADDRESS, CITY, STATE, ZIP CODE 101 POTTERS LN CLARKSVILLE, IN 47129 | | | | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | | ID PREFI TAG | EFIX (EACH CORRECTIVE ACTION SHO | | D BE COMPLETION | | |
| E 000 | Initial Comments | | E | 000 | | | | |
| | | aredness Survey was iana Department of Health in CFR 483.73. | | | | | | |
| | Survey Date: 07/10/23 | | | | | | | |
| | Facility Number: 000 Provider Number: 15 AIM Number: 10026 | 55265 | | | | | | |
| | compliance with Eme Requirements for Me | are Center was found in rgency Preparedness | | | | | | |
| | The facility has 124 c the survey, the censu | ertified beds. At the time of us was 100. | | | | | | |
| K 000 | Quality Review comp INITIAL COMMENTS | | К | 000 | 0 | | | |
| | Licensure Survey was | decertification and State s conducted by the Indiana n in accordance with 42 CFR | | | | | | |
| | Survey Date: 07/10/23 | | | | | | | |
| | Facility Number: 000 Provider Number: 15 AIM Number: 10026 | 55265 | | | | | | |
| | | de survey, Wedgewood as found in compliance with ticipation | | | | | | |

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE (X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/13/2023 FORM APPROVED OMB NO. 0938-0391

| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: | A. BUILDI | TIPLE CONSTRUCTION ING 01 | | (X3) DATE SURVEY COMPLETED | | | |
|---|--|--|-----------|--|------------|----------------------------|---------|--|--|
| | | 155265 | B. WING | | | 07/ | 10/2023 | | |
| NAME OF PROVIDER OR SUPPLIER WEDGEWOOD HEALTHCARE CENTER | | | | STREET ADDRESS, CITY, STATE, ZIP CODE 101 POTTERS LN CLARKSVILLE, IN 47129 | | | , | | |
| (X4) ID PREFIX TAG | (EACH DEFICIENC | ID PREFI TAG | | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD E CROSS-REFERENCED TO THE APPROPRI DEFICIENCY) | BE | (X5) COMPLETION DATE | | | |
| K 000 | Continued From page 1 Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety From Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This one story facility was determined to be of Type V (111) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridor and in all areas open to the corridor. The facility has smoke detectors hard wired to the fire alarm system installed in resident sleeping rooms 501 through 512 and has battery operated smoke alarms installed in all other resident sleeping rooms. The facility has a capacity of 124 and had a census of 100 at the time of this visit. All areas where the residents have customary access were sprinklered and all areas providing facility services were sprinklered. Quality Review completed on 07/12/23 | | K | 000 | DETICIENCY | | | | |