

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/14/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155181		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/11/2023	
NAME OF PROVIDER OR SUPPLIER CARMEL HEALTH & LIVING COMMUNITY				STREET ADDRESS, CITY, STATE, ZIP CODE 118 MEDICAL DR CARMEL, IN 46032			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>A Pre-Occupancy Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a).</p> <p>Survey Dates: 07/11/23</p> <p>Facility Number: 000095 Provider Number: 155181 AIM Number: 100290490</p> <p>At this Pre-Occupancy Life Safety Code survey, Carmel Health & Living Community was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one-story facility with a partial walkout lower level was determined to be of Type V (111) construction and fully sprinklered. The facility has a fire alarm system with smoke detection on all levels in the corridors and in all areas open to the corridor. The facility has smoke detectors hard wired to the fire alarm system in resident sleeping rooms in the 700 and 800 Hall. The facility has battery operated smoke detectors in resident sleeping rooms in the 200, 300, 400 and 500 Hall. The facility has a capacity of 188 and had a census of 127 at the time of this visit.</p> <p>All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered.</p>			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/14/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155181	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/11/2023
NAME OF PROVIDER OR SUPPLIER CARMEL HEALTH & LIVING COMMUNITY			STREET ADDRESS, CITY, STATE, ZIP CODE 118 MEDICAL DR CARMEL, IN 46032		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>Continued From page 1</p> <p>The scope of work included Reconfiguring the means of egress by replacement and relocation of an existing exterior door with delayed-egress hardware. The relocation of the door reduces the length of Corridor 742. Exit marking is modified to direct occupants to the compliant required exits of the compartment.</p> <p>Quality Review completed on 07/13/23</p>	K 000			