

City of Fort Wayne  
River Survey 2005  
St. Joseph River @ Tennessee Street

Wk	Date	Depth(ft)	ECOLI	DO	Temp(F)	pH	PHOS	NH3-N	TSS
1	04/04/05	12.09	19	12.45	47.5	6.76	0.20	0.020	7
2	04/11/05	11.74	20	10.84	57.3	7.27	0.08	0.020	14
3	04/18/05	8.39	40	12.45	57.8	7.84	0.06	0.100	28
4	04/25/05	12.74	387	12.29	47.1	6.62	0.01	0.030	16
5	05/02/05	11.11	70	12.49	51.0	6.62	0.09	0.020	14
6	05/09/05	8.50	18	11.18	62.8	7.46	0.08	0.020	13
7	05/18/05	8.89	110	9.93	59.0	7.56	0.10	0.100	25
8	05/23/05	9.38	111	6.45	62.4	8.06	0.10	0.020	22
9	05/31/05	7.94	192	5.54	65.5	8.23	0.05	0.026	20
10	06/06/05	7.11	5200	No Data	69.8	7.87	0.09	0.045	26
11	06/13/05	8.44	1986	No Data	76.7	7.48	0.10	0.103	8
12	06/20/05	6.96	109	8.01	69.7	8.03	0.09	0.100	24
13	06/27/05	10.53	50	14.38	82.3	8.37	0.02	0.020	8
14	07/05/05	6.59	87	5.41	76.7	7.85	0.05	0.002	18
15	07/11/05	5.05	157	6.02	77.5	7.82	0.16	0.002	32
16	07/18/05	10.73	210	7.08	78.5	8.13	0.13	0.002	20
17	07/25/05	11.21	34	9.78	81.9	7.98	0.13	0.100	12
18	08/01/05	10.94	99	6.07	76.1	7.88	0.14	0.148	38
19	08/08/05	10.14	921	8.41	79.9	8.66	0.09	0.100	14
20	08/15/05	6.51	249	No Data	77.6	7.78	0.14	0.100	11
21	08/22/05	10.70	140	7.44	77.3	7.93	0.11	0.100	17
22	08/29/05	10.17	45	7.20	76.5	8.18	0.11	0.100	14
23	09/06/05	10.50	35	8.79	73.5	7.92	0.26	0.421	12
24	09/13/05	10.43	14	12.71	75.8	8.16	0.11	0.100	13
25	09/19/05	10.89	28	8.58	70.1	8.00	0.10	0.100	8
26	09/26/05	11.54	1300	8.50	70.7	8.82	0.19	0.100	72
27	10/03/05	11.26	68	9.13	71.6	8.95	0.07	0.100	18
28	10/10/05	11.23	40	8.16	60.8	7.16	0.12	0.100	15
29	10/17/05	11.20	67	10.29	58.4	8.19	0.09	0.100	20
30	10/24/05	10.34	199	8.41	53.2	7.78	0.08	0.103	21
31	10/31/05	11.29	16	11.77	50.7	7.49	0.02	0.100	12
	Max.	12.74	5200	14.38	81.90	8.82	0.260	0.421	72
	Min.	5.05	14	5.41	47.10	6.62	0.01	0.002	7
	Avg.	9.82	388	9.28	67.60	7.83	0.10	0.081	19

E.Coli = colonies per 100 mls, yellow indicates >235

PHOS = Total Phosphorus mg/l, NH3-N = Ammonia-Nitrogen mg/l, DO = Dissolved Oxygen mg/l

TSS = Total Suspended Solids mg/l

City of Fort Wayne  
River Survey 2005  
St. Marys River @ Spy Run Avenue

Wk	Date	Depth(ft)	ECOLI	DO	Temp(F)	pH	PHOS	NH3-N	TSS
1	04/04/05	9.51	345	11.51	45.9	6.47	0.21	0.038	46
2	04/11/05	9.16	61	11.45	58.3	7.09	0.23	0.020	44
3	04/18/05	6.12	35	22.31	60.9	7.78	0.13	0.100	49
4	04/25/05	10.43	6890	11.51	42.6	6.45	0.58	1.010	166
5	05/02/05	8.77	192	10.11	50.2	6.28	0.28	0.042	47
6	05/09/05	6.22	73	14.50	64.2	7.38	0.12	0.050	29
7	05/18/05	6.67	291	11.99	59.3	7.40	0.21	0.300	29
8	05/23/05	7.28	291	6.58	62.9	7.98	0.28	0.020	22
9	05/31/05	5.57	77	7.84	67.0	8.35	0.13	0.020	32
10	06/06/05	4.82	1733	7.57	73.6	7.80	0.13	0.020	44
11	06/13/05	6.05	46110	No Data	73.8	7.86	0.23	0.114	53
12	06/20/05	4.84	613	8.27	68.7	7.89	0.23	0.100	55
13	06/27/05	8.51	727	18.85	82.8	8.69	0.05	0.002	16
14	07/05/05	4.53	326	6.84	77.2	7.76	0.31	0.002	51
15	07/11/05	3.11	461	11.04	76.3	7.96	0.26	0.002	70
16	07/18/05	8.47	1120	No Data	77.7	7.59	0.16	0.002	19
17	07/25/05	8.68	118	5.95	83.8	8.39	0.36	0.100	19
18	08/01/05	9.20	344	7.75	77.0	8.48	0.21	0.025	31
19	08/08/05	8.20	37	7.91	81.1	8.56	0.23	0.147	24
20	08/15/05	8.31	866	5.44	76.3	7.57	0.26	0.200	18
21	08/22/05	8.64	365	8.04	78.2	7.91	0.14	0.100	21
22	08/29/05	8.26	50	6.11	76.9	8.16	0.18	0.100	19
23	09/06/05	8.56	59	5.91	70.9	7.59	0.42	0.015	37
24	09/13/05	8.34	17	10.81	74.7	7.96	0.14	0.100	16
25	09/19/05	8.54	194	11.54	69.6	8.30	0.23	0.200	22
26	09/26/05	9.45	>2420	5.80	68.1	7.20	0.26	0.114	68
27	10/03/05	9.10	345	7.19	63.1	7.26	0.37	0.100	84
28	10/10/05	8.76	161	7.81	58.9	6.95	0.20	0.100	29
29	10/17/05	8.95	111	9.38	57.7	7.78	0.19	0.100	31
30	10/24/05	8.37	115	9.43	52.9	7.69	0.19	0.100	30
31	10/31/05	8.58	93	10.36	47.1	6.96	0.29	0.100	36
	Max.	10.43	46110	22.31	83.8	8.69	0.580	1.010	166
	Min.	3.11	17	5.44	42.6	6.28	0.05	0.002	16
	Avg.	7.74	2007	9.65	67.0	7.66	0.23	0.111	40

E.Coli = colonies per 100 mls, yellow indicates >235

PHOS = Total Phosphorus mg/l, NH3-N = Ammonia-Nitrogen mg/l, DO = Dissolved Oxygen mg/l

TSS = Total Suspended Solids mg/l

City of Fort Wayne  
River Survey 2005  
Maumee River @ Anthony Boulevard

Wk	Date	Depth(ft)	ECOLI	DO	Temp(F)	pH	PHOS	NH3-N	TSS
1	04/04/05	4.26	102	12.40	46.8	6.15	0.17	0.020	26
2	04/11/05	2.76	41	10.91	57.5	6.77	0.17	0.020	32
3	04/18/05	1.98	19	13.11	58.9	7.14	0.08	0.100	50
4	04/25/05	9.01	1733	12.14	43.2	6.43	0.58	0.898	154
5	05/02/05	3.95	145	10.89	50.4	6.11	0.30	0.028	39
6	05/09/05	2.13	40	12.78	62.5	6.92	0.08	0.020	26
7	05/18/05	2.18	179	9.60	59.0	7.10	0.14	0.100	40
8	05/23/05	2.65	152	5.79	62.7	7.79	0.18	0.020	32
9	05/31/05	1.59	50	5.49	66.3	8.57	0.13	0.024	38
10	06/06/05	1.64	4220	6.33	73.1	7.89	0.11	0.020	26
11	06/13/05	2.30	22820	No Data	75.8	7.81	0.12	0.061	27
12	06/20/05	1.74	345	8.64	70.4	8.00	0.15	0.100	50
13	06/27/05	1.06	96	10.02	78.6	7.77	0.07	0.085	12
14	07/05/05	1.37	365	7.54	77.6	7.69	0.01	0.002	39
15	07/11/05	0.89	76	10.82	77.9	7.69	0.19	0.002	34
16	07/18/05	1.45	548	6.43	78.9	7.89	0.14	0.002	24
17	07/25/05	1.40	105	5.43	83.3	8.09	0.15	0.100	17
18	08/01/05	1.97	260	6.01	76.7	7.49	0.15	0.154	40
19	08/08/05	0.90	45	6.08	78.2	7.83	0.11	0.184	17
20	08/15/05	1.27	2203	5.35	77.1	7.67	0.14	0.200	12
21	08/22/05	1.32	228	8.06	78.2	7.84	0.17	0.100	12
22	08/29/05	0.93	31	5.15	75.6	7.58	0.15	0.100	21
23	09/06/05	1.08	29	8.73	71.7	7.86	0.24	0.034	18
24	09/13/05	0.55	18	6.38	73.6	6.99	0.11	0.100	17
25	09/19/05	0.85	365	7.71	69.3	7.32	0.15	0.200	13
26	09/26/05	4.57	>2420	8.52	69.3	7.39	0.12	0.100	26
27	10/03/05	3.41	517	9.02	63.3	7.26	0.32	0.100	119
28	10/10/05	0.99	135	8.88	60.5	6.84	0.16	0.100	27
29	10/17/05	1.15	161	9.86	58.6	7.77	0.11	0.100	28
30	10/24/05	0.62	>2420	9.22	54.6	7.41	0.14	0.176	34
31	10/31/05	1.50	54	11.43	47.5	6.99	0.27	0.100	35
	Max.	9.01	22820	13.11	83.3	8.57	0.580	0.898	154
	Min.	0.55	18	5.15	43.2	6.11	0.01	0.002	12
	Avg.	2.05	1132	8.62	67.0	7.42	0.16	0.108	35

E.Coli = colonies per 100 mls, yellow indicates >235

PHOS = Total Phosphorus mg/l, NH3-N = Ammonia-Nitrogen mg/l, DO = Dissolved Oxygen mg/l

TSS = Total Suspended Solids mg/l

City of Fort Wayne  
River Survey 2005  
Maumee River @ Landin Road

Wk	Date	Depth(ft)	ECOLI	DO	Temp(F)	pH	PHOS	NH3-N	TSS
1	04/04/05	7.68	84	12.35	47.7	6.98	0.17	0.243	24
2	04/11/05	6.74	47	10.93	57.2	7.27	0.17	0.026	35
3	04/18/05	5.90	13	14.94	60.4	7.91	0.14	0.100	46
4	04/25/05	12.59	4430	11.95	43.7	6.96	0.56	0.961	184
5	05/02/05	7.74	111	11.08	50.6	7.03	0.26	0.034	44
6	05/09/05	6.09	23	12.84	62.3	7.47	0.18	0.020	24
7	05/18/05	6.30	435	10.52	60.0	7.58	0.16	0.100	40
8	05/23/05	6.60	238	5.49	63.4	8.04	0.17	0.020	36
9	05/31/05	5.43	40	No Data	66.6	8.29	0.12	0.022	32
10	06/06/05	5.35	345	5.68	72.5	7.89	0.25	0.020	38
11	06/13/05	6.40	10760	No Data	75.4	7.67	0.11	0.132	28
12	06/20/05	4.97	192	9.05	70.5	7.98	0.18	0.100	34
13	06/27/05	4.30	61	8.74	79.9	7.93	0.07	0.036	16
14	07/05/05	5.02	144	6.53	77.4	7.81	0.05	0.021	21
15	07/11/05	4.06	84	10.99	78.3	8.04	0.18	0.002	32
16	07/18/05	5.71	866	5.69	78.0	7.83	0.27	0.002	28
17	07/25/05	5.08	261	8.67	82.8	7.68	0.38	0.100	14
18	08/01/05	5.51	488	5.48	75.9	7.57	0.19	0.167	43
19	08/08/05	3.83	178	6.12	79.5	7.51	0.15	0.191	18
20	08/15/05	4.87	1986	5.09	75.7	7.42	0.39	0.200	12
21	08/22/05	4.08	308	6.59	76.1	7.42	0.18	0.295	14
22	08/29/05	4.45	147	6.99	75.6	7.52	0.21	0.165	30
23	09/06/05	4.37	138	6.49	72.8	7.63	0.25	0.098	29
24	09/13/05	4.13	126	6.02	74.0	7.22	0.28	0.100	32
25	09/19/05	4.30	517	6.25	69.7	7.25	0.19	0.200	21
26	09/26/05	8.11	>2420	5.99	69.1	7.41	0.34	0.195	66
27	10/03/05	6.71	387	8.56	63.9	7.51	0.39	0.100	76
28	10/10/05	4.71	166	8.29	60.7	7.32	0.25	0.130	26
29	10/17/05	4.54	82	9.22	58.0	7.82	0.17	0.100	19
30	10/24/05	4.41	727	9.28	53.7	7.67	0.13	0.268	26
31	10/31/05	5.65	91	10.79	48.5	7.39	0.29	0.100	43
Max.		12.59	10760	14.94	82.8	8.29	0.560	0.961	184
Min.		3.83	13	5.09	43.7	6.96	0.05	0.002	12
Avg.		5.66	757	8.50	67.1	7.58	0.220	0.137	36

E.Coli = colonies per 100 mls, yellow indicates >235

PHOS = Total Phosphorus mg/l, NH3-N = Ammonia-Nitrogen mg/l, DO = Dissolved Oxygen mg/l

TSS = Total Suspended Solids mg/l

City of Fort Wayne  
River Survey 2006  
St. Joseph River @ Tennessee Street

Wk	Date	Depth(ft)	pH	DO	Temp(F)	ECOLI	NH3-N	PHOS	TSS
1	04/03/06	11.56	7.25	12.19	50.28	517	0.05	0.05	30
2	04/10/06	10.66	7.43	11.51	51.09	70	0.05	0.11	42
3	04/17/06	12.9	7.48	10.40	60.07	866	0.05	0.10	28
4	04/24/06	9.92	7.51	9.69	60.61	100	0.05	0.14	37
5	05/01/06	8.48	7.43	9.67	57.68	308	0.05	0.18	28
6	05/08/06	9.32	8.07	10.45	62.44	45	0.05	0.31	28
7	05/15/06	13.97	7.38	10.60	52.80	687	0.24	0.29	54
8	05/22/06	12.78	7.47	10.28	59.29	86	0.05	0.12	46
9	05/30/06	11.02	7.99	9.65	73.64	86	0.05	0.03	21
10	06/05/06	11.14	7.21	8.80	68.74	184	0.05	0.06	28
11	06/12/06	10.97	7.49	8.65	67.46	126	0.05	0.06	20
12	06/19/06	10.81	7.61	6.84	73.81	228	0.05	0.90	16
13	06/26/06	11.54	7.28	7.51	74.57	122	0.05	0.19	34
14	07/06/06	10.89	7.91	9.88	73.45	66	0.05	0.25	31
15	07/10/06	11.48	7.36	7.53	74.55	45	0.05	0.10	42
16	07/17/06	12.56	7.12	8.16	76.76	372	0.05	0.21	59
17	07/24/06	10.19	7.56	7.48	75.88	96	0.05	0.14	24
18	07/31/06	11.35	7.49	7.74	78.00	488	0.05	0.19	35
19	08/07/06	8.29	7.19	7.10	78.86	81	0.05	0.16	40
20	08/14/06	5.24	7.84	6.66	73.73	58	0.05	0.21	27
21	08/21/06	6.92	7.91	7.37	73.73	365	0.05	0.13	18
22	08/28/06	4.19	7.67	6.27	75.03	240	0.05	0.09	33
23	09/05/06	6.50	7.27	8.64	69.15	133	0.05	0.08	23
24	09/11/06	5.62	7.53	8.96	67.34	201	0.05	0.16	35
25	09/18/06	7.61	7.60	8.06	68.09	3000	0.05	0.10	36
26	09/26/06	10.75	7.80	11.27	61.14	261	0.05	0.10	31
27	10/02/06	11.48	7.50	10.99	60.40	2420	0.05	0.16	29
28	10/09/06	11.13	7.17	9.58	57.94	205	0.05	0.62	34
29	10/16/06	11.44	7.08	11.55	49.70	411	0.05	0.15	52
30	10/23/06	12.30	6.87	11.03	49.20	36	0.05	0.19	46
	Max.	13.97	8.07	12.19	78.86	3000	0.24	0.90	59
	Min.	4.19	6.87	6.27	49.20	36	0.05	0.03	16
	Avg.	10.10	7.48	9.15	65.85	397	0.06	0.18	34

DO = Dissolved Oxygen mg/l, E.Coli = colonies per 100 mls (yellow indicates >235)  
 NH3-N = Ammonia Nitrogen mg/l, PHOS = Total Phosphorus mg/l  
 TSS = Total Suspended Solids mg/l

City of Fort Wayne  
River Survey 2006  
St. Marys River @ Spy Run Avenue

Wk	Date	Depth(ft)	pH	DO	Temp(F)	ECOLI	NH3-N	PHOS	TSS
1	04/03/06	9.24	7.07	10.46	49.92	11530	0.29	0.68	368
2	04/10/06	8.15	7.37	10.77	52.64	201	0.05	0.21	56
3	04/17/06	11.04	6.80	8.11	56.60	16160	0.20	0.70	312
4	04/24/06	7.84	7.07	8.10	60.17	100	0.05	0.21	60
5	05/01/06	6.36	7.32	12.77	56.16	4080	0.35	0.58	53
6	05/08/06	8.91	7.88	13.21	61.33	99	0.05	0.33	40
7	05/15/06	11.71	7.35	9.38	53.08	6400	0.33	0.34	194
8	05/22/06	10.19	7.22	8.95	57.23	166	0.05	0.28	92
9	05/30/06	8.66	7.66	6.77	72.06	816	0.05	0.11	70
10	06/05/06	8.92	7.12	7.03	65.70	866	0.05	0.25	105
11	06/12/06	8.47	7.29	7.61	63.47	1553	0.38	0.62	120
12	06/19/06	9.16	7.56	7.43	73.54	758	0.05	0.21	40
13	06/26/06	9.18	7.19	5.88	73.15	365	0.15	0.30	54
14	07/06/06	8.78	7.92	13.61	74.09	210	0.05	0.23	37
15	07/10/06	9.18	7.18	12.11	76.15	88	0.05	0.10	66
16	07/17/06	10.49	6.92	5.94	78.88	548	0.05	0.28	65
17	07/24/06	8.33	7.06	6.07	75.65	488	0.05	0.31	63
18	07/31/06	9.16	7.21	6.03	79.15	548	0.05	0.33	48
19	08/07/06	5.99	6.58	5.92	78.97	649	0.05	0.36	100
20	08/14/06	3.46	7.53	5.84	72.96	228	0.05	0.34	61
21	08/21/06	4.56	7.62	3.60	74.48	613	0.20	0.30	35
22	08/28/06	4.60	7.45	4.10	75.35	1986	0.05	0.13	60
23	09/05/06	4.58	7.11	5.52	67.42	1414	0.15	0.34	99
24	09/11/06	3.70	7.27	6.17	67.16	435	0.13	0.30	80
25	09/18/06	5.05	7.34	6.82	68.47	81640	0.20	0.28	62
26	09/26/06	8.57	7.69	11.86	61.45	816	0.05	0.21	38
27	10/02/06	9.05	7.32	12.77	59.47	2420	0.05	0.29	20
28	10/09/06	8.87	7.17	9.95	57.11	261	0.05	0.11	30
29	10/16/06	9.24	7.11	7.85	49.00	82	0.05	0.25	8
30	10/23/06	9.85	6.74	8.17	49.90	248	0.05	0.54	52
	Max.	11.71	7.88	13.61	79.15	81640	0.38	0.70	368
	Min.	3.46	6.58	3.60	49.00	82	0.05	0.10	8
	Avg.	8.04	7.27	8.29	65.36	4526	0.11	0.32	83

DO = Dissolved Oxygen mg/l, E.Coli = colonies per 100 mls (yellow indicates >235)

NH3-N = Ammonia Nitrogen mg/l, PHOS = Total Phosphorus mg/l

TSS = Total Suspended Solids mg/l

Low DOs are associated with oil in groundwater from the NIPSCO site on Superior Street.

City of Fort Wayne  
River Survey 2006  
Maumee River @ Anthony Boulevard

Wk	Date	Depth(ft)	pH	DO	Temp(F)	ECOLI	NH3-N	PHOS	TSS
1	04/03/06	5.01	7.03	11.84	50.29	8690	0.17	0.37	200
2	04/10/06	3.17	7.08	11.24	51.83	107	0.05	0.18	50
3	04/17/06	9.69	6.69	9.23	57.67	12740	0.20	0.64	290
4	04/24/06	3.01	6.88	8.97	61.22	100	0.05	0.20	52
5	05/01/06	1.67	7.26	10.82	57.40	1986	0.05	0.20	46
6	05/08/06	1.63	7.72	11.27	62.71	55	0.05	0.33	36
7	05/15/06	10.97	7.29	10.40	53.00	3495	0.29	0.21	77
8	05/22/06	6.04	7.12	10.74	58.88	122	0.05	0.20	97
9	05/30/06	3.69	7.81	8.30	72.91	649	0.05	0.03	40
10	06/05/06	4.15	7.09	8.29	67.63	579	0.05	0.19	79
11	06/12/06	3.39	7.33	8.65	65.20	613	0.15	0.17	65
12	06/19/06	1.74	7.42	8.35	73.79	649	0.05	0.14	35
13	06/26/06	2.18	7.53	8.30	75.48	248	0.05	0.23	52
14	07/06/06	1.53	7.67	10.00	73.94	99	0.05	0.21	30
15	07/10/06	1.79	6.84	8.03	75.21	70	0.05	0.16	49
16	07/17/06	6.32	7.10	8.59	77.59	435	0.05	0.20	61
17	07/24/06	2.91	7.10	7.76	76.55	172	0.05	0.23	57
18	07/31/06	4.05	7.45	7.47	78.03	378	0.05	0.23	57
19	08/07/06	2.09	6.62	6.54	78.97	172	0.05	0.24	67
20	08/14/06	1.16	7.54	8.03	75.63	73	0.05	0.16	47
21	08/21/06	1.37	8.01	7.49	75.11	866	0.05	0.17	48
22	08/28/06	1.57	7.53	6.62	76.33	2420	0.05	0.17	50
23	09/05/06	1.20	7.19	7.23	67.40	816	0.05	0.28	67
24	09/11/06	0.66	7.21	7.70	68.46	345	0.05	0.15	54
25	09/18/06	1.16	7.23	8.11	69.19	15650	0.05	0.20	46
26	09/26/06	1.44	7.58	9.93	61.18	150	0.05	0.12	33
27	10/02/06	4.68	7.29	10.64	60.15	2420	0.05	0.30	28
28	10/09/06	1.95	7.36	10.24	57.88	210	0.05	0.10	44
29	10/16/06	4.38	7.00	11.80	48.10	152	0.05	0.12	50
30	10/23/06	5.58	6.48	10.71	49.90	249	0.05	0.47	59
Max.		10.97	8.01	11.84	78.97	15650	0.29	0.64	290
Min.		1.16	6.48	6.54	48.10	55	0.05	0.03	28
Avg.		3.34	7.25	9.11	65.92	1824	0.07	0.22	66

DO = Dissolved Oxygen mg/l, E.Coli = colonies per 100 mls (yellow indicates >235)

NH3-N = Ammonia Nitrogen mg/l, PHOS = Total Phosphorus mg/l

TSS = Total Suspended Solids mg/l

City of Fort Wayne  
River Survey 2006  
Maumee River @ Landin Road

Wk	Date	Depth(ft)	pH	DO	Temp(F)	ECOLI	NH3-N	PHOS	TSS
1	04/03/06	9.34	7.31	10.90	50.66	14140	0.21	0.45	172
2	04/10/06	7.10	7.30	10.86	51.53	127	0.05	0.18	54
3	04/17/06	13.37	7.27	8.98	58.11	4200	0.20	0.66	298
4	04/24/06	7.07	7.53	8.99	61.23	100	0.05	0.20	54
5	05/01/06	5.84	7.34	10.68	57.85	1300	0.05	0.31	45
6	05/08/06	5.33	7.93	10.30	61.58	44	0.05	0.33	38
7	05/15/06	14.58	7.29	10.10	53.15	3310	0.34	0.31	136
8	05/22/06	9.66	7.43	10.26	58.96	127	0.05	0.24	89
9	05/30/06	7.57	7.74	8.15	72.93	118	0.05	0.07	43
10	06/05/06	7.94	7.16	8.10	68.32	687	0.05	0.15	82
11	06/12/06	7.41	7.41	8.19	65.70	727	0.05	0.47	60
12	06/19/06	5.84	7.56	6.94	72.51	272	0.05	0.19	36
13	06/26/06	6.53	7.31	7.19	74.24	225	0.05	0.03	45
14	07/06/06	4.81	7.57	8.00	72.14	119	0.11	0.32	30
15	07/10/06	5.55	7.25	6.78	75.61	60	0.05	0.31	47
16	07/17/06	9.81	7.05	7.78	78.31	308	0.05	0.27	78
17	07/24/06	6.54	7.27	7.37	75.35	142	0.05	0.22	42
18	07/31/06	8.06	7.29	7.06	78.41	435	0.05	0.24	54
19	08/07/06	6.02	6.98	6.73	79.33	161	0.05	0.25	59
20	08/14/06	4.63	7.37	6.52	74.36	130	0.05	0.19	43
21	08/21/06	5.07	7.81	6.07	74.34	365	0.05	0.22	33
22	08/28/06	5.45	7.47	5.10	75.26	2420	0.13	0.14	39
23	09/05/06	4.70	7.08	7.20	67.60	548	0.10	0.23	54
24	09/11/06	4.78	7.09	6.52	67.48	238	0.10	0.23	36
25	09/18/06	5.32	7.42	7.65	69.13	2420	0.05	0.22	45
26	09/26/06	5.14	7.56	10.32	60.87	261	0.05	0.17	45
27	10/02/06	5.25	7.09	9.12	61.59	2420	0.05	0.28	38
28	10/09/06	5.60	6.87	9.51	57.85	194	0.05	1.17	44
29	10/16/06	7.77	7.29	11.65	48.90	313	0.05	0.16	70
30	10/23/06	9.15	6.70	10.51	50.10	236	0.05	0.44	65
Max.		14.58	7.93	10.90	79.33	14140	0.34	1.17	298
Min.		4.63	6.70	5.10	48.90	44	0.05	0.03	30
Avg.		7.04	7.32	8.45	65.78	1205	0.08	0.29	66

DO = Dissolved Oxygen mg/l, E.Coli = colonies per 100 mls (yellow indicates >235)  
 NH3-N = Ammonia Nitrogen mg/l, PHOS = Total Phosphorus mg/l  
 TSS = Total Suspended Solids mg/l

Jim Cornell Feb 2007

**APPENDIX G: Data Set for St. Joseph River @ Tennessee Avenue**

**Box and Whiskers Graph**

St. Joseph @ Tennessee Avenue - 1970s Fecal Coliform		St. Joseph @ Tennessee Avenue - 1980s Fecal Coliform		St. Joseph @ Tennessee Avenue - 1990s E. Coli		St. Joseph @ Tennessee Avenue - 2000s E. Coli		Applicable Standard for E. Coli
Result (cfu/100 mL)	Indicator Organis m	Result (cfu/100 mL)	Indicator Organis m	Result (cfu/100 mL)	Indicator Organis m	Result (cfu/100 mL)	Indicator Organis m	
280 Coliform		180 Coliform		2400 E. coli (		60 E. coli (235 cfu/100 mL		
170 Coliform		140 Coliform		70 E. coli (		50 E. coli (235 cfu/100 mL		
30 Coliform		290 Coliform		1300 E. coli (		220 E. coli (235 cfu/100 mL		
320 Coliform		1200 Coliform		60 E. coli (		260 E. coli (235 cfu/100 mL		
100 Coliform		10 Coliform		900 E. coli (		110 E. coli (235 cfu/100 mL		
120 Coliform		1600 Coliform		230 E. coli (		140 E. coli (235 cfu/100 mL		
1200 Coliform		440 Coliform		190 E. coli (		20 E. coli (235 cfu/100 mL		
710 Coliform		2000 Coliform		500 E. coli (		48 E. coli (235 cfu/100 mL		
220 Coliform		2900 Coliform		10000 E. coli (		32 E. coli (235 cfu/100 mL		
220 Coliform		2000 Coliform		1100 E. coli (		500 E. coli (235 cfu/100 mL		
10 Coliform		40 Coliform		150 E. coli (		540 E. coli (235 cfu/100 mL		
150 Coliform		240 Coliform		240 E. coli (		370 E. coli (235 cfu/100 mL		
100 Coliform		350 Coliform		290 E. coli (		100 E. coli (235 cfu/100 mL		
760 Coliform		210 Coliform		700 E. coli (		100 E. coli (235 cfu/100 mL		
1000 Coliform		72 Coliform		200 E. coli (		200 E. coli (235 cfu/100 mL		
100 Coliform		4400 Coliform		90 E. coli (		144 E. coli (235 cfu/100 mL		
360 Coliform		1800 Coliform		180 E. coli (		100 E. coli (235 cfu/100 mL		
130 Coliform		130 Coliform		150 E. coli (		20 E. coli (235 cfu/100 mL		
2900 Coliform		30 Coliform		400 E. coli (		80 E. coli (235 cfu/100 mL		
210 Coliform		1900 Coliform		200 E. coli (		44 E. coli (235 cfu/100 mL		
120 Coliform		660 Coliform		300 E. coli (		102 E. coli (235 cfu/100 mL		
10 Coliform		110 Coliform		90 E. coli (		102 E. coli (235 cfu/100 mL		
70 Coliform		18000 Coliform		120 E. coli (		480 E. coli (235 cfu/100 mL		
610 Coliform		100 Coliform		10 E. coli (		450 E. coli (235 cfu/100 mL		
70 Coliform		250 Coliform		20 E. coli (		210 E. coli (235 cfu/100 mL		
30 Coliform		40 Coliform		170 E. coli (		1120 E. coli (235 cfu/100 mL		
2600 Coliform		270 Coliform		410 E. coli (		160 E. coli (235 cfu/100 mL		
400 Coliform		50 Coliform		1700 E. coli (		360 E. coli (235 cfu/100 mL		
570 Coliform		490 Coliform		480 E. coli (		180 E. coli (235 cfu/100 mL		
80 Coliform		890 Coliform		60 E. coli (		550 E. coli (235 cfu/100 mL		
150 Coliform		430 Coliform		100 E. coli (		3200 E. coli (235 cfu/100 mL		
420 Coliform		190 Coliform		880 E. coli (		270 E. coli (235 cfu/100 mL		
3200 Coliform		200 Coliform		20 E. coli (		180 E. coli (235 cfu/100 mL		
150 Coliform		140 Coliform		120 E. coli (		544 E. coli (235 cfu/100 mL		
870 Coliform		10 Coliform		80 E. coli (		320 E. coli (235 cfu/100 mL		
40 Coliform		380 Coliform		50 E. coli (		220 E. coli (235 cfu/100 mL		
290 Coliform		1600 Coliform		290 E. coli (		200 E. coli (235 cfu/100 mL		
		30 Coliform		28000 E. coli (		360 E. coli (235 cfu/100 mL		
		120 Coliform		300 E. coli (		100 E. coli (235 cfu/100 mL		
		330 Coliform		20 E. coli (		5600 E. coli (235 cfu/100 mL		

Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Applicable Standard for E. Coli
		800 Coliform		250 E. coli (		100 E. coli (235 cfu/100 mL		
		540 Coliform		690 E. coli (		100 E. coli (235 cfu/100 mL		
		250 Coliform		330 E. coli (		140 E. coli (235 cfu/100 mL		
		120 Coliform		250 E. coli (		290 E. coli (235 cfu/100 mL		
		590 Coliform		10 E. coli (		140 E. coli (235 cfu/100 mL		
		10 Coliform		450 E. coli (		240 E. coli (235 cfu/100 mL		
		30 Coliform		110 E. coli (		240 E. coli (235 cfu/100 mL		
		10 Coliform		120 E. coli (		210 E. coli (235 cfu/100 mL		
		750 Coliform		1800 E. coli (		220 E. coli (235 cfu/100 mL		
		750 Coliform		520 E. coli (		150 E. coli (235 cfu/100 mL		
		460 Coliform		110 E. coli (		80 E. coli (235 cfu/100 mL		
		100 Coliform		940 E. coli (		50 E. coli (235 cfu/100 mL		
		5000 Coliform		4000 E. coli (		245 E. coli (235 cfu/100 mL		
		130 Coliform		230 E. coli (		980 E. coli (235 cfu/100 mL		
		600 Coliform		230 E. coli (		210 E. coli (235 cfu/100 mL		
		2000 Coliform		10000 E. coli (		70 E. coli (235 cfu/100 mL		
		110 Coliform		1600 E. coli (		50 E. coli (235 cfu/100 mL		
		250 Coliform		2800 E. coli (		30 E. coli (235 cfu/100 mL		
		1900 Coliform		60 E. coli (		320 E. coli (235 cfu/100 mL		
		90 Coliform		80 E. coli (		415 E. coli (235 cfu/100 mL		
		220 Coliform		90 E. coli (		100 E. coli (235 cfu/100 mL		
		40 Coliform		890 E. coli (		10 E. coli (235 cfu/100 mL		
		11 Coliform		230 E. coli (		75 E. coli (235 cfu/100 mL		
		750 Coliform		220 E. coli (		150 E. coli (235 cfu/100 mL		
		150 Coliform		10 E. coli (		8 E. coli (235 cfu/100 mL		
		600 Coliform		4000 E. coli (		34 E. coli (235 cfu/100 mL		
		210 Coliform		1800 E. coli (		5 E. coli (235 cfu/100 mL		
		500 Coliform		930 E. coli (		3 E. coli (235 cfu/100 mL		
		110 Coliform		20 E. coli (		12 E. coli (235 cfu/100 mL		
		4600 Coliform		50 E. coli (		700 E. coli (235 cfu/100 mL		
		40 Coliform		360 E. coli (		78 E. coli (235 cfu/100 mL		
		680 Coliform		160 E. coli (		76 E. coli (235 cfu/100 mL		
		200 Coliform		200 E. coli (		38 E. coli (235 cfu/100 mL		
		10 Coliform		6600 E. coli (		80 E. coli (235 cfu/100 mL		
		300 Coliform		10 E. coli (		130 E. coli (235 cfu/100 mL		
		470 Coliform		160 E. coli (		40 E. coli (235 cfu/100 mL		
		190 Coliform		200 E. coli (		190 E. coli (235 cfu/100 mL		
		10 Coliform		30 E. coli (		360 E. coli (235 cfu/100 mL		
		150 Coliform		20 E. coli (		500 E. coli (235 cfu/100 mL		
		100 Coliform		390 E. coli (		440 E. coli (235 cfu/100 mL		
		60 Coliform		360 E. coli (		60 E. coli (235 cfu/100 mL		
		800 Coliform		120 E. coli (		640 E. coli (235 cfu/100 mL		
		2000 Coliform		40 E. coli (		120 E. coli (235 cfu/100 mL		
		190 Coliform		440 E. coli (		54 E. coli (235 cfu/100 mL		
		400 Coliform		110 E. coli (		20 E. coli (235 cfu/100 mL		
				10 E. coli (		8 E. coli (235 cfu/100 mL		
				40 E. coli (		96 E. coli (235 cfu/100 mL		
				80 E. coli (		92 E. coli (235 cfu/100 mL		
				230 E. coli (		92 E. coli (235 cfu/100 mL		

Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Applicable Standard for E. Coli
				140 E. coli (		184 E. coli (235 cfu/100 mL		
				10 E. coli (		104 E. coli (235 cfu/100 mL		
				970 E. coli (		20 E. coli (235 cfu/100 mL		
				800 E. coli (		23 E. coli (235 cfu/100 mL		
				300 E. coli (		20 E. coli (235 cfu/100 mL		
				110 E. coli (		21 E. coli (235 cfu/100 mL		
				7900 E. coli (		14 E. coli (235 cfu/100 mL		
				110 E. coli (		36 E. coli (235 cfu/100 mL		
				20 E. coli (		1454 E. coli (235 cfu/100 mL		
				80 E. coli (		238 E. coli (235 cfu/100 mL		
				180 E. coli (		93 E. coli (235 cfu/100 mL		
				50 E. coli (		9680 E. coli (235 cfu/100 mL		
				370 E. coli (		6520 E. coli (235 cfu/100 mL		
						218 E. coli (235 cfu/100 mL		
						3309 E. coli (235 cfu/100 mL		
						126 E. coli (235 cfu/100 mL		
						190 E. coli (235 cfu/100 mL		
						20 E. coli (235 cfu/100 mL		
						1288 E. coli (235 cfu/100 mL		
						85 E. coli (235 cfu/100 mL		
						320 E. coli (235 cfu/100 mL		
						82 E. coli (235 cfu/100 mL		
						104 E. coli (235 cfu/100 mL		
						190 E. coli (235 cfu/100 mL		
						1488 E. coli (235 cfu/100 mL		
						840 E. coli (235 cfu/100 mL		
						82 E. coli (235 cfu/100 mL		
						85 E. coli (235 cfu/100 mL		
						66 E. coli (235 cfu/100 mL		
						110 E. coli (235 cfu/100 mL		
						58 E. coli (235 cfu/100 mL		
						39 E. coli (235 cfu/100 mL		
						613 E. coli (235 cfu/100 mL		
						19 E. coli (235 cfu/100 mL		
						20 E. coli (235 cfu/100 mL		
						40 E. coli (235 cfu/100 mL		
						387 E. coli (235 cfu/100 mL		
						70 E. coli (235 cfu/100 mL		
						18 E. coli (235 cfu/100 mL		
						110 E. coli (235 cfu/100 mL		
						111 E. coli (235 cfu/100 mL		
						192 E. coli (235 cfu/100 mL		
						5200 E. coli (235 cfu/100 mL		
						1986 E. coli (235 cfu/100 mL		
						109 E. coli (235 cfu/100 mL		
						50 E. coli (235 cfu/100 mL		
						87 E. coli (235 cfu/100 mL		
						157 E. coli (235 cfu/100 mL		
						210 E. coli (235 cfu/100 mL		

Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Applicable Standard for E. Coli
						34	E. coli	(235 cfu/100 mL)
						99	E. coli	(235 cfu/100 mL)
						921	E. coli	(235 cfu/100 mL)
						249	E. coli	(235 cfu/100 mL)
						140	E. coli	(235 cfu/100 mL)
						45	E. coli	(235 cfu/100 mL)
						35	E. coli	(235 cfu/100 mL)
						14	E. coli	(235 cfu/100 mL)
						28	E. coli	(235 cfu/100 mL)
						1300	E. coli	(235 cfu/100 mL)
						68	E. coli	(235 cfu/100 mL)
						40	E. coli	(235 cfu/100 mL)
						67	E. coli	(235 cfu/100 mL)
						199	E. coli	(235 cfu/100 mL)
						16	E. coli	(235 cfu/100 mL)
						517	E. coli	(235 cfu/100 mL)
						70	E. coli	(235 cfu/100 mL)
						866	E. coli	(235 cfu/100 mL)
						100	E. coli	(235 cfu/100 mL)
						308	E. coli	(235 cfu/100 mL)
						45	E. coli	(235 cfu/100 mL)
						687	E. coli	(235 cfu/100 mL)
						86	E. coli	(235 cfu/100 mL)
						86	E. coli	(235 cfu/100 mL)
						184	E. coli	(235 cfu/100 mL)
						126	E. coli	(235 cfu/100 mL)
						228	E. coli	(235 cfu/100 mL)
						122	E. coli	(235 cfu/100 mL)
						66	E. coli	(235 cfu/100 mL)
						45	E. coli	(235 cfu/100 mL)
						372	E. coli	(235 cfu/100 mL)
						96	E. coli	(235 cfu/100 mL)
						488	E. coli	(235 cfu/100 mL)
						81	E. coli	(235 cfu/100 mL)
						58	E. coli	(235 cfu/100 mL)
						365	E. coli	(235 cfu/100 mL)
						240	E. coli	(235 cfu/100 mL)
						133	E. coli	(235 cfu/100 mL)
						201	E. coli	(235 cfu/100 mL)
						3000	E. coli	(235 cfu/100 mL)
						261	E. coli	(235 cfu/100 mL)
						2420	E. coli	(235 cfu/100 mL)
						205	E. coli	(235 cfu/100 mL)
						411	E. coli	(235 cfu/100 mL)
						36	E. coli	(235 cfu/100 mL)

### Summary Range

	St. Joseph @ Tennessee Avenue - 1970s	St. Joseph @ Tennessee Avenue - 1980s	St. Joseph @ Tennessee Avenue - 1990s	St. Joseph @ Tennessee Avenue - 2000s
Minimum:	10	10	10	3
5th Percentile:	26	10	11	18
25th Percentile:	100	110	83	60
Median:	210	250	200	120
75th Percentile:	570	680	495	280
95th Percentile:	2,660	2,720	4,000	1,485
Maximum:	3,200	18,000	28,000	9,680

### Chart Data

	St. Joseph @ Tennessee Avenue - 1970s Fecal Coliform	St. Joseph @ Tennessee Avenue - 1980s Fecal Coliform	St. Joseph @ Tennessee Avenue - 1990s E. Coli	St. Joseph @ Tennessee Avenue - 2000s E. Coli
Series 1	10	10	10	3
Series 2	16	-	1	15
Series 3	74	100	72	42
Series 4	110	140	118	60
Series 5	360	430	295	160
Series 6	2,090	2,040	3,505	1,205
Series 7	540	15,280	24,000	8,195

## **APPENDIX H: Data Set for St. Marys River @ Spy Run**

### **Box and Whiskers Graph**

St. Marys @ Spy Run - 1980s Fecal Coliform		St. Marys @ Spy Run - 1990s E. Coli		St. Marys @ Spy Run - 2000s E. Coli		Applicable Standard for E. Coli
Result (cfu/100 mL)	Indicator Organis m	Result (cfu/100 mL)	Indicator Organis m	Result (cfu/100 mL)	Indicator Organis m	
2500 Coliform		2400 E. coli (		970 E. coli (235 cfu/100 mL)		
930 Coliform		600 E. coli (		870 E. coli (235 cfu/100 mL)		
2700 Coliform		16000 E. coli (		1600 E. coli (235 cfu/100 mL)		
4800 Coliform		30 E. coli (		600 E. coli (235 cfu/100 mL)		
800 Coliform		30000 E. coli (		1200 E. coli (235 cfu/100 mL)		
5700 Coliform		540 E. coli (		900 E. coli (235 cfu/100 mL)		
800 Coliform		530 E. coli (		70 E. coli (235 cfu/100 mL)		
29000 Coliform		240 E. coli (		32 E. coli (235 cfu/100 mL)		
1700 Coliform		18000 E. coli (		90 E. coli (235 cfu/100 mL)		
4900 Coliform		2300 E. coli (		520 E. coli (235 cfu/100 mL)		
1300 Coliform		200 E. coli (		600 E. coli (235 cfu/100 mL)		
5000 Coliform		470 E. coli (		1480 E. coli (235 cfu/100 mL)		
10 Coliform		600 E. coli (		2920 E. coli (235 cfu/100 mL)		
340 Coliform		500 E. coli (		1000 E. coli (235 cfu/100 mL)		
940 Coliform		2900 E. coli (		848 E. coli (235 cfu/100 mL)		
10 Coliform		1600 E. coli (		450 E. coli (235 cfu/100 mL)		
10000 Coliform		1700 E. coli (		3000 E. coli (235 cfu/100 mL)		
1600 Coliform		130 E. coli (		260 E. coli (235 cfu/100 mL)		
3600 Coliform		700 E. coli (		3000 E. coli (235 cfu/100 mL)		
80 Coliform		1300 E. coli (		1450 E. coli (235 cfu/100 mL)		
12000 Coliform		440 E. coli (		500 E. coli (235 cfu/100 mL)		
440 Coliform		260 E. coli (		360 E. coli (235 cfu/100 mL)		
100 Coliform		40 E. coli (		4600 E. coli (235 cfu/100 mL)		
8800 Coliform		200 E. coli (		4000 E. coli (235 cfu/100 mL)		
8300 Coliform		240 E. coli (		700 E. coli (235 cfu/100 mL)		
3000 Coliform		1900 E. coli (		4250 E. coli (235 cfu/100 mL)		
230 Coliform		2500 E. coli (		1160 E. coli (235 cfu/100 mL)		
		4600 E. coli (		6000 E. coli (235 cfu/100 mL)		
		700 E. coli (		600 E. coli (235 cfu/100 mL)		
		290 E. coli (		620 E. coli (235 cfu/100 mL)		
		1600 E. coli (		3000 E. coli (235 cfu/100 mL)		
		1000 E. coli (		1800 E. coli (235 cfu/100 mL)		
		120 E. coli (		380 E. coli (235 cfu/100 mL)		
		1800 E. coli (		884 E. coli (235 cfu/100 mL)		
		2900 E. coli (		740 E. coli (235 cfu/100 mL)		
		350 E. coli (		660 E. coli (235 cfu/100 mL)		
		600 E. coli (		680 E. coli (235 cfu/100 mL)		
		3500 E. coli (		3740 E. coli (235 cfu/100 mL)		
		1200 E. coli (		1000 E. coli (235 cfu/100 mL)		
		40 E. coli (		5400 E. coli (235 cfu/100 mL)		
		450 E. coli (		500 E. coli (235 cfu/100 mL)		
		840 E. coli (		2700 E. coli (235 cfu/100 mL)		

Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Applicable Standard for E. Coli
		370 E. coli (		560 E. coli (235 cfu/100 mL)		
		580 E. coli (		1400 E. coli (235 cfu/100 mL)		
		50 E. coli (		420 E. coli (235 cfu/100 mL)		
		490 E. coli (		360 E. coli (235 cfu/100 mL)		
		1900 E. coli (		220 E. coli (235 cfu/100 mL)		
		1500 E. coli (		300 E. coli (235 cfu/100 mL)		
		540 E. coli (		380 E. coli (235 cfu/100 mL)		
		370 E. coli (		170 E. coli (235 cfu/100 mL)		
		60 E. coli (		270 E. coli (235 cfu/100 mL)		
		20000 E. coli (		740 E. coli (235 cfu/100 mL)		
		220 E. coli (		55 E. coli (235 cfu/100 mL)		
		4300 E. coli (		130 E. coli (235 cfu/100 mL)		
		1800 E. coli (		1600 E. coli (235 cfu/100 mL)		
		2000 E. coli (		60 E. coli (235 cfu/100 mL)		
		250 E. coli (		240 E. coli (235 cfu/100 mL)		
		120 E. coli (		250 E. coli (235 cfu/100 mL)		
		250 E. coli (		220 E. coli (235 cfu/100 mL)		
		910 E. coli (		260 E. coli (235 cfu/100 mL)		
		90 E. coli (		600 E. coli (235 cfu/100 mL)		
		50 E. coli (		190 E. coli (235 cfu/100 mL)		
		200 E. coli (		160 E. coli (235 cfu/100 mL)		
		330 E. coli (		32 E. coli (235 cfu/100 mL)		
		180 E. coli (		8 E. coli (235 cfu/100 mL)		
		3100 E. coli (		20 E. coli (235 cfu/100 mL)		
		740 E. coli (		8 E. coli (235 cfu/100 mL)		
		210 E. coli (		8 E. coli (235 cfu/100 mL)		
		140 E. coli (		2000 E. coli (235 cfu/100 mL)		
		510 E. coli (		249 E. coli (235 cfu/100 mL)		
		310 E. coli (		88 E. coli (235 cfu/100 mL)		
		1400 E. coli (		36 E. coli (235 cfu/100 mL)		
		200 E. coli (		20 E. coli (235 cfu/100 mL)		
		70 E. coli (		300 E. coli (235 cfu/100 mL)		
		380 E. coli (		260 E. coli (235 cfu/100 mL)		
		530 E. coli (		620 E. coli (235 cfu/100 mL)		
		80 E. coli (		250 E. coli (235 cfu/100 mL)		
		2000 E. coli (		500 E. coli (235 cfu/100 mL)		
		3400 E. coli (		200 E. coli (235 cfu/100 mL)		
		460 E. coli (		20 E. coli (235 cfu/100 mL)		
		330 E. coli (		800 E. coli (235 cfu/100 mL)		
		740 E. coli (		340 E. coli (235 cfu/100 mL)		
		890 E. coli (		29 E. coli (235 cfu/100 mL)		
		1400 E. coli (		67 E. coli (235 cfu/100 mL)		
		70 E. coli (		24 E. coli (235 cfu/100 mL)		
		130 E. coli (		34 E. coli (235 cfu/100 mL)		
		17000 E. coli (		3 E. coli (235 cfu/100 mL)		
		22000 E. coli (		5 E. coli (235 cfu/100 mL)		
		2700 E. coli (		64 E. coli (235 cfu/100 mL)		
		1400 E. coli (		18 E. coli (235 cfu/100 mL)		
		210 E. coli (		56 E. coli (235 cfu/100 mL)		

Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Applicable Standard for E. Coli
		2200 E. coli (		1 E. coli (		235 cfu/100 mL)
		8100 E. coli (		159 E. coli (		235 cfu/100 mL)
		290 E. coli (		41 E. coli (		235 cfu/100 mL)
		600 E. coli (		25 E. coli (		235 cfu/100 mL)
		120000 E. coli (		365 E. coli (		235 cfu/100 mL)
		15000 E. coli (		3972 E. coli (		235 cfu/100 mL)
		10 E. coli (		9676 E. coli (		235 cfu/100 mL)
		90 E. coli (		189 E. coli (		235 cfu/100 mL)
		800 E. coli (		1844 E. coli (		235 cfu/100 mL)
		690 E. coli (		8220 E. coli (		235 cfu/100 mL)
		1600 E. coli (		452 E. coli (		235 cfu/100 mL)
				7754 E. coli (		235 cfu/100 mL)
				798 E. coli (		235 cfu/100 mL)
				325 E. coli (		235 cfu/100 mL)
				264 E. coli (		235 cfu/100 mL)
				8212 E. coli (		235 cfu/100 mL)
				84 E. coli (		235 cfu/100 mL)
				816 E. coli (		235 cfu/100 mL)
				840 E. coli (		235 cfu/100 mL)
				1352 E. coli (		235 cfu/100 mL)
				576 E. coli (		235 cfu/100 mL)
				6510 E. coli (		235 cfu/100 mL)
				12262 E. coli (		235 cfu/100 mL)
				238 E. coli (		235 cfu/100 mL)
				160 E. coli (		235 cfu/100 mL)
				299 E. coli (		235 cfu/100 mL)
				169 E. coli (		235 cfu/100 mL)
				60 E. coli (		235 cfu/100 mL)
				126 E. coli (		235 cfu/100 mL)
				365 E. coli (		235 cfu/100 mL)
				345 E. coli (		235 cfu/100 mL)
				61 E. coli (		235 cfu/100 mL)
				35 E. coli (		235 cfu/100 mL)
				6890 E. coli (		235 cfu/100 mL)
				192 E. coli (		235 cfu/100 mL)
				73 E. coli (		235 cfu/100 mL)
				291 E. coli (		235 cfu/100 mL)
				291 E. coli (		235 cfu/100 mL)
				77 E. coli (		235 cfu/100 mL)
				1733 E. coli (		235 cfu/100 mL)
				46110 E. coli (		235 cfu/100 mL)
				613 E. coli (		235 cfu/100 mL)
				727 E. coli (		235 cfu/100 mL)
				326 E. coli (		235 cfu/100 mL)
				461 E. coli (		235 cfu/100 mL)
				1120 E. coli (		235 cfu/100 mL)
				118 E. coli (		235 cfu/100 mL)
				344 E. coli (		235 cfu/100 mL)
				37 E. coli (		235 cfu/100 mL)

Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Applicable Standard for E. Coli
						866 E. coli (235 cfu/100 mL)
						365 E. coli (235 cfu/100 mL)
						50 E. coli (235 cfu/100 mL)
						59 E. coli (235 cfu/100 mL)
						17 E. coli (235 cfu/100 mL)
						194 E. coli (235 cfu/100 mL)
		>2420				E. coli (235 cfu/100 mL)
						345 E. coli (235 cfu/100 mL)
						161 E. coli (235 cfu/100 mL)
						111 E. coli (235 cfu/100 mL)
						115 E. coli (235 cfu/100 mL)
						93 E. coli (235 cfu/100 mL)
						11530 E. coli (235 cfu/100 mL)
						201 E. coli (235 cfu/100 mL)
						16160 E. coli (235 cfu/100 mL)
						100 E. coli (235 cfu/100 mL)
						4080 E. coli (235 cfu/100 mL)
						99 E. coli (235 cfu/100 mL)
						6400 E. coli (235 cfu/100 mL)
						166 E. coli (235 cfu/100 mL)
						816 E. coli (235 cfu/100 mL)
						866 E. coli (235 cfu/100 mL)
						1553 E. coli (235 cfu/100 mL)
						758 E. coli (235 cfu/100 mL)
						365 E. coli (235 cfu/100 mL)
						210 E. coli (235 cfu/100 mL)
						88 E. coli (235 cfu/100 mL)
						548 E. coli (235 cfu/100 mL)
						488 E. coli (235 cfu/100 mL)
						548 E. coli (235 cfu/100 mL)
						649 E. coli (235 cfu/100 mL)
						228 E. coli (235 cfu/100 mL)
						613 E. coli (235 cfu/100 mL)
						1986 E. coli (235 cfu/100 mL)
						1414 E. coli (235 cfu/100 mL)
						435 E. coli (235 cfu/100 mL)
						81640 E. coli (235 cfu/100 mL)
						816 E. coli (235 cfu/100 mL)
						2420 E. coli (235 cfu/100 mL)
						261 E. coli (235 cfu/100 mL)
						82 E. coli (235 cfu/100 mL)
						248 E. coli (235 cfu/100 mL)

Summary Range			
	St. Marys @ Spy Run - 1980s Fecal	St. Marys @ Spy Run - 1990s E. Coli	St. Marys @ Spy Run - 2000s E. Coli
Minimum:	10	10	1
5th Percentile:	31	51	20
25th Percentile:	620	240	145
Median:	1,700	590	365
75th Percentile:	4,950	1,800	935
95th Percentile:	11,400	16,950	6,976
Maximum:	29,000	120,000	81,640

Chart Data			
	St. Marys @ Spy Run - 1980s Fecal Coliform	St. Marys @ Spy Run - 1990s E. Coli	St. Marys @ Spy Run - 2000s E. Coli
Series 1	10	10	1
Series 2	21	41	19
Series 3	589	190	125
Series 4	1,080	350	221
Series 5	3,250	1,210	570
Series 6	6,450	15,150	6,041
Series 7	17,600	103,050	74,664

**APPENDIX I: Data Set for Maumee River @ Anthony Boulevard**

**Box and Whiskers Graph**

Maumee @ Anthony Boulevard - 1970s Fecal Coliform		Maumee @ Anthony Boulevard - 1980s Fecal Coliform		Maumee @ Anthony Boulevard - 2000s E. Coli		Applicable Standard for E. coli
Result (cfu/100 mL)	Indicator Organis m	Result (cfu/100 mL)	Indicator Organis m	Result (cfu/100 mL)	Indicator Organis m	
750 Coliform		190 Coliform		560 E. coli	(235 cfu/100 mL)	
3600 Coliform		2100 Coliform		340 E. coli	(235 cfu/100 mL)	
520 Coliform		100 Coliform		1320 E. coli	(235 cfu/100 mL)	
1200 Coliform		5500 Coliform		1000 E. coli	(235 cfu/100 mL)	
2200 Coliform		1800 Coliform		20 E. coli	(235 cfu/100 mL)	
570 Coliform		120 Coliform		44 E. coli	(235 cfu/100 mL)	
1300 Coliform		5000 Coliform		26 E. coli	(235 cfu/100 mL)	
4800 Coliform		910 Coliform		432 E. coli	(235 cfu/100 mL)	
2700 Coliform		780 Coliform		590 E. coli	(235 cfu/100 mL)	
380 Coliform		760 Coliform		1000 E. coli	(235 cfu/100 mL)	
710 Coliform		180 Coliform		570 E. coli	(235 cfu/100 mL)	
2200 Coliform		150 Coliform		230 E. coli	(235 cfu/100 mL)	
5600 Coliform		8100 Coliform		1600 E. coli	(235 cfu/100 mL)	
670 Coliform		9900 Coliform		150 E. coli	(235 cfu/100 mL)	
260 Coliform		190 Coliform		980 E. coli	(235 cfu/100 mL)	
110 Coliform		20 Coliform		60 E. coli	(235 cfu/100 mL)	
470 Coliform		30 Coliform		980 E. coli	(235 cfu/100 mL)	
390 Coliform		3400 Coliform		810 E. coli	(235 cfu/100 mL)	
50 Coliform		280 Coliform		330 E. coli	(235 cfu/100 mL)	
1000 Coliform		5200 Coliform		110 E. coli	(235 cfu/100 mL)	
440 Coliform		690 Coliform		6000 E. coli	(235 cfu/100 mL)	
210 Coliform		5400 Coliform		1080 E. coli	(235 cfu/100 mL)	
510 Coliform		540 Coliform		260 E. coli	(235 cfu/100 mL)	
20 Coliform		140 Coliform		2400 E. coli	(235 cfu/100 mL)	
240 Coliform		360 Coliform		8000 E. coli	(235 cfu/100 mL)	
50 Coliform		460 Coliform		20000 E. coli	(235 cfu/100 mL)	
600 Coliform		2600 Coliform		460 E. coli	(235 cfu/100 mL)	
5900 Coliform		770 Coliform		440 E. coli	(235 cfu/100 mL)	
790 Coliform		270 Coliform		3200 E. coli	(235 cfu/100 mL)	
3200 Coliform		840 Coliform		700 E. coli	(235 cfu/100 mL)	
810 Coliform		130 Coliform		220 E. coli	(235 cfu/100 mL)	
270 Coliform		50 Coliform		616 E. coli	(235 cfu/100 mL)	
140 Coliform		2200 Coliform		1040 E. coli	(235 cfu/100 mL)	
3700 Coliform		2100 Coliform		460 E. coli	(235 cfu/100 mL)	
46 Coliform		2600 Coliform		360 E. coli	(235 cfu/100 mL)	
570 Coliform		440 Coliform		4440 E. coli	(235 cfu/100 mL)	
330 Coliform		2900 Coliform		300 E. coli	(235 cfu/100 mL)	
260 Coliform		42000 Coliform		4300 E. coli	(235 cfu/100 mL)	
80 Coliform		1800 Coliform		100 E. coli	(235 cfu/100 mL)	
750 Coliform		4000 Coliform		1100 E. coli	(235 cfu/100 mL)	

Result (cfu/100 mL)	Indicator Organisms	Result (cfu/100 mL)	Indicator Organisms	Result (cfu/100 mL)	Indicator Organisms	Applicable Standard for E. coli
320 Coliform		9600 Coliform		540 E. coli	(235 cfu/100 mL)	
120 Coliform		1100 Coliform		330 E. coli	(235 cfu/100 mL)	
1600 Coliform		1000 Coliform		260 E. coli	(235 cfu/100 mL)	
520 Coliform		620 Coliform		430 E. coli	(235 cfu/100 mL)	
400 Coliform		40 Coliform		540 E. coli	(235 cfu/100 mL)	
1800 Coliform		8800 Coliform		290 E. coli	(235 cfu/100 mL)	
560 Coliform		2200 Coliform		70 E. coli	(235 cfu/100 mL)	
150 Coliform		1200 Coliform		470 E. coli	(235 cfu/100 mL)	
2500 Coliform		190 Coliform		60 E. coli	(235 cfu/100 mL)	
1800 Coliform		38000 Coliform		270 E. coli	(235 cfu/100 mL)	
1800 Coliform		520 Coliform		600 E. coli	(235 cfu/100 mL)	
530 Coliform		6400 Coliform		400 E. coli	(235 cfu/100 mL)	
830 Coliform		3200 Coliform		2400 E. coli	(235 cfu/100 mL)	
680 Coliform		1600 Coliform		110 E. coli	(235 cfu/100 mL)	
880 Coliform		2800 Coliform		50 E. coli	(235 cfu/100 mL)	
		13000 Coliform		90 E. coli	(235 cfu/100 mL)	
				900 E. coli	(235 cfu/100 mL)	
				310 E. coli	(235 cfu/100 mL)	
				220 E. coli	(235 cfu/100 mL)	
				70 E. coli	(235 cfu/100 mL)	
				115 E. coli	(235 cfu/100 mL)	
				800 E. coli	(235 cfu/100 mL)	
				80 E. coli	(235 cfu/100 mL)	
				9 E. coli	(235 cfu/100 mL)	
				13 E. coli	(235 cfu/100 mL)	
				28 E. coli	(235 cfu/100 mL)	
				1100 E. coli	(235 cfu/100 mL)	
				146 E. coli	(235 cfu/100 mL)	
				84 E. coli	(235 cfu/100 mL)	
				40 E. coli	(235 cfu/100 mL)	
				44 E. coli	(235 cfu/100 mL)	
				495 E. coli	(235 cfu/100 mL)	
				320 E. coli	(235 cfu/100 mL)	
				400 E. coli	(235 cfu/100 mL)	
				250 E. coli	(235 cfu/100 mL)	
				300 E. coli	(235 cfu/100 mL)	
				140 E. coli	(235 cfu/100 mL)	
				10 E. coli	(235 cfu/100 mL)	
				760 E. coli	(235 cfu/100 mL)	
				230 E. coli	(235 cfu/100 mL)	
				42 E. coli	(235 cfu/100 mL)	
				26 E. coli	(235 cfu/100 mL)	
				10 E. coli	(235 cfu/100 mL)	
				14 E. coli	(235 cfu/100 mL)	
				3 E. coli	(235 cfu/100 mL)	
				5 E. coli	(235 cfu/100 mL)	
				104 E. coli	(235 cfu/100 mL)	
				80 E. coli	(235 cfu/100 mL)	
				136 E. coli	(235 cfu/100 mL)	

Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Applicable Standard for E. coli
				15	E. coli	(235 cfu/100 mL)
				82	E. coli	(235 cfu/100 mL)
				31	E. coli	(235 cfu/100 mL)
				17	E. coli	(235 cfu/100 mL)
				291	E. coli	(235 cfu/100 mL)
				3972	E. coli	(235 cfu/100 mL)
				4480	E. coli	(235 cfu/100 mL)
				166	E. coli	(235 cfu/100 mL)
				9680	E. coli	(235 cfu/100 mL)
				6260	E. coli	(235 cfu/100 mL)
				406	E. coli	(235 cfu/100 mL)
				5178	E. coli	(235 cfu/100 mL)
				436	E. coli	(235 cfu/100 mL)
				153	E. coli	(235 cfu/100 mL)
				126	E. coli	(235 cfu/100 mL)
				9222	E. coli	(235 cfu/100 mL)
				85	E. coli	(235 cfu/100 mL)
				728	E. coli	(235 cfu/100 mL)
				808	E. coli	(235 cfu/100 mL)
				710	E. coli	(235 cfu/100 mL)
				602	E. coli	(235 cfu/100 mL)
				8704	E. coli	(235 cfu/100 mL)
				9768	E. coli	(235 cfu/100 mL)
				218	E. coli	(235 cfu/100 mL)
				187	E. coli	(235 cfu/100 mL)
				84	E. coli	(235 cfu/100 mL)
				105	E. coli	(235 cfu/100 mL)
				57	E. coli	(235 cfu/100 mL)
				84	E. coli	(235 cfu/100 mL)
				411	E. coli	(235 cfu/100 mL)
				102	E. coli	(235 cfu/100 mL)
				41	E. coli	(235 cfu/100 mL)
				19	E. coli	(235 cfu/100 mL)
				1733	E. coli	(235 cfu/100 mL)
				145	E. coli	(235 cfu/100 mL)
				40	E. coli	(235 cfu/100 mL)
				179	E. coli	(235 cfu/100 mL)
				152	E. coli	(235 cfu/100 mL)
				50	E. coli	(235 cfu/100 mL)
				4220	E. coli	(235 cfu/100 mL)
				22820	E. coli	(235 cfu/100 mL)
				345	E. coli	(235 cfu/100 mL)
				96	E. coli	(235 cfu/100 mL)
				365	E. coli	(235 cfu/100 mL)
				76	E. coli	(235 cfu/100 mL)
				548	E. coli	(235 cfu/100 mL)
				105	E. coli	(235 cfu/100 mL)
				260	E. coli	(235 cfu/100 mL)
				45	E. coli	(235 cfu/100 mL)

Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Applicable Standard for E. coli
				2203	E. coli	(235 cfu/100 mL)
				228	E. coli	(235 cfu/100 mL)
				31	E. coli	(235 cfu/100 mL)
				29	E. coli	(235 cfu/100 mL)
				18	E. coli	(235 cfu/100 mL)
				365	E. coli	(235 cfu/100 mL)
				2420	E. coli	(235 cfu/100 mL)
				517	E. coli	(235 cfu/100 mL)
				135	E. coli	(235 cfu/100 mL)
				161	E. coli	(235 cfu/100 mL)
				2420	E. coli	(235 cfu/100 mL)
				54	E. coli	(235 cfu/100 mL)
				8690	E. coli	(235 cfu/100 mL)
				107	E. coli	(235 cfu/100 mL)
				12740	E. coli	(235 cfu/100 mL)
				100	E. coli	(235 cfu/100 mL)
				1986	E. coli	(235 cfu/100 mL)
				55	E. coli	(235 cfu/100 mL)
				3495	E. coli	(235 cfu/100 mL)
				122	E. coli	(235 cfu/100 mL)
				649	E. coli	(235 cfu/100 mL)
				579	E. coli	(235 cfu/100 mL)
				613	E. coli	(235 cfu/100 mL)
				649	E. coli	(235 cfu/100 mL)
				248	E. coli	(235 cfu/100 mL)
				99	E. coli	(235 cfu/100 mL)
				70	E. coli	(235 cfu/100 mL)
				435	E. coli	(235 cfu/100 mL)
				172	E. coli	(235 cfu/100 mL)
				378	E. coli	(235 cfu/100 mL)
				172	E. coli	(235 cfu/100 mL)
				73	E. coli	(235 cfu/100 mL)
				866	E. coli	(235 cfu/100 mL)
				2420	E. coli	(235 cfu/100 mL)
				816	E. coli	(235 cfu/100 mL)
				345	E. coli	(235 cfu/100 mL)
				15650	E. coli	(235 cfu/100 mL)
				150	E. coli	(235 cfu/100 mL)
				2420	E. coli	(235 cfu/100 mL)
				210	E. coli	(235 cfu/100 mL)
				152	E. coli	(235 cfu/100 mL)
				249	E. coli	(235 cfu/100 mL)

Summary Range			
	Maumee @ Anthony Boulevard -	Maumee @ Anthony Boulevard -	Maumee @ Anthony Boulevard -
Minimum:	20	20	3
5th Percentile:	50	48	18
25th Percentile:	295	278	95
Median:	570	1,050	291
75th Percentile:	1,450	3,250	770
95th Percentile:	4,030	10,675	8,034
Maximum:	5,900	42,000	22,820

Chart Data			
	Maumee @ Anthony Boulevard - 1970s Fecal Coliform	Maumee @ Anthony Boulevard - 1980s Fecal Coliform	Maumee @ Anthony Boulevard - 2000s E. Coli
Series 1	20	20	3
Series 2	30	28	15
Series 3	245	230	77
Series 4	275	773	196
Series 5	880	2,200	480
Series 6	2,580	7,425	7,264
Series 7	1,870	31,325	14,786

## **APPENDIX J: Data Set for Maumee River @ Landin Road**

### **Box and Whiskers Graph**

Maumee @ Landin Road - 1990s E. Coli		Maumee @ Landin Road - 2000s E. Coli		Applicable standard for E. coli
Result (cfu/100 mL)	Indicator Organis m	Result (cfu/100 mL)	Indicator Organis m	
2900 E. coli (		730 E. coli (235 cfu/100 mL)		
1600 E. coli (		240 E. coli (235 cfu/100 mL)		
340 E. coli (		770 E. coli (235 mprn/100 mL)		
30 E. coli (		600 E. coli (235 cfu/100 mL)		
330 E. coli (		270 E. coli (235 cfu/100 mL)		
90 E. coli (		390 E. coli (235 cfu/100 mL)		
150 E. coli (		480 E. coli (235 cfu/100 mL)		
6200 E. coli (		10 E. coli (235 cfu/100 mL)		
5200 E. coli (		44 E. coli (235 cfu/100 mL)		
2200 E. coli (		64 E. coli (235 cfu/100 mL)		
10 E. coli (		308 E. coli (235 cfu/100 mL)		
430 E. coli (		650 E. coli (235 cfu/100 mL)		
340 E. coli (		600 E. coli (235 cfu/100 mL)		
400 E. coli (		360 E. coli (235 cfu/100 mL)		
210 E. coli (		170 E. coli (235 cfu/100 mL)		
10 E. coli (		1024 E. coli (235 cfu/100 mL)		
550 E. coli (		200 E. coli (235 cfu/100 mL)		
6300 E. coli (		800 E. coli (235 cfu/100 mL)		
780 E. coli (		60 E. coli (235 cfu/100 mL)		
360 E. coli (		830 E. coli (235 cfu/100 mL)		
220 E. coli (		1020 E. coli (235 cfu/100 mL)		
730 E. coli (		440 E. coli (235 cfu/100 mL)		
40 E. coli (		60 E. coli (235 cfu/100 mL)		
450 E. coli (		3200 E. coli (235 cfu/100 mL)		
380 E. coli (		920 E. coli (235 cfu/100 mL)		
5400 E. coli (		200 E. coli (235 cfu/100 mL)		
1200 E. coli (		2240 E. coli (235 cfu/100 mL)		
3500 E. coli (		1460 E. coli (235 cfu/100 mL)		
18000 E. coli (		8000 E. coli (235 cfu/100 mL)		
190 E. coli (		500 E. coli (235 cfu/100 mL)		
10 E. coli (		1020 E. coli (235 cfu/100 mL)		
810 E. coli (		4600 E. coli (235 cfu/100 mL)		
130 E. coli (		620 E. coli (235 cfu/100 mL)		
70 E. coli (		1020 E. coli (235 cfu/100 mL)		
150 E. coli (		768 E. coli (235 cfu/100 mL)		
150 E. coli (		440 E. coli (235 cfu/100 mL)		
290 E. coli (		400 E. coli (235 cfu/100 mL)		
20 E. coli (		300 E. coli (235 cfu/100 mL)		
170 E. coli (		5000 E. coli (235 cfu/100 mL)		
2200 E. coli (		400 E. coli (235 cfu/100 mL)		
790 E. coli (		5400 E. coli (235 cfu/100 mL)		
50 E. coli (		300 E. coli (235 cfu/100 mL)		
110 E. coli (		1800 E. coli (235 cfu/100 mL)		
400 E. coli (		200 E. coli (235 cfu/100 mL)		

Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Applicable standard for E. coli
540 E. coli (		470 E. coli (235 cfu/100 mL)		
160 E. coli (		250 E. coli (235 cfu/100 mL)		
340 E. coli (		660 E. coli (235 cfu/100 mL)		
200 E. coli (		430 E. coli (235 cfu/100 mL)		
330 E. coli (		420 E. coli (235 cfu/100 mL)		
150 E. coli (		400 E. coli (235 cfu/100 mL)		
870 E. coli (		130 E. coli (235 cfu/100 mL)		
90 E. coli (		160 E. coli (235 cfu/100 mL)		
1700 E. coli (		65 E. coli (235 cfu/100 mL)		
2600 E. coli (		620 E. coli (235 cfu/100 mL)		
320 E. coli (		1480 E. coli (235 cfu/100 mL)		
120 E. coli (		420 E. coli (235 cfu/100 mL)		
630 E. coli (		560 E. coli (235 cfu/100 mL)		
50 E. coli (		370 E. coli (235 cfu/100 mL)		
2900 E. coli (		640 E. coli (235 cfu/100 mL)		
170 E. coli (		680 E. coli (235 cfu/100 mL)		
170 E. coli (		220 E. coli (235 cfu/100 mL)		
3300 E. coli (		130 E. coli (235 cfu/100 mL)		
59000 E. coli (		105 E. coli (235 cfu/100 mL)		
1800 E. coli (		270 E. coli (235 cfu/100 mL)		
40 E. coli (		32 E. coli (235 cfu/100 mL)		
30 E. coli (		36 E. coli (235 cfu/100 mL)		
2600 E. coli (		7 E. coli (235 cfu/100 mL)		
8800 E. coli (		48 E. coli (235 cfu/100 mL)		
540 E. coli (		28 E. coli (235 cfu/100 mL)		
150 E. coli (		1000 E. coli (235 cfu/100 mL)		
21000 E. coli (		152 E. coli (235 cfu/100 mL)		
310 E. coli (		64 E. coli (235 cfu/100 mL)		
30 E. coli (		352 E. coli (235 cfu/100 mL)		
1400 E. coli (		296 E. coli (235 cfu/100 mL)		
590 E. coli (		500 E. coli (235 cfu/100 mL)		
220 E. coli (		340 E. coli (235 cfu/100 mL)		
870 E. coli (		500 E. coli (235 cfu/100 mL)		
		200 E. coli (235 cfu/100 mL)		
		1500 E. coli (235 cfu/100 mL)		
		140 E. coli (235 cfu/100 mL)		
		15 E. coli (235 cfu/100 mL)		
		840 E. coli (235 cfu/100 mL)		
		250 E. coli (235 cfu/100 mL)		
		78 E. coli (235 cfu/100 mL)		
		22 E. coli (235 cfu/100 mL)		
		8 E. coli (235 cfu/100 mL)		
		20 E. coli (235 cfu/100 mL)		
		1 E. coli (235 cfu/100 mL)		
		7 E. coli (235 cfu/100 mL)		
		24 E. coli (235 cfu/100 mL)		
		78 E. coli (235 cfu/100 mL)		
		84 E. coli (235 cfu/100 mL)		
		52 E. coli (235 cfu/100 mL)		

Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Applicable standard for E. coli
		51	E. coli	(235 cfu/100 mL)
		27	E. coli	(235 cfu/100 mL)
		16	E. coli	(235 cfu/100 mL)
		411	E. coli	(235 cfu/100 mL)
		4840	E. coli	(235 cfu/100 mL)
		630	E. coli	(235 cfu/100 mL)
		110	E. coli	(235 cfu/100 mL)
		9680	E. coli	(235 cfu/100 mL)
		7740	E. coli	(235 cfu/100 mL)
		366	E. coli	(235 cfu/100 mL)
		5767	E. coli	(235 cfu/100 mL)
		500	E. coli	(235 cfu/100 mL)
		186	E. coli	(235 cfu/100 mL)
		786	E. coli	(235 cfu/100 mL)
		1024	E. coli	(235 cfu/100 mL)
		63	E. coli	(235 cfu/100 mL)
		456	E. coli	(235 cfu/100 mL)
		700	E. coli	(235 cfu/100 mL)
		424	E. coli	(235 cfu/100 mL)
		1092	E. coli	(235 cfu/100 mL)
		2924	E. coli	(235 cfu/100 mL)
		16328	E. coli	(235 cfu/100 mL)
		292	E. coli	(235 cfu/100 mL)
		97	E. coli	(235 cfu/100 mL)
		113	E. coli	(235 cfu/100 mL)
		152	E. coli	(235 cfu/100 mL)
		161	E. coli	(235 cfu/100 mL)
		162	E. coli	(235 cfu/100 mL)
		387	E. coli	(235 cfu/100 mL)
		84	E. coli	(235 cfu/100 mL)
		47	E. coli	(235 cfu/100 mL)
		13	E. coli	(235 cfu/100 mL)
		4430	E. coli	(235 cfu/100 mL)
		111	E. coli	(235 cfu/100 mL)
		23	E. coli	(235 cfu/100 mL)
		435	E. coli	(235 cfu/100 mL)
		238	E. coli	(235 cfu/100 mL)
		40	E. coli	(235 cfu/100 mL)
		345	E. coli	(235 cfu/100 mL)
		10760	E. coli	(235 cfu/100 mL)
		192	E. coli	(235 cfu/100 mL)
		61	E. coli	(235 cfu/100 mL)
		144	E. coli	(235 cfu/100 mL)
		84	E. coli	(235 cfu/100 mL)
		866	E. coli	(235 cfu/100 mL)
		261	E. coli	(235 cfu/100 mL)
		488	E. coli	(235 cfu/100 mL)
		178	E. coli	(235 cfu/100 mL)
		1986	E. coli	(235 cfu/100 mL)

Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Applicable standard for E. coli
		308	E. coli	(235 cfu/100 mL)
		147	E. coli	(235 cfu/100 mL)
		138	E. coli	(235 cfu/100 mL)
		126	E. coli	(235 cfu/100 mL)
		517	E. coli	(235 cfu/100 mL)
		2420	E. coli	(235 cfu/100 mL)
		387	E. coli	(235 cfu/100 mL)
		166	E. coli	(235 cfu/100 mL)
		82	E. coli	(235 cfu/100 mL)
		727	E. coli	(235 cfu/100 mL)
		91	E. coli	(235 cfu/100 mL)
		14140	E. coli	(235 cfu/100 mL)
		127	E. coli	(235 cfu/100 mL)
		4200	E. coli	(235 cfu/100 mL)
		100	E. coli	(235 cfu/100 mL)
		1300	E. coli	(235 cfu/100 mL)
		44	E. coli	(235 cfu/100 mL)
		3310	E. coli	(235 cfu/100 mL)
		127	E. coli	(235 cfu/100 mL)
		118	E. coli	(235 cfu/100 mL)
		687	E. coli	(235 cfu/100 mL)
		727	E. coli	(235 cfu/100 mL)
		272	E. coli	(235 cfu/100 mL)
		225	E. coli	(235 cfu/100 mL)
		119	E. coli	(235 cfu/100 mL)
		60	E. coli	(235 cfu/100 mL)
		308	E. coli	(235 cfu/100 mL)
		142	E. coli	(235 cfu/100 mL)
		435	E. coli	(235 cfu/100 mL)
		161	E. coli	(235 cfu/100 mL)
		130	E. coli	(235 cfu/100 mL)
		365	E. coli	(235 cfu/100 mL)
		2420	E. coli	(235 cfu/100 mL)
		548	E. coli	(235 cfu/100 mL)
		238	E. coli	(235 cfu/100 mL)
		2420	E. coli	(235 cfu/100 mL)
		261	E. coli	(235 cfu/100 mL)
		2420	E. coli	(235 cfu/100 mL)
		194	E. coli	(235 cfu/100 mL)
		313	E. coli	(235 cfu/100 mL)
		236	E. coli	(235 cfu/100 mL)

Summary Range		
	Maumee @ Landin Road - 1990s E. Coli	Maumee @ Landin Road - 2000s E. Coli
Minimum:	10	1
5th Percentile:	28	22
25th Percentile:	150	123
Median:	340	308
75th Percentile:	1,400	694
95th Percentile:	6,800	4,816
Maximum:	59,000	16,328

Chart Data		
	Maumee @ Landin Road - 1990s E. Coli	Maumee @ Landin Road - 2000s E. Coli
Series 1	10	1
Series 2	18	21
Series 3	122	100
Series 4	190	186
Series 5	1,060	386
Series 6	5,400	4,123
Series 7	52,200	11,512

## **APPENDIX K: Data Set for Maumee River @ SR 101**

### **Box and Whiskers Graph**

Maumee @ SR101 - 1970s Fecal Coliform		Maumee @ SR101 - 1980s Fecal Coliform		Maumee @ SR101 - 1990s E. Coli		Applicable Standard (E. coli)
Result (cfu/100 mL)	Indicator Organis m	Result (cfu/100 mL)	Indicator Organis m	Result (cfu/100 mL)	Indicator Organis m	
1100 Coliform		150 Coliform		11000 E. coli	(235 cfu/100 mL)	
1200 Coliform		180 Coliform		110 E. coli	(235 cfu/100 mL)	
420 Coliform		260 Coliform		40 E. coli	(235 cfu/100 mL)	
1200 Coliform		3300 Coliform		1200 E. coli	(235 cfu/100 mL)	
1300 Coliform		20 Coliform		27000 E. coli	(235 cfu/100 mL)	
1200 Coliform		6000 Coliform		220 E. coli	(235 cfu/100 mL)	
2300 Coliform		5500 Coliform		370 E. coli	(235 cfu/100 mL)	
180 Coliform		150 Coliform		410 E. coli	(235 cfu/100 mL)	
5500 Coliform		1200 Coliform		6000 E. coli	(235 cfu/100 mL)	
90 Coliform		2000 Coliform		290 E. coli	(235 cfu/100 mL)	
720 Coliform		160 Coliform		1400 E. coli	(235 cfu/100 mL)	
1200 Coliform		340 Coliform		1500 E. coli	(235 cfu/100 mL)	
1100 Coliform		190 Coliform		270 E. coli	(235 cfu/100 mL)	
1600 Coliform		160 Coliform		200 E. coli	(235 cfu/100 mL)	
50 Coliform		35000 Coliform		4300 E. coli	(235 cfu/100 mL)	
240 Coliform		54000 Coliform		700 E. coli	(235 cfu/100 mL)	
800 Coliform		640 Coliform		680 E. coli	(235 cfu/100 mL)	
220 Coliform		72000 Coliform		230 E. coli	(235 cfu/100 mL)	
240 Coliform		3700 Coliform		100 E. coli	(235 cfu/100 mL)	
130 Coliform		460 Coliform		160 E. coli	(235 cfu/100 mL)	
1200 Coliform		4300 Coliform		1400 E. coli	(235 cfu/100 mL)	
70 Coliform		910 Coliform		210 E. coli	(235 cfu/100 mL)	
780 Coliform		130 Coliform		80 E. coli	(235 cfu/100 mL)	
30 Coliform		14000 Coliform		170 E. coli	(235 cfu/100 mL)	
480 Coliform		19000 Coliform		170 E. coli	(235 cfu/100 mL)	
30 Coliform		140 Coliform		1400 E. coli	(235 cfu/100 mL)	
670 Coliform		920 Coliform		630 E. coli	(235 cfu/100 mL)	
860 Coliform		3700 Coliform		280 E. coli	(235 cfu/100 mL)	
720 Coliform		110 Coliform		460 E. coli	(235 cfu/100 mL)	
430 Coliform		980 Coliform		2800 E. coli	(235 cfu/100 mL)	
40 Coliform		730 Coliform		860 E. coli	(235 cfu/100 mL)	
2800 Coliform		540 Coliform		10 E. coli	(235 cfu/100 mL)	
450 Coliform		310 Coliform		50 E. coli	(235 cfu/100 mL)	
10 Coliform		2300 Coliform		840 E. coli	(235 cfu/100 mL)	
50 Coliform		240 Coliform		170 E. coli	(235 cfu/100 mL)	
3300 Coliform		10 Coliform		250 E. coli	(235 cfu/100 mL)	
740 Coliform		500 Coliform		530 E. coli	(235 cfu/100 mL)	
80 Coliform		1800 Coliform		3100 E. coli	(235 cfu/100 mL)	
10 Coliform		1000 Coliform		1600 E. coli	(235 cfu/100 mL)	
4400 Coliform		150 Coliform		130 E. coli	(235 cfu/100 mL)	
500 Coliform		230 Coliform		60 E. coli	(235 cfu/100 mL)	
600 Coliform		370 Coliform		310 E. coli	(235 cfu/100 mL)	

Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Applicable Standard (E. coli)
200 Coliform		150 Coliform		2100 E. coli		(235 cfu/100 mL)
20 Coliform		240 Coliform		330 E. coli		(235 cfu/100 mL)
4400 Coliform		550 Coliform		1700 E. coli		(235 cfu/100 mL)
2300 Coliform		1800 Coliform		700 E. coli		(235 cfu/100 mL)
2300 Coliform		220 Coliform		450 E. coli		(235 cfu/100 mL)
140 Coliform		30 Coliform		550 E. coli		(235 cfu/100 mL)
270 Coliform		10 Coliform		120 E. coli		(235 cfu/100 mL)
770 Coliform		3700 Coliform		1300 E. coli		(235 cfu/100 mL)
		1100 Coliform		30 E. coli		(235 cfu/100 mL)
		80 Coliform		390 E. coli		(235 cfu/100 mL)
		100 Coliform		250 E. coli		(235 cfu/100 mL)
		130 Coliform		180 E. coli		(235 cfu/100 mL)
		100 Coliform		2500 E. coli		(235 cfu/100 mL)
		95000 Coliform		210 E. coli		(235 cfu/100 mL)
		390 Coliform		39000 E. coli		(235 cfu/100 mL)
		2600 Coliform		630 E. coli		(235 cfu/100 mL)
		1900 Coliform		50 E. coli		(235 cfu/100 mL)
		340 Coliform		780 E. coli		(235 cfu/100 mL)
		800 Coliform		10 E. coli		(235 cfu/100 mL)
		2400 Coliform		50 E. coli		(235 cfu/100 mL)
		380 Coliform		20 E. coli		(235 cfu/100 mL)
		3200 Coliform		150 E. coli		(235 cfu/100 mL)
		200 Coliform		20 E. coli		(235 cfu/100 mL)
		3900 Coliform		270 E. coli		(235 cfu/100 mL)
		430 Coliform		10 E. coli		(235 cfu/100 mL)
		12000 Coliform		80 E. coli		(235 cfu/100 mL)
		790 Coliform		13000 E. coli		(235 cfu/100 mL)
		5300 Coliform		970 E. coli		(235 cfu/100 mL)
		190 Coliform		40 E. coli		(235 cfu/100 mL)
		1000 Coliform		140 E. coli		(235 cfu/100 mL)
		520 Coliform		400 E. coli		(235 cfu/100 mL)
		10 Coliform		800 E. coli		(235 cfu/100 mL)
		10 Coliform		280 E. coli		(235 cfu/100 mL)
		2200 Coliform		110 E. coli		(235 cfu/100 mL)
		920 Coliform		130 E. coli		(235 cfu/100 mL)
		120 Coliform		270 E. coli		(235 cfu/100 mL)
		90 Coliform		100 E. coli		(235 cfu/100 mL)
		130 Coliform		1200 E. coli		(235 cfu/100 mL)
		70 Coliform		30 E. coli		(235 cfu/100 mL)
		2600 Coliform		3300 E. coli		(235 cfu/100 mL)
		3600 Coliform		800 E. coli		(235 cfu/100 mL)
		1600 Coliform		120 E. coli		(235 cfu/100 mL)
		70 Coliform		240 E. coli		(235 cfu/100 mL)
				590 E. coli		(235 cfu/100 mL)
				350 E. coli		(235 cfu/100 mL)
				380 E. coli		(235 cfu/100 mL)
				60 E. coli		(235 cfu/100 mL)
				40 E. coli		(235 cfu/100 mL)
				1200 E. coli		(235 cfu/100 mL)

Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Result (cfu/100 mL)	Indicator Organism	Applicable Standard (E. coli)
				4900	E. coli	(235 cfu/100 mL)
				3300	E. coli	(235 cfu/100 mL)
				420	E. coli	(235 cfu/100 mL)
				190	E. coli	(235 cfu/100 mL)
				1700	E. coli	(235 cfu/100 mL)
				11000	E. coli	(235 cfu/100 mL)
				560	E. coli	(235 cfu/100 mL)
				110	E. coli	(235 cfu/100 mL)
				89000	E. coli	(235 cfu/100 mL)
				530	E. coli	(235 cfu/100 mL)
				40	E. coli	(235 cfu/100 mL)
				530	E. coli	(235 cfu/100 mL)
				440	E. coli	(235 cfu/100 mL)
				160	E. coli	(235 cfu/100 mL)
				710	E. coli	(235 cfu/100 mL)
				150	E. coli	(235 cfu/100 mL)
				310	E. coli	(235 mpn/100 mL)

Summary Range			
	Maumee @ SR101 - 1970s Fecal Coliform	Maumee @ SR101 - 1980s Fecal Coliform	Maumee @ SR101 - 1990s E. Coli
Minimum:	10	10	10
5th Percentile:	25	22	30
25th Percentile:	150	150	138
Median:	635	520	340
75th Percentile:	1,200	2,300	888
95th Percentile:	3,905	18,000	9,250
Maximum:	5,500	95,000	89,000

Chart Data			
	Maumee @ SR101 - 1970s Fecal Coliform	Maumee @ SR101 - 1980s Fecal Coliform	Maumee @ SR101 - 1990s E. Coli
Series 1	10	10	10
Series 2	15	12	20
Series 3	126	128	108
Series 4	485	370	203
Series 5	565	1,780	548
Series 6	2,705	15,700	8,362
Series 7	1,595	77,000	79,750

Maumee @ SR101 - 1970s Fecal Coliform	Maumee @ SR101 - 1980s Fecal Coliform	Maumee @ SR101 - 1990s E. Coli
---	---	--------------------------------------

## APPENDIX L: Substantial and Widespread Economic and Social Impact – Supporting Information

The City of Fort Wayne’s original 2005 Financial Capability Analysis (Original FCA) is contained in Section 3.5 of the Long Term Control Plan (LTCP). The Municipal Preliminary Screener (MPS) analysis presented in this Updated UAA is based on updated information through the year 2018. Supporting information to the Updated UAA MPS analysis and comparisons to the Original UAA are summarized below.

### Section 1 – Annual Operation and Maintenance (O&M) Cost Information

#### *Original FCA analysis*

- Annual O&M costs for the existing system were projected to increase at an average annual rate of 2.5 percent from the year 2005 baseline, plus additional costs for increases in the operation and maintenance of new facilities constructed as part of the LTCP and wastewater capital plans. The indexed annual costs were synchronized with the capital program implementation schedule and were compared to historical expenses and published rates for accuracy and consistency.
  - The 2005 annual O&M expense in the original FCA for sewer was \$16,305,000. In addition to that O&M expense, there was an additional expense of \$1,793,000 for Payment in Lieu of Taxes (PILOT).
  - The estimated annual O&M expense for the year 2017 projected in the original FCA was \$27,116,000 with an additional estimated PILOT payment of \$5,401,000.

#### *Updated UAA MPS analysis*

- Actual 2017 O&M expenses for sewer were used in the updated analysis and in some MPS analysis scenarios 2017 actual stormwater O&M expenses were also used. 2017 Sewer O&M is **\$26,404,190** and 2017 Stormwater O&M is **\$5,323,261**. Although the City believes PILOT is a legitimate part of its O&M expense for the Utility, PILOT was not included in the updated calculations, but is noted below. The following are a breakdown of O&M costs:

<b>Wastewater Utility (excluding depreciation)</b>		
Operating Expenses:		
	Personnel services	\$ 9,028,357
	Contractual services	\$ 4,288,511
	Utilities	\$ 1,856,846
	Chemicals	\$ 721,152
	Administrative services	\$ 6,773,185
	Other supplies and services	\$ 3,736,139
	<b>TOTAL O&amp;M EXPENSE (EXCLUDING PILOT)</b>	<b>\$ 26,404,190</b>
	PILOT	\$ 4,670,166
	<b>TOTAL O&amp;M EXPENSE (WITH PILOT)</b>	<b>\$ 31,074,356</b>

<b>Stormwater Utility (excluding depreciation)</b>			
Operating Expenses:			
	Personnel services	\$	1,980,449
	Contractual services	\$	244,868
	Administrative services	\$	2,546,941
	Other supplies and services	\$	551,003
<b>TOTAL O&amp;M EXPENSE (EXCLUDING PILOT)</b>		<b>\$</b>	<b>5,323,261</b>
	PILOT		\$1,233,469
<b>TOTAL O&amp;M EXPENSE (WITH PILOT)</b>		<b>\$</b>	<b>6,556,730</b>

- The City continues to assume an average annual increase of 2.5% in total annual O&M costs is a reasonable projection.

## Section 2 - Debt Service Information and Payment Requirements

### *Original FCA analysis*

- Consistent with revenue bond requirements, the City assumed it would set rates to comply with a debt service coverage of 130 percent.
- City assumed 2% debt acquisition costs, 6% for average interest rates and a bond duration of 20 years
- Stormwater cost were not included

### *Updated UAA MPS analysis*

- Consistent with revenue bond requirements, the City continues to assume it will maintain rates to comply with a debt service coverage of 130 percent.
- City continues to assume 2% debt acquisition costs, 6% for average interest rates and a bond duration of 20 years
- Stormwater costs were included in some MPS analysis scenarios
- The average annual debt service payment for existing debt (through 2018) is based on the average of 2019-2025 payments per the bond amortization schedules. This resulted in total annual average payment for sewer of **\$43,839,865** and for stormwater **\$2,145,057**

CITY OF FORT WAYNE, INDIANA  
USE ATTAINABILITY ANALYSIS: RECREATIONAL USE  
ST. MARYS RIVER, ST. JOSEPH RIVER, AND MAUMEE RIVER

2020 UPDATE

Bond Issues and Debt Service Requirements										
	Principal Outstanding		Annual Debt Service Payment							
Sewer										
Year	Principal		2019	2020	2021	2022	2023	2024	2025	
2009A	3,443,758	SRF	248,944	248,945	248,945	248,945	248,946	248,944	248,945	
2009B	22,692,236	SRF	2,171,004	2,171,004	2,171,004	2,171,004	2,171,004	2,171,004	2,171,004	
2011A	30,280,000	Revenue	3,486,640	3,483,520	3,483,300	3,495,840	3,510,720	3,527,800	3,556,940	
2011B	26,667,000	SRF	2,120,715	2,120,533	2,120,526	2,120,673	2,120,949	2,120,332	2,120,822	
2012A	8,603,000	SRF	622,277	622,626	622,815	622,844	622,712	622,421	622,969	
2012B	12,515,000	Revenue	1,308,750	1,312,750	1,316,250	1,319,250	1,326,750	1,333,650	1,333,100	
2012	12,375,000	Revenue	2,166,293	2,166,640	2,166,553	2,171,030				
2013	2,765,000	Revenue								
2013A	27,140,000	Revenue	4,067,428	4,071,838	4,079,785	4,071,173	4,111,293	4,139,170		
2013B	42,260,000	Revenue	1,492,125	1,492,125	1,492,125	1,492,125	1,492,125	1,492,125	5,657,125	
2014A	15,543,000	SRF	1,119,400	1,119,835	1,119,823	1,119,365	1,119,461	1,120,086	1,119,218	
2014B	60,247,000	SRF	2,535,033	2,552,746	2,539,230	2,545,407	4,665,661	4,629,978	4,577,604	
2014C	4,820,000	SRF	350,563	348,954	352,192	350,121	352,897	350,366	352,681	
2016	35,125,000	Revenue	4,265,750	4,268,650	4,270,900	4,265,000	4,261,100	4,261,700	4,261,300	
2016A	108,000,000	SRF	6,223,700	6,225,800	6,221,200	6,225,000	6,222,000	6,222,300	6,225,800	
2016B	138,583,000	SRF	5,870,195	6,271,089	7,493,108	7,489,325	7,491,099	7,488,025	7,489,927	
2017A	16,700,000	Revenue	1,577,144	1,567,416	1,562,183	1,556,317	1,554,818	1,552,561	1,544,544	
2017B	16,700,000	Revenue	1,582,017	1,572,163	1,561,803	1,560,937	1,554,312	1,547,055	1,544,165	
2018A	742,584	SRF	757,687							
2018B	21,722,416	SRF	599,202	1,428,759	1,428,836	1,428,646	1,428,579	1,428,311	1,428,828	avg
			42,564,864	43,045,392	44,250,577	44,253,001	44,254,426	44,255,828	44,254,971	43,839,865
Stormwater										avg
SW 2017	27,320,000	Revenue	2,195,000	2,193,550	2,186,550	2,104,400	2,107,800	2,110,550	2,117,550	2,145,057

### Section 3 - Capital Improvement Program Information

#### *Original FCA analysis*

- The City's capital improvement program (CIP) assumed that the City would move forward during the 2008-2025 year forecast period with the following plans and projects: the LTCP and sanitary sewer discharge elimination plans, sewer repair and replacement program, collection system and treatment master plans, as well as other projected wastewater improvements and maintenance needs within the collection system and at the City's treatment plant. The estimated cost of the total sewer CIP including the LTCP was approximately:

#### **Original LTCP 2008-2025**

<b>Capital Program</b>	<b>2005 Dollar Value</b>	<b>Inflated Dollar Value</b>
LTCP	\$239.4 million	\$361.7 million
Wastewater Improvements CIP	\$454.6 million	\$566.0 million
<b>TOTAL</b>	<b>\$694.0 million</b>	<b>\$927.7 million</b>

- Capital costs were projected to increase at an average annual rate of 3.5 percent. Thus, the estimated Inflated Dollar Value of the Capital Program, as noted in the table above, was calculated based upon each project's cost being inflated at 3.5 percent per year from 2005 up to the year it was scheduled to be completed.
- The City's repair, replacement, and capital maintenance activities were assumed to increase over time, reflecting the increased attention the systems will require as they age.
- Increases in future operating and maintenance costs for new infrastructure were incorporated based on projects that would directly result in new system components or improved performance.
- Stormwater capital improvement costs were not included

#### *Updated UAA MPS analysis*

- Actual CIP costs were used through 2018, with remaining sewer capital costs projected to increase at an average annual rate of 3.5 percent for 2019-2025. The results of actual costs and the remaining projected costs through 2025 are shown in the tables below.

#### **Current LTCP 2008-2025**

<b>Capital Program</b>	<b>2005 Dollar Value</b>	<b>Actual to Date &amp; Projected Dollar Value</b>
LTCP	\$339.9 million	\$494.6 million
Wastewater Improvements CIP	\$326.6 million	\$471.7 million
<b>TOTAL</b>	<b>\$666.5 million</b>	<b>\$966.6 million</b>

- The City's sewer repair, replacement, and capital maintenance activities are assumed to continue to increase over time, reflecting the increased attention the systems will require as they age.
- The City's sewer capital improvement program assumes that the City will continue to move forward during the remaining period with projects from the LTCP and sanitary sewer overflow elimination plans, sewer repair and replacement program, collection system and treatment

master plans, as well as other projected wastewater improvements and maintenance needs within the collection system and at the City's treatment plant. The current estimated cost of this capital improvement program is approximately:

- To implement complete capture and full control of all CSOs, the infrastructure would need to be significantly upsized, and the CIP estimated cost would be increased to approximately:

**Full Control 2008-2025  
Capital Program**

	<b>2005 Dollar Value</b>	<b>Actual to Date &amp; Projected Dollar Value</b>
Full Control	\$703.3 million	\$1,080.0 million
Wastewater Improvements CIP	\$326.6 million	\$471.7 million
<b>TOTAL</b>	<b>\$1029.9 million</b>	<b>\$1551.7 million</b>

- A comparison and breakdown of the above noted 2008-2025 Current LTCP and Full Control cost estimates are provided in the following Exhibits, as well as more details on actual costs expended to date.
  - **Exhibit L-1:** Summary of all years 2008-2025 capital costs (in both 2005 dollar and inflated dollar value) as well as LTCP capital costs expended 2008-2018
- Stormwater capital improvement costs were included in some MPS analysis scenarios
- The City's stormwater capital improvement program assumes that the City will continue to move forward during the remaining period with projects for water quality improvements, capacity and repair and replacement programs, as well as other projected stormwater improvements and maintenance needs within the stormwater system.
- The following attachments provide additional or more detailed information on the Capital Programs used in the Updated analysis
  - **Exhibit L-2:** Summary of remaining years 2019-2025 Sewer Utility capital and O&M costs for CURRENT LTCP scenario
    - Average Annual Revenue funded CIP - **\$16,483,614**
    - Expected increase in O&M from CIP - **\$5,374,641**
    - Remaining LTCP Cost - **\$241,724,068**
    - Remaining other Sewer CIP Costs - **\$239,470,850**
    - Total CIP funded by Revenue - **\$115,385,295**
    - Total CIP funded by Existing Bonds and Reimbursements - **\$154,794,141**
  - **Exhibit L-3:** Summary of remaining years 2019-2025 Sewer Utility capital and O&M costs for FULL CONTROL scenario
    - Average Annual Revenue funded CIP - **\$27,346,166**
    - Expected increase in O&M from CIP - **\$13,709,020**
    - Remaining LTCP Cost - **\$827,167,360**
    - Remaining other Sewer CIP Costs - **\$239,470,850**
    - Total CIP funded by Revenue - **\$191,423,165**
    - Total CIP funded by Existing Bonds and Reimbursements - **\$154,794,141**
  - **Exhibit L-4:** Summary of remaining years 2019-2025 Stormwater Utility capital and O&M costs

- Average Annual Revenue funded CIP - **\$7,240,610**
- Expected increase in O&M from CIP - **\$384,577**
- Remaining Stormwater Cost - **\$61,160,863**
- Total CIP funded by Revenue - **\$50,681,610**
- Total CIP funded by Existing Bonds and Reimbursements - **\$16,479,253**

## Section 4 - Residential Flow Share

### Original FCA analysis

- The Residential share of total wastewater flow in 2005 was estimated to be 60% based on a projection that the residential share of sewer flow increasing over time, as well as hydraulic modeling, land use information, infrastructure records and infiltration and inflow information at that time.

### Updated UAA MPS analysis

- The Residential share of total wastewater flow currently is estimated to be **66.4%**.
  - The primary difference between the original projection and the current calculation appears to be due improved hydraulic modeling information for the combined area flows and updated GIS information on the allocation of inflow and infiltration.

Residential Flow Analysis - WPCP Annual Treatment Breakdown			
2017			
Flow Characterization	Total (MG)	Residential Share (MG)	Comment on Calculation / Source of Information
<b>Billed Flow / Customer Consumption</b>	<b>8,057.3</b>	3,664.2	per customer metering / billing records - 45.5% residential
<b>Non-Billed Flow Breakdown</b>			
Recycled discharge from Biosolids Facility*	1,100.0	500.2	per customer metering/billing records - 45.5% residential
Combined Sewer Area Stormwater	1,341.3	831.6	per modeling and GIS analysis of land use and runoff area of combined area - 62% residential
Public Pipe & Manhole Leakage Allowance	1,751.9	1576.3	per GIS pipe and manhole records for public pipe, design standards for leakage, portioned by customer count/billing records - 90% residential
Private Pipe & Manhole Leakage Allowance	628.4	487.1	per GIS pipe and manhole records for private pipe, design standards for leakage, portioned by GIS records - 77.5% residential
Collection System Inflow & Infiltration	6,348.4	5,712.2	general allocation of remaining I&I - distributed per customer count/billing records - 90% residential
<b>Total Flow to Wastewater Treatment Plant**</b>	<b>19,227.3</b>	<b>12,771.7</b>	
		66.4%	
* Biosolids Facility receives lime sludge water from water Filtration Plant and anerobic sludge water from WPCP, which is placed in ponds and decant water returned to WPCP			
** Matches 2017 WPCP Influent Meter Records			

## Section 5 - Residential Customer Count

### *Original FCA analysis*

- The City's residential customer count based on billing information was 71,496 in 2005

2005 CUSTOMER COUNT		
Retail		TOTAL
	Residential	71,946
	Commercial	4,991
	Institutional	532
	Governmentl	160
	Industrial	319
	Sub-total Retail	77,948
Wholesale		
	Contract	13
	Sub-total Wholesale	13
	<b>TOTAL</b>	<b>77,961</b>

### *Updated UAA MPS analysis*

- The City's residential customer count based on current billing information is **81,796**

2017 CUSTOMER COUNT		
Retail		TOTAL
	Residential	81,796
	Multi-Family	1,631
	Lg Multi-Family	793
	Sm Commercial	4,339
	Lg Commercial	1,196
	Institutional	637
	Governmentl	106
	Civil City	124
	Inter-Dept	9
	Industrial	276
	Sub-total Retail	90,906
Wholesale		
	Contract	20
	Sub-total Wholesale	20
	<b>TOTAL</b>	<b>90,926</b>

## Section 6 - Median Household Income

### *Original FCA analysis*

- 1999 Median Household Income (MHI) was calculated by identifying each census tract in the service area and weighting it by population according to the formula prescribed by the guidance document. MHI was then inflated to 2005 by using the countywide rate of change from 1999 MHI, as reported in the 2000 census, to 2005 MHI, as reported in the 2005 American Community Survey (ACS). For future projections, MHI was forecasted to grow by 2.2% per year.
  - The 2005 MHI in the original FCA was \$42,791
  - Forecasted to 2017, the MHI per the original FCA would be calculated to be \$55,560

### *Updated UAA MPS analysis*

- An MHI value of **\$48,039** is used for the sewer service area. This figure is derived from the 2017 American Community Survey (ACS) 5-Year Estimates, which generates such financial data in years other than census years.
- An MHI value of **\$35,881** is used to calculate the MPS for Wayne Township. This figure comes from the 2017 American Community Survey (ACS) 1-Year Estimates.
  - **Exhibit L-5:** Provides details on the calculation of MHI for the Sewer Service Area and Wayne Township

## Section 7 - Residential Indicator / Municipal Preliminary Screener Values

### *Original FCA analysis*

- The Residential Indicator calculation in the 2005 FCA for the original approved LTCP, was calculated for the peak year to be:
  - All of Sewer Service Area - 1.80%
  - Only Wayne Township - 2.49%

### *Updated UAA MPS analysis*

- The details of the MPS calculations in the Updated UAA Table 5.5-5, using the updated information noted in Section 5.5 and the information in this Appendix L, can be found in the following Exhibits:
  - **Exhibit L-6:** Calculation of MPS for Full Control/WQS Compliance costs (sewer only costs) for:
    - All of Sewer Service Area - **2.96%**
    - Only Wayne Township - **3.97%**
  - **Exhibit L-7:** Calculation of MPS for Full Control/WQS Compliance costs (sewer and stormwater costs) for:
    - All of Sewer Service Area - **3.22%**
    - Only Wayne Township - **4.31%**
  - **Exhibit L-8:** Calculation of MPS for Current LTCP Compliance costs (sewer only costs) for:
    - All of Sewer Service Area - **1.87%**
    - Only Wayne Township - **2.51%**

- **Exhibit L-9:** Calculation of MPS for Current LTCP costs (sewer and stormwater costs) for:
  - All of Sewer Service Area - **2.13%**
  - Only Wayne Township - **2.85%**

**Exhibit L-1: Comparison of Current LTCP and Full Control CIP's 2008-2025**

**Exhibit L-1**  
**Comparison of Current LTCP**  
**and Full Control CIP's**  
**2008-2025**

**FORT WAYNE LTCP - CSO CONTROL MEASURE COST SUMMARY COMPARISON**

As of Jan 1, 2019

		CURRENT APPROVED LTCP			FULL CONTROL		
		CURRENT / INFLATED \$ VALUE			2005 \$ VALUE		
CSOCM No.	Projects / Category of Work	Capital Cost Completed 2008-2018	Total Capital Cost 2008-2025	Total Capital Cost 2008-2025	Capital Cost Completed 2008-2018	Total Capital Cost 2008-2025	Total Capital Cost 2008-2025
1	Plant Phase II - Primaries	\$-	\$-	\$-	\$-	\$-	\$-
2	Plant Phase III - Increase Peak Flow	\$22,317,154	\$22,317,154	\$22,317,154	\$17,425,431	\$17,425,431	\$17,425,431
3	Early Floatable Control	\$1,986,029	\$1,986,029	\$1,986,029	\$1,777,987	\$1,777,987	\$1,777,987
4	CSSCIP - Phase I	\$9,516,501	\$9,516,501	\$9,516,501	\$8,041,892	\$8,041,892	\$8,041,892
5	WW Ponds Storage & Dewatering	\$41,655,946	\$41,655,946	\$41,655,946	\$34,025,743	\$34,025,743	\$34,025,743
6	CSSCIP - Phase II	\$31,181,322	\$33,691,322	\$33,691,322	\$24,100,919	\$25,760,313	\$25,760,313
7 & 8	St. Joe River Relief Sewers	\$6,738,182	\$6,738,182	\$21,164,698	\$5,132,693	\$5,132,693	\$14,392,331
9	CSO 61 & 62 Relief Sewer, CSO 54 Storage	\$7,583,500	\$9,193,500	\$21,567,722	\$5,337,913	\$6,374,564	\$14,316,940
10	Morton Street to WW Ponds	\$10,401,510	\$15,146,510	\$24,959,262	\$7,126,821	\$10,263,804	\$16,562,104
11	3RPORT Tunnel, Sewers, Pump Station	\$121,376,924	\$333,810,992	\$839,248,006	\$84,316,220	\$219,349,083	\$534,521,093
12	Foster Park Relief Sewer	\$89,621	\$18,574,621	\$25,313,276	\$69,068	\$10,624,879	\$14,487,795
13	Late Floatable Control	\$-	\$740,000	\$740,000	\$-	\$409,723	\$409,723
14	CSO 64 Satellite Storage	\$-	\$1,200,000	\$7,516,901	\$-	\$684,346	\$4,286,798
15	WW Ponds High Rate Treatment	\$-	\$-	\$30,337,232	\$-	\$-	\$17,298,000
	<b>Total - LTCP</b>	<b>\$252,846,689</b>	<b>\$494,570,758</b>	<b>\$1,080,014,049</b>	<b>\$187,354,686</b>	<b>\$339,870,457</b>	<b>\$703,306,150</b>

Capital Costs Remaining (Years 2019-2025)

\$241,724,068

\$827,167,360

\$152,515,770

\$515,951,463

See Exhibit L-2  
for breakdown

See Exhibit L-3  
for breakdown

**Exhibit L-2: Current LTCP and All Sewer CIP Costs 2019-2025**

Exhibit L-2  
Current LTCP and All Sewer  
CIP Costs 2019-2025

2019 - 2025 Capital Budget: SEWER UTILITY - CURRENT LTCP

DESCRIPTION	FUNDING SOURCE	2019 BUDGET	2020 BUDGET	2021 BUDGET	2022 BUDGET	2023 BUDGET	2024 BUDGET	2025 BUDGET	TOTAL	O&M Increases from New TOTAL
<b>LTCP</b>		84,364,068	52,770,000	30,780,000	40,010,000	18,540,000	8,610,000	6,650,000	241,724,068	3,254,294
WPC PLANT TOTALS		6,608,526	13,235,000	7,595,000	6,235,000	6,445,000	5,580,000	16,045,000	61,743,526	937,706
BIOSOLIDS TOTALS		618,679	870,000	160,000	160,000	1,875,000	1,785,000	370,000	5,838,679	12,070
WET WEATHER PUMPING & STORAGE TOTALS		2,697,473	995,000	465,000	325,000	1,140,000	3,400,000	1,630,000	10,652,473	130,079
COLLECTION SYSTEM PUMPING & STORAGE TOTALS		1,538,139	2,140,000	1,250,000	1,120,000	1,280,000	1,120,000	1,160,000	9,608,139	92,656
COLLECTION SYSTEMS TOTALS		9,823,236	28,500,000	20,505,000	14,805,000	14,995,000	22,825,000	33,865,000	145,318,236	870,719
WPC MAINTENANCE TOTALS		1,534,797	1,415,000	690,000	640,000	650,000	680,000	700,000	6,309,797	77,116
<b>TOTAL SEWER UTILITY</b>		<b>107,184,918</b>	<b>99,925,000</b>	<b>61,445,000</b>	<b>63,295,000</b>	<b>44,925,000</b>	<b>44,000,000</b>	<b>60,420,000</b>	<b>481,194,918</b>	<b>5,374,641</b>
	Revenue Funded	5,395,295	16,905,000	17,360,000	17,860,000	18,355,000	19,960,000	19,550,000	115,385,295	
								Avg per Year	16,483,614	
	Existing Bonds, Reimbursements, Etc. Funds	100,704,141	42,590,000	11,000,000	-	500,000	-	-	154,794,141	
	Future Bond 1	1,085,481	40,430,000						41,515,481	
	Future Bond 2			33,085,000	45,435,000	26,070,000			104,590,000	
	Future Bond 3						24,040,000	40,870,000	64,910,000	
									211,015,481	
<b>Total LTCP Projects</b>		<b>84,364,068</b>	<b>52,770,000</b>	<b>30,780,000</b>	<b>40,010,000</b>	<b>18,540,000</b>	<b>8,610,000</b>	<b>6,650,000</b>	<b>241,724,068</b>	<b>3,254,294</b>
<b>Non LTCP Projects</b>		<b>22,820,850</b>	<b>47,155,000</b>	<b>30,665,000</b>	<b>23,285,000</b>	<b>26,385,000</b>	<b>35,390,000</b>	<b>53,770,000</b>	<b>239,470,850</b>	<b>2,120,346</b>
<b>Total Projects</b>		<b>107,184,918</b>	<b>99,925,000</b>	<b>61,445,000</b>	<b>63,295,000</b>	<b>44,925,000</b>	<b>44,000,000</b>	<b>60,420,000</b>	<b>481,194,918</b>	<b>5,374,641</b>

Remaining LTCP Capital Costs

Remaining Other Wastewater  
Capital Costs

Estimated increase  
in O&M

**Exhibit L-3: Full Control and All Sewer CIP Costs 2019-2025**

2019 - 2025 Capital Budget: SEWER UTILITY - FULL CONTROL

DESCRIPTION	FUNDING SOURCE	2019 BUDGET	2020 BUDGET	2021 BUDGET	2022 BUDGET	2023 BUDGET	2024 BUDGET	2025 BUDGET	TOTAL	O&M Increases from New TOTAL
LTCP-FULL CONTROL		84,364,068	290,443,459	167,428,893	179,036,488	55,523,455	35,683,127	14,687,870	827,167,360	11,588,674
WPC PLANT TOTALS		6,608,526	13,235,000	7,595,000	6,235,000	6,445,000	5,580,000	16,045,000	61,743,526	937,706
BIOSOLIDS TOTALS		618,679	870,000	160,000	160,000	1,875,000	1,785,000	370,000	5,838,679	12,070
WET WEATHER PUMPING & STORAGE TOTALS		2,697,473	995,000	465,000	325,000	1,140,000	3,400,000	1,630,000	10,652,473	130,079
COLLECTION SYSTEM PUMPING & STORAGE TOTALS		1,538,139	2,140,000	1,250,000	1,120,000	1,280,000	1,120,000	1,160,000	9,608,139	92,656
COLLECTION SYSTEMS TOTALS		9,823,236	28,500,000	20,505,000	14,805,000	14,995,000	22,825,000	33,865,000	145,318,236	870,719
WPC MAINTENANCE TOTALS		1,534,797	1,415,000	690,000	640,000	650,000	680,000	700,000	6,309,797	77,116
TOTAL SEWER UTILITY		107,184,918	337,598,459	198,093,893	202,321,488	81,908,455	71,073,127	68,457,870	1,066,638,209	13,709,020
Revenue Funded		5,395,295	24,905,000	32,360,000	32,860,000	33,355,000	34,960,000	27,587,870	191,423,165	
								Avg per Year	27,346,166	
Existing Bonds, Reimbursements, Etc. Funds		100,704,141	42,590,000	11,000,000	-	500,000	-	-	154,794,141	
Future Bond 1		1,085,481	270,103,459						271,188,940	
Future Bond 2				154,733,893	169,461,488	48,053,455			372,248,835	
Future Bond 3							36,113,127	40,870,000	76,983,127	
									720,420,902	
Total LTCP Projects		84,364,068	290,443,459	167,428,893	179,036,488	55,523,455	35,683,127	14,687,870	827,167,360	11,588,674
Non LTCP Projects		22,820,850	47,155,000	30,665,000	23,285,000	26,385,000	35,390,000	53,770,000	239,470,850	2,120,346
Total Projects		107,184,918	337,598,459	198,093,893	202,321,488	81,908,455	71,073,127	68,457,870	1,066,638,209	13,709,020

Remaining LTCP Capital Costs

Remaining Other Wastewater  
Capital Costs

Estimated increase  
in O&M

**Exhibit L-4: Stormwater CIP Costs 2019-2025**

Exhibit L-4 Stormwater CIP  
Costs 2019-2025

2019 - 2025 Capital Budget: STORMWATER

DESCRIPTION	FUNDING SOURCE	2019 BUDGET	2020 BUDGET	2021 BUDGET	2022 BUDGET	2023 BUDGET	2024 BUDGET	2025 BUDGET	TOTAL	O&M Increases from New TOTAL
STREAMS, DITCHES, DRAINS TOTALS		2,675,965	1,210,000	720,000	430,000	820,000	1,200,000	1,230,000	8,285,965	29,500
STORMWATER PUMPING & STORAGE TOTALS		277,133	90,000	60,000	60,000	120,000	120,000	130,000	857,133	15,020
FLOOD MANAGEMENT TOTALS		906,365	830,000	-	630,000	820,000	300,000	310,000	3,796,365	43,864
DRAINAGE SYSTEMS TOTALS		11,100,523	9,920,000	6,980,000	5,160,000	4,940,000	5,090,000	5,270,000	48,460,523	226,193
STORM MAINTENANCE TOTALS		1,030,877	720,000	590,000	810,000	840,000	870,000	900,000	5,760,877	70,000
<b>TOTAL STORMWATER UTILITY</b>		<b>15,990,863</b>	<b>12,770,000</b>	<b>8,350,000</b>	<b>7,090,000</b>	<b>7,540,000</b>	<b>7,580,000</b>	<b>7,840,000</b>	<b>67,160,863</b>	<b>384,577</b>
<b>TOTAL SEWER UTILITY</b>		<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>-</b>	<b>-</b>
	Revenue Funded	5,311,610	7,880,000	7,440,000	7,090,000	7,540,000	7,580,000	7,840,000	50,681,610	
								Avg per Year	7,240,230	
	Existing Bonds, Reimbursements, Etc. Funds	10,679,253	4,890,000	910,000	-	-	-	-	16,479,253	
	Future Bond 1	-	-	-	-	-	-	-	-	

Remaining Other Stormwater Capital Costs

Estimated increase in O&M

**Exhibit L-5: Sewer Service Area and Wayne Township Median Household Income**

MEDIAN INCOME IN THE PAST 12 MONTHS (IN 2017 INFLATION-ADJUSTED DOLLARS)  
2013-2017 American Community Survey 5-Year Estimates

Exhibit L-5 pg 1 of 2

Sewer Service Area  
Median Household  
Income

Geography	MHI	MHI Margin of Error	Households	HH Margin of Error	Weighted MHI
Census Tract 1, Allen County, Indiana	\$45,000	8418	1128	43	\$490.52
Census Tract 3, Allen County, Indiana	\$52,109	15304	1327	81	\$668.21
Census Tract 4, Allen County, Indiana	\$43,946	4151	1213	92	\$515.12
Census Tract 5, Allen County, Indiana	\$27,418	8638	1284	103	\$340.20
Census Tract 6, Allen County, Indiana	\$32,500	4388	702	75	\$220.47
Census Tract 7.01, Allen County, Indiana	\$35,227	3473	1274	98	\$433.69
Census Tract 7.04, Allen County, Indiana	\$34,665	3290	1270	85	\$425.43
Census Tract 8, Allen County, Indiana	\$41,763	2516	1795	104	\$724.41
Census Tract 9, Allen County, Indiana	\$33,404	3375	1292	79	\$417.05
Census Tract 10, Allen County, Indiana	\$35,729	9973	469	63	\$161.93
Census Tract 11, Allen County, Indiana	\$36,631	2499	943	81	\$333.80
Census Tract 12, Allen County, Indiana	\$20,417	8683	618	59	\$121.93
Census Tract 13, Allen County, Indiana	\$26,215	10725	631	54	\$159.85
Census Tract 16, Allen County, Indiana	\$23,209	3754	799	69	\$179.20
Census Tract 17, Allen County, Indiana	\$19,694	3388	698	83	\$132.84
Census Tract 20, Allen County, Indiana	\$27,581	5886	1296	123	\$345.42
Census Tract 21, Allen County, Indiana	\$27,788	6157	836	88	\$224.49
Census Tract 22, Allen County, Indiana	\$38,310	3971	1754	131	\$649.34
Census Tract 23, Allen County, Indiana	\$23,981	3936	1867	133	\$432.66
Census Tract 25, Allen County, Indiana	\$46,250	7692	1301	108	\$581.46
Census Tract 26, Allen County, Indiana	\$39,110	7862	1214	119	\$458.81
Census Tract 28, Allen County, Indiana	\$27,097	7907	776	72	\$203.20
Census Tract 29, Allen County, Indiana	\$23,924	4217	905	65	\$209.22
Census Tract 30, Allen County, Indiana	\$25,981	6117	1258	128	\$315.84
Census Tract 31, Allen County, Indiana	\$24,736	4595	1047	79	\$250.27
Census Tract 32, Allen County, Indiana	\$53,342	8703	2045	160	\$1,054.13
Census Tract 33.01, Allen County, Indiana	\$42,543	7855	1183	51	\$486.34
Census Tract 33.04, Allen County, Indiana	\$38,703	4501	1602	108	\$599.15
Census Tract 34, Allen County, Indiana	\$46,691	8113	1853	97	\$836.06
Census Tract 35, Allen County, Indiana	\$25,313	3061	1756	111	\$429.54
Census Tract 36, Allen County, Indiana	\$32,129	5493	2679	176	\$831.77
Census Tract 37, Allen County, Indiana	\$38,000	7153	1114	72	\$409.07
Census Tract 38, Allen County, Indiana	\$29,375	2362	1659	103	\$470.93
Census Tract 39.01, Allen County, Indiana	\$48,393	10970	1462	89	\$683.69
Census Tract 39.02, Allen County, Indiana	\$38,281	9761	1330	70	\$492.00
Census Tract 40, Allen County, Indiana	\$34,367	5693	1202	103	\$399.19
Census Tract 41.01, Allen County, Indiana	\$42,381	9370	930	58	\$380.88
Census Tract 41.03, Allen County, Indiana	\$46,181	10790	2618	170	\$1,168.33
Census Tract 43, Allen County, Indiana	\$20,972	3557	982	77	\$199.01
Census Tract 44, Allen County, Indiana	\$22,917	5001	1190	121	\$263.53
Census Tract 103.04, Allen County, Indiana	\$79,917	7519	2647	147	\$2,044.20
Census Tract 106.01, Allen County, Indiana	\$66,995	5068	1405	121	\$909.60
Census Tract 106.02, Allen County, Indiana	\$50,818	4666	1506	107	\$739.56
Census Tract 106.03, Allen County, Indiana	\$54,464	9350	718	40	\$377.89
Census Tract 106.04, Allen County, Indiana	\$27,839	4208	1142	96	\$307.22
Census Tract 107.05, Allen County, Indiana	\$57,933	8720	2200	116	\$1,231.63
Census Tract 107.06, Allen County, Indiana	\$60,000	3622	1860	93	\$1,078.44
Census Tract 107.07, Allen County, Indiana	\$68,078	10752	2349	120	\$1,545.33
Census Tract 108.03, Allen County, Indiana	\$60,217	6632	1996	77	\$1,161.48
Census Tract 108.04, Allen County, Indiana	\$53,377	5783	1764	63	\$909.88
Census Tract 108.07, Allen County, Indiana	\$53,456	3722	1762	92	\$910.19
Census Tract 108.08, Allen County, Indiana	\$78,945	7548	1929	84	\$1,471.59
Census Tract 108.09, Allen County, Indiana	\$50,741	8863	2094	126	\$1,026.75
Census Tract 108.11, Allen County, Indiana	\$65,383	15865	2165	175	\$1,367.90
Census Tract 108.12, Allen County, Indiana	\$65,011	4369	1779	75	\$1,117.62
Census Tract 108.13, Allen County, Indiana	\$56,169	9308	1683	97	\$913.51
Census Tract 108.15, Allen County, Indiana	\$75,659	6018	1811	99	\$1,324.07
Census Tract 108.16, Allen County, Indiana	\$78,568	7469	1907	94	\$1,447.86
Census Tract 108.17, Allen County, Indiana	\$57,819	9166	1520	72	\$849.27
Census Tract 108.19, Allen County, Indiana	\$40,745	7015	2308	116	\$908.74
Census Tract 108.21, Allen County, Indiana	\$36,954	7035	1986	122	\$709.20
Census Tract 113.02, Allen County, Indiana	\$33,571	9141	2052	186	\$665.69
Census Tract 113.03, Allen County, Indiana	\$36,071	16168	794	61	\$276.76
Census Tract 115.01, Allen County, Indiana	\$40,216	4884	1930	104	\$750.04
Census Tract 115.02, Allen County, Indiana	\$47,072	14760	1295	80	\$589.07
Census Tract 9800.01, Allen County, Indiana	\$12,500	2331	58	26	\$7.01
Census Tract 9800.02, Allen County, Indiana					\$0.00
Block Group 3, Census Tract 102.01, Allen County, Indli	\$71,397	40443	479	89	\$330.48
Block Group 4, Census Tract 102.01, Allen County, Indli	\$88,237	8531	463	85	\$394.79
Block Group 2, Census Tract 103.05, Allen County, Indli	\$118,897	14130	819	102	\$940.99
Block Group 4, Census Tract 103.05, Allen County, Indli	\$102,500	62381	562	95	\$556.66
Block Group 1, Census Tract 103.07, Allen County, Indli	\$91,842	16969	410	71	\$363.88
Block Group 2, Census Tract 103.07, Allen County, Indli	\$83,574	5962	1101	101	\$889.18
Block Group 1, Census Tract 103.08, Allen County, Indli	\$90,962	10291	1482	143	\$1,302.68
Block Group 1, Census Tract 113.04, Allen County, Indli	\$56,065	12146	901	116	\$488.14
Block Group 2, Census Tract 113.04, Allen County, Indli	\$11,748	1515	717	123	\$81.40
Block Group 2, Census Tract 116.07, Allen County, Indli	\$62,019	9882	587	94	\$351.80

Total, Service Area

103,483

\$48,039.49

US

\$57,652

Indiana

\$52,182

Allen County

\$51,091

S19

// Search / Tables / S1901

**INCOME IN THE PAST 12 MONTHS (IN 2017 INFLATION-ADJUSTED DOLLARS)**

Survey/Program: American Community Survey TableID: S1901 Product: 2017: ACS 1-Year Estimates Subject Tables

	Households		Families		Married
	Estimate	Margin of Error	Estimate	Margin of Error	Estimate
Total	43,687	+/-1,887	22,494	+/-1,538	
Less than \$10,000	8.2%	+/-2.0	6.3%	+/-2.8	
\$10,000 to \$14,999	8.1%	+/-2.0	5.7%	+/-2.5	
\$15,000 to \$24,999	18.3%	+/-3.2	14.4%	+/-4.0	
\$25,000 to \$34,999	13.9%	+/-2.8	9.1%	+/-2.8	
\$35,000 to \$49,999	15.2%	+/-2.4	16.5%	+/-3.3	
\$50,000 to \$74,999	18.4%	+/-2.9	24.9%	+/-4.5	
\$75,000 to \$99,999	11.2%	+/-2.1	14.1%	+/-3.2	
\$100,000 to \$149,999	5.0%	+/-1.6	6.4%	+/-2.3	
\$150,000 to \$199,999	1.1%	+/-0.5	1.7%	+/-1.0	
\$200,000 or more	0.6%	+/-0.4	0.8%	+/-0.7	
Median income (dollars)	35,881	+/-2,664	47,818	+/-5,812	62,411
Mean income (dollars)	45,005	+/-2,634	52,977	+/-3,926	
PERCENT ALLOCATED					
Household income in ...	29.8%	(X)	(X)	(X)	
Family income in the ...	(X)	(X)	30.7%	(X)	
Nonfamily income in t...	(X)	(X)	(X)	(X)	

 Send Feedback  
[cedsci.feedback@census.gov](mailto:cedsci.feedback@census.gov)

**Exhibit L-6: Full Control No Stormwater Costs**

Assumes a portion of projects are rate funded and does not include stormwater projects

City of Fort Wayne  
EPA CSO FINANCIAL CAPABILITY ASSESSMENT - PHASE 1 THE RESIDENTIAL INDICATOR

WORKSHEET 1: CALCULATION OF COST PER HOUSEHOLD  
(2017 \$ Value and FULL CONTROL SCENARIO)

See Section 1 of Appendix L

Description	Amount	EPA Line No.	Source
<b>Current and Projected Wastewater Treatment and Wet-Weather Control Costs:</b>			
Current WWT and Wet-Weather Control Costs:			
Annual O&M Expense - Sewer (excluding Depreciation)	\$26,404,190	100	From 2017 Source: Comparative Statement of Revenues, Expenses, and Changes in Net Position
Annual Debt Service (Principal & Interest)	43,839,865	101	Based on the average debt service for the 7 years (2019-2025). Note, it excludes stormwater bonds
Subtotal	70,244,055	102	Calculation
Projected WWT and Wet-Weather Control Costs:			
Annual Rate Funded Capital Projects	27,346,166		Calculated as an average of sewer capital improvements
Expected increase in O&M due to new assets (as a % of capital assets)	13,709,020		Calculated as a percentage of capital assets - See Capital Projects Schedules.
Annual Incremental O&M Expense without STORM	41,055,186	103	\$13,709,020 from Sewer.
Capital Cost of LTCP	\$827,167,360		Capital Projects Schedules
Capital Cost of Wastewater Improvement CIP	239,470,850		Capital Projects Schedules
Subtotal	1,066,638,210		
Less: Total Rate Funded Wastewater Improvements	(191,423,165)		Capital Projects Schedules
Less: Improvements Funded by Existing Bonds & Reimbursements	(154,794,141)		
Subtotal	720,420,904		
Plus: 2.00% Acquisition Costs (Wastewater)	14,408,418		See Assumptions
Projected Debt Service (Wastewater)	64,065,828		Assumed \$734,830,000 bond at 6.00% interest amortized over 20 Years. Assumed increments of \$5,000
Capital Cost of Stormwater Improvement CIP	Not Included		See Capital Projects Schedules
Less: Total Rate Funded Stormwater Improvements	Not Included		See Capital Projects Schedules
Less: Improvements Funded by Existing Bonds & Reimbursements	Not Included		
Subtotal	Not Included		
2.00% Acquisition Costs (Stormwater)	Not Included		See Assumptions
Projected Debt Service (Stormwater)	Not Included		Stormwater is not included in current calculation.
Total Projected Debt Service (Principal & Interest)	64,065,828	104	Calculation
Subtotal	105,121,014	105	Calculation
Total Current and Projected WWT and Wet-Weather Control Costs without STORM	\$175,365,069	106	Calculation
<b>Allocation of WWT and Wet-Weather Costs to Residential Customers:</b>			
Residential Flow as a Percentage of Total Flow	66.40%		Per Utility Analysis
Residential Share of Total WWT and Wet-Weather Control Costs	\$116,442,406	107	Calculation
<b>Determination of WWT and Wet-Weather Cost Per Household:</b>			
Total Number of Residential Accounts in Service Area	81,796	108	Per Utility Customer Records
Cost Per Household - Sewer. No stormwater included.	\$1,424	109	Calculation

See Section 2 of Appendix L

See Section 3 of Appendix L  
and Exhibit L-3 for Annual  
Costs and O&M Increase

See Section 3 of  
Appendix L and  
Exhibit L-3 for  
Capital Costs and  
Funding Breakdown

See Section 4 of Appendix L

See Section 5 of Appendix L

*Assumes a portion of projects are rate funded and does not include stormwater projects*

City of Fort Wayne  
EPA CSO FINANCIAL CAPABILITY ASSESSMENT - PHASE 1 THE RESIDENTIAL INDICATOR

WORKSHEET 2: CALCULATION OF THE RESIDENTIAL INDICATOR  
(2017 \$ Value and FULL CONTROL SCENARIO)

Description	Amount	EPA Line No.	Source
Adjusted Median Household Income Levels			
Using Weighted Average MHI:			
Census Year MHI	NA	201	Not Applicable
Adjustment Factor	NA	202	Not Applicable
Adjusted MHI	\$48,039	203	Source: 2017 American Community Survey Estimate
Annual WWT and Wet-Weather Control Cost Per Household (CPH) without STORM	\$1,424	204	Calculation
<b>Residential Indicator:</b> (CPH as % of MHI)	2.96%	205	Calculation
<b>Analysis of the Residential Indicator</b>	High		
<b>Financial Impact</b>	<b>Residential Indicator (CPH as % MHI)</b>		
Low	Less than 1.0 Percent of MHI		
Mid-Range	1.0-2.0 Percent of MHI		
High	Greater than 2.0 Percent of MHI		

See Section 6 of Appendix L

*Assumes a portion of projects are rate funded and does not include stormwater projects*

City of Fort Wayne  
EPA CSO FINANCIAL CAPABILITY ASSESSMENT - PHASE 1 THE RESIDENTIAL INDICATOR

WORKSHEET 2: CALCULATION OF THE RESIDENTIAL INDICATOR  
(2017 \$ Value and FULL CONTROL SCENARIO)

Description	Amount	EPA Line No.	Source
Adjusted Median Household Income Levels			
Using Weighted Average MHI:			
Census Year MHI	NA	201	Not Applicable
Adjustment Factor	NA	202	Not Applicable
Adjusted MHI	\$35,881	203	Source: 2017 American Community Survey Estimate
Annual WWT and Wet-Weather Control Cost Per Household (CPH) without STORM	\$1,424	204	Calculation
<b>Residential Indicator:</b> (CPH as % of MHI)	3.97%	205	Calculation
<b>Analysis of the Residential Indicator</b>	High		
<b>Financial Impact</b>	<b>Residential Indicator (CPH as % MHI)</b>		
Low	Less than 1.0 Percent of MHI		
Mid-Range	1.0-2.0 Percent of MHI		
High	Greater than 2.0 Percent of MHI		

See Section 6 of Appendix L

**Exhibit L-7: Full Control Includes Stormwater Costs**

Assumes a portion of projects are rate funded and includes stormwater projects

City of Fort Wayne  
EPA CSO FINANCIAL CAPABILITY ASSESSMENT - PHASE 1 THE RESIDENTIAL INDICATOR

WORKSHEET 1: CALCULATION OF COST PER HOUSEHOLD  
(2017 \$ Value and FULL CONTROL SCENARIO)

See Section 1 of Appendix L

Description	Amount	EPA Line No.	Source
<b>Current and Projected Wastewater Treatment and Wet-Weather Control Costs:</b>			
Current WWT and Wet-Weather Control Costs:			
Annual O&M Expense - Sewer and Storm (excluding Depreciation)	\$31,727,451	100	From 2017 Source: Comparative Statement of Revenues, Expenses, and Changes in Net Position
Annual Debt Service (Principal & Interest)	45,984,922	101	Based on the average debt service for the 7 years (2019-2025).
Subtotal	77,712,373	102	Calculation
<b>Projected WWT and Wet-Weather Control Costs:</b>			
Annual Rate Funded Capital Projects	34,586,396		Calculated as an average of sewer capital improvements + average of stormwater capital improvements
Expected increase in O&M due to new assets (as a % of capital assets)	14,093,597		Calculated as a percentage of capital assets - See Capital Projects Schedules. \$13,709,020 from Sewer and \$384,577 from Storm.
Annual Incremental O&M Expense with STORM	48,679,993	103	
Capital Cost of LTCP	\$827,167,360		Capital Projects Schedules
Capital Cost of Wastewater Improvement CIP	239,470,850		Capital Projects Schedules
Subtotal	1,066,638,210		
Less: Total Rate Funded Wastewater Improvements	(191,423,165)		Capital Projects Schedules
Less: Improvements Funded by Existing Bonds & Reimbursements	(154,794,141)		
Subtotal	720,420,904		
Plus: 2.00% Acquisition Costs (Wastewater)	14,408,418		
Projected Debt Service (Wastewater)	64,065,828		See Assumptions Assumed \$734,830,000 bond at 6.00% interest amortized over 20 Years. Assumed increments of \$5,000
Capital Cost of Stormwater Improvement CIP	67,160,863		See Capital Projects Schedules
Less: Total Rate Funded Stormwater Improvements	(50,681,610)		See Capital Projects Schedules
Less: Improvements Funded by Existing Bonds & Reimbursements	(16,479,253)		
Subtotal	0		
2.00% Acquisition Costs (StormWater)	0		
Projected Debt Service (StormWater)	0		See Assumptions Projects less allowances are assumed rate funded.
Total Projected Debt Service (Principal & Interest)	64,065,828	104	Calculation
Subtotal	112,745,821	105	Calculation
Total Current and Projected WWT and Wet-Weather Control Costs with STORM	\$190,458,194	106	Calculation
<b>Allocation of WWT and Wet-Weather Costs to Residential Customers:</b>			
Residential Flow as a Percentage of Total Flow	66.40%		Per Utility Analysis
Residential Share of Total WWT and Wet-Weather Control Costs	\$126,464,241	107	Calculation
<b>Determination of WWT and Wet-Weather Cost Per Household:</b>			
Total Number of Residential Accounts in Service Area	81,796	108	Per Utility Customer Records
Cost Per Household - Sewer and Storm	\$1,546	109	Calculation

See Section 2 of Appendix L

See Section 3 of Appendix L  
and Exhibit L-3 for Annual  
Costs and O&M Increase

See Section 3 of  
Appendix L and  
Exhibit L-3 for  
Capital Costs and  
Funding Breakdown

See Section 3 of  
Appendix L and  
Exhibit L-4 for  
Capital Costs and  
Funding Breakdown

See Section 4 of Appendix L

See Section 5 of Appendix L

*Assumes a portion of projects are rate funded and includes stormwater projects*

City of Fort Wayne  
EPA CSO FINANCIAL CAPABILITY ASSESSMENT - PHASE 1 THE RESIDENTIAL INDICATOR

WORKSHEET 2: CALCULATION OF THE RESIDENTIAL INDICATOR  
(2017 \$ Value and FULL CONTROL SCENARIO)

Description	Amount	EPA Line No.	Source
Adjusted Median Household Income Levels			
Using Weighted Average MHI: Census Year MHI	NA	201	Not Applicable
Adjustment Factor	NA	202	Not Applicable
Adjusted MHI	\$48,039	203	Source: 2017 American Community Survey Estimate
Annual WWT and Wet-Weather Control Cost Per Household (CPH) with STORM	\$1,546	204	Calculation
<b>Residential Indicator:</b> (CPH as % of MHI)	3.22%	205	Calculation
<b>Analysis of the Residential Indicator</b>	High		
<b>Financial Impact</b>	<b>Residential Indicator (CPH as % MHI)</b>		
Low	Less than 1.0 Percent of MHI		
Mid-Range	1.0-2.0 Percent of MHI		
High	Greater than 2.0 Percent of MHI		

See Section 6 of Appendix L

*Assumes a portion of projects are rate funded and includes stormwater projects*

City of Fort Wayne  
EPA CSO FINANCIAL CAPABILITY ASSESSMENT - PHASE 1 THE RESIDENTIAL INDICATOR

WORKSHEET 2: CALCULATION OF THE RESIDENTIAL INDICATOR  
(2017 \$ Value and FULL CONTROL SCENARIO)

Description	Amount	EPA Line No.	Source
Adjusted Median Household Income Levels			
Using Weighted Average MHI:			
Census Year MHI	NA	201	Not Applicable
Adjustment Factor	NA	202	Not Applicable
Adjusted MHI	\$35,881	203	Source: 2017 American Community Survey Estimate
Annual WWT and Wet-Weather Control Cost Per Household (CPH) with STORM	\$1,546	204	Calculation
<b>Residential Indicator:</b> (CPH as % of MHI)	4.31%	205	Calculation
<b>Analysis of the Residential Indicator</b>	High		
<b>Financial Impact</b>	<b>Residential Indicator (CPH as % MHI)</b>		
Low	Less than 1.0 Percent of MHI		
Mid-Range	1.0-2.0 Percent of MHI		
High	Greater than 2.0 Percent of MHI		

See Section 6 of Appendix L

**Exhibit L-8: Approved LTCP No Stormwater Costs**

*Assumes a portion of projects are rate funded and does not include stormwater projects*

City of Fort Wayne  
EPA CSO FINANCIAL CAPABILITY ASSESSMENT - PHASE 1 THE RESIDENTIAL INDICATOR

WORKSHEET 1: CALCULATION OF COST PER HOUSEHOLD  
(2017 \$ Value and APPROVED LTCP)

Description	Amount	EPA Line No.	Source
<b>Current and Projected Wastewater Treatment and Wet-Weather Control Costs:</b>			
Current WWT and Wet-Weather Control Costs:			
Annual O&M Expense - Sewer (excluding Depreciation)	\$26,404,190	100	From 2017 Source: Comparative Statement of Revenues, Expenses, and Changes in Net Position
Annual Debt Service (Principal & Interest)	43,839,865	101	Based on the average debt service for the 7 years (2019-2025). Note, it excludes stormwater bonds
Subtotal	70,244,055	102	Calculation
<b>Projected WWT and Wet-Weather Control Costs:</b>			
Annual Rate Funded Capital Projects	16,483,614		Calculated as an average of sewer capital improvements
Expected increase in O&M due to new assets (as a % of capital assets)	5,374,641		Calculated as a percentage of capital assets - See Capital Projects Schedules. \$5,374,641 from Sewer.
Annual Incremental O&M Expense without STORM	21,858,255	103	
Capital Cost of LTCP	\$241,724,068		Capital Projects Schedules
Capital Cost of Wastewater Improvement CIP	239,470,850		Capital Projects Schedules
Subtotal	481,194,918		
Less: Total Rate Funded Wastewater Improvements	(115,385,295)		Capital Projects Schedules
Less: Improvements Funded by Existing Bonds & Reimbursements	(154,794,141)		
Subtotal	211,015,482		
Plus: 2.00% Acquisition Costs (Wastewater)	4,220,310		See Assumptions
Projected Debt Service (Wastewater)	18,765,604		Assumed \$215,240,000 bond at 6.00% interest amortized over 20 Years. Assumed increments of \$5,000
Capital Cost of Stormwater Improvement CIP	Not Included		See Capital Projects Schedules
Less: Total Rate Funded Stormwater Improvements	Not Included		See Capital Projects Schedules
Less: Improvements Funded by Existing Bonds & Reimbursements	Not Included		
Subtotal	Not Included		
2.00% Acquisition Costs (Stormwater)	Not Included		See Assumptions
Projected Debt Service (Stormwater)	Not Included		Stormwater is not included in current calculation.
Total Projected Debt Service (Principal & Interest)	18,765,604	104	Calculation
Subtotal	40,623,859	105	Calculation
Total Current and Projected WWT and Wet-Weather Control Costs without STORM	\$110,867,914	106	Calculation
<b>Allocation of WWT and Wet-Weather Costs to Residential Customers:</b>			
Residential Flow as a Percentage of Total Flow	66.40%		Per Utility Analysis
Residential Share of Total WWT and Wet-Weather Control Costs	\$73,616,295	107	Calculation
<b>Determination of WWT and Wet-Weather Cost Per Household:</b>			
Total Number of Residential Accounts in Service Area	81,796	108	Per Utility Customer Records
Cost Per Household - Sewer. No stormwater included.	\$900	109	Calculation

See Section 1 of Appendix L

See Section 2 of Appendix L

See Section 3 of Appendix L  
and Exhibit L-2 for Annual  
Costs and O&M Increase

See Section 3 of  
Appendix L and  
Exhibit L-2 for  
Capital Costs and  
Funding Breakdown

See Section 4 of Appendix L

See Section 5 of Appendix L

*Assumes a portion of projects are rate funded and does not include stormwater projects*

City of Fort Wayne  
 EPA CSO FINANCIAL CAPABILITY ASSESSMENT - PHASE 1 THE RESIDENTIAL INDICATOR

WORKSHEET 2: CALCULATION OF THE RESIDENTIAL INDICATOR  
 (2017 \$ Value and APPROVED LTCP)

Description	Amount	EPA Line No.	Source
Adjusted Median Household Income Levels			
Using Weighted Average MHI:			
Census Year MHI	NA	201	Not Applicable
Adjustment Factor	NA	202	Not Applicable
Adjusted MHI	\$48,039	203	Source: 2017 American Community Survey Estimate
Annual WWT and Wet-Weather Control Cost Per Household (CPH) without STORM	\$900	204	Calculation
<b>Residential Indicator:</b> (CPH as % of MHI)	1.87%	205	Calculation
<b>Analysis of the Residential Indicator</b>	Mid-Range		
<b>Financial Impact</b>	<b>Residential Indicator (CPH as % MHI)</b>		
Low	Less than 1.0 Percent of MHI		
Mid-Range	1.0-2.0 Percent of MHI		
High	Greater than 2.0 Percent of MHI		

See Section 6 of Appendix L

*Assumes a portion of projects are rate funded and does not include stormwater projects*

City of Fort Wayne  
 EPA CSO FINANCIAL CAPABILITY ASSESSMENT - PHASE 1 THE RESIDENTIAL INDICATOR

WORKSHEET 2: CALCULATION OF THE RESIDENTIAL INDICATOR  
 (2017 \$ Value and APPROVED LTCP)

Description	Amount	EPA Line No.	Source
Adjusted Median Household Income Levels			
Using Weighted Average MHI: Census Year MHI	NA	201	Not Applicable
Adjustment Factor	NA	202	Not Applicable
Adjusted MHI	\$35,881	203	Source: 2017 American Community Survey Estimate
Annual WWT and Wet-Weather Control Cost Per Household (CPH) without STORM	\$900	204	Calculation
<b>Residential Indicator:</b> (CPH as % of MHI)	2.51%	205	Calculation
Analysis of the Residential Indicator	High		
<b>Financial Impact</b>	<b>Residential Indicator (CPH as % MHI)</b>		
Low	Less than 1.0 Percent of MHI		
Mid-Range	1.0-2.0 Percent of MHI		
High	Greater than 2.0 Percent of MHI		

See Section 6 of Appendix L

**Exhibit L-9: Approved LTCP Includes Stormwater Costs**

City of Fort Wayne  
EPA CSO FINANCIAL CAPABILITY ASSESSMENT - PHASE 1 THE RESIDENTIAL INDICATOR

*Assumes a portion of projects are rate funded and includes stormwater projects*

WORKSHEET 1: CALCULATION OF COST PER HOUSEHOLD  
(2017 \$ Value and APPROVED LTCP)

Description	Amount	EPA Line No.	Source
<b>Current and Projected Wastewater Treatment and Wet-Weather Control Costs:</b>			
Current WWT and Wet-Weather Control Costs:			
Annual O&M Expense - Sewer and Storm (excluding Depreciation)	\$31,727,451	100	From 2017 Source: Comparative Statement of Revenues, Expenses, and Changes in Net Position
Annual Debt Service (Principal & Interest)	45,984,922	101	Based on the average debt service for the 7 years (2019-2025).
Subtotal	77,712,373	102	Calculation
Projected WWT and Wet-Weather Control Costs:			
Annual Rate Funded Capital Projects	23,723,844		Calculated as an average of sewer capital improvements + average of stormwater capital improvements
Expected increase in O&M due to new assets (as a % of capital assets)	5,759,218		Calculated as a percentage of capital assets - See Capital Projects Schedules.
Annual Incremental O&M Expense with STORM	29,483,062	103	\$5,374,641 from Sewer and \$384,577 from Storm.
Capital Cost of LTCP	\$241,724,068		Capital Projects Schedules
Capital Cost of Wastewater Improvement CIP	239,470,850		Capital Projects Schedules
Subtotal	481,194,918		
Less: Total Rate Funded Wastewater Improvements	(115,385,295)		Capital Projects Schedules
Less: Improvements Funded by Existing Bonds & Reimbursements	(154,794,141)		
Subtotal	211,015,482		
Plus: 2.00% Acquisition Costs (Wastewater)	4,220,310		See Assumptions
Projected Debt Service (Wastewater)	18,765,604		Assumed \$215,240,000 bond at 6.00% interest amortized over 20 Years. Assumed increments of \$5,000
Capital Cost of Stormwater Improvement CIP	67,160,863		See Capital Projects Schedules
Less: Total Rate Funded Stormwater Improvements	(50,681,610)		See Capital Projects Schedules
Less: Improvements Funded by Existing Bonds & Reimbursements	(16,479,253)		
Subtotal	0		
2.00% Acquisition Costs (Stormwater)	0		See Assumptions
Projected Debt Service (Stormwater)	0		Projects less allowances are assumed rate funded.
Total Projected Debt Service (Principal & Interest)	18,765,604	104	Calculation
Subtotal	48,248,666	105	Calculation
Total Current and Projected WWT and Wet-Weather Control Costs with STORM	\$125,961,039	106	Calculation
<b>Allocation of WWT and Wet-Weather Costs to Residential Customers:</b>			
Residential Flow as a Percentage of Total Flow	66.40%		Per Utility Analysis
Residential Share of Total WWT and Wet-Weather Control Costs	\$83,638,130	107	Calculation
<b>Determination of WWT and Wet-Weather Cost Per Household:</b>			
Total Number of Residential Accounts in Service Area	81,796	108	Per Utility Customer Records
Cost Per Household - Sewer and Storm	\$1,023	109	Calculation

See Section 1 of Appendix L

See Section 2 of Appendix L

See Section 3 of Appendix L and Exhibit L-2 for Annual Costs and O&M Increase

See Section 3 of Appendix L and Exhibit L-2 for Capital Costs and Funding Breakdown

See Section 3 of Appendix L and Exhibit L-4 for Capital Costs and Funding Breakdown

See Section 4 of Appendix L

See Section 5 of Appendix L

*Assumes a portion of projects are rate funded and includes stormwater projects*

City of Fort Wayne  
 EPA CSO FINANCIAL CAPABILITY ASSESSMENT - PHASE 1 THE RESIDENTIAL INDICATOR

WORKSHEET 2: CALCULATION OF THE RESIDENTIAL INDICATOR  
 (2017 \$ Value and APPROVED LTCP)

Description	Amount	EPA Line No.	Source
Adjusted Median Household Income Levels			
Using Weighted Average MHI:			
Census Year MHI	NA	201	Not Applicable
Adjustment Factor	NA	202	Not Applicable
Adjusted MHI	\$48,039	203	Source: 2017 American Community Survey Estimate
Annual WWT and Wet-Weather Control Cost Per Household (CPH) with STORM	\$1,023	204	Calculation
<b>Residential Indicator:</b> (CPH as % of MHI)	2.13%	205	Calculation
<b>Analysis of the Residential Indicator</b>	High		
<b>Financial Impact</b>	<b>Residential Indicator (CPH as % MHI)</b>		
Low	Less than 1.0 Percent of MHI		
Mid-Range	1.0-2.0 Percent of MHI		
High	Greater than 2.0 Percent of MHI		

See Section 6 of Appendix L

*Assumes a portion of projects are rate funded and includes stormwater projects*

City of Fort Wayne  
EPA CSO FINANCIAL CAPABILITY ASSESSMENT - PHASE 1 THE RESIDENTIAL INDICATOR

WORKSHEET 2: CALCULATION OF THE RESIDENTIAL INDICATOR  
(2017 \$ Value and APPROVED LTCP)

Description	Amount	EPA Line No.	Source
Adjusted Median Household Income Levels			
Using Weighted Average MHI:			
Census Year MHI	NA	201	Not Applicable
Adjustment Factor	NA	202	Not Applicable
Adjusted MHI	\$35,881	203	Source: 2017 American Community Survey Estimate
Annual WWT and Wet-Weather Control Cost Per Household (CPH) with STORM	\$1,023	204	Calculation
<b>Residential Indicator:</b> (CPH as % of MHI)	2.85%	205	Calculation
<b>Analysis of the Residential Indicator</b>	High		
<b>Financial Impact</b>	<b>Residential Indicator (CPH as % MHI)</b>		
Low	Less than 1.0 Percent of MHI		
Mid-Range	1.0-2.0 Percent of MHI		
High	Greater than 2.0 Percent of MHI		

See Section 6 of Appendix L

## **APPENDIX M: Precision of Cost Estimating for CSO Control Measures**

Preliminary cost estimates were prepared for various CSO control measures as part of the LTCP development effort to serve as a selection criterion among prospective alternative control measures. For more detailed information on the cost estimating methodology, *see* Attachment 1 to the LTCP titled, “Cost Estimating Methodology.” The primary method for cost-estimating was the use of parametric models, developed from a series of recent planning-level cost estimating analyses conducted in the Midwest along with USEPA and industry references.

The Association for the Advancement of Cost Engineering (AACE) International has developed a Cost Estimate Classification System, which is summarized as follows:

*“The Cost Estimate Classification System provides guidelines for applying the general principles of estimate classification to asset project cost estimates. Asset project cost estimates typically involve estimates for capital investment and exclude operating and life-cycle evaluations. The Cost Estimate Classification System maps the phases and stages of asset cost estimating together with a generic maturity and quality matrix that can be applied across a wide variety of industries.”*

AACE’s Cost Estimate Classification System is shown below. Given the purpose and characteristics of the preliminary cost estimates developed for the LTCP, the City’s cost estimates fall in AACE Class 4. The most accurate estimates in this Class are expected to range from approximately -15% to +20%, while some estimates in this Class could range from approximately -30% to +50%. These accuracy ranges are analogous to degrees of uncertainty in the City’s cost estimates.

### AACE Cost Estimate Classification System

ESTIMATE CLASS	Primary Characteristic	Secondary Characteristic			
	LEVEL OF PROJECT DEFINITION Expressed as % of complete definition	END USAGE Typical purpose of estimate	METHODOLOGY Typical estimating method	EXPECTED ACCURACY RANGE Typical variation in low and high ranges [a]	PREPARATION EFFORT Typical degree of effort relative to least cost index of 1 [b]
Class 5	0% to 2%	Concept Screening	Capacity Factored, Parametric Models, Judgment, or Analogy	L: -20% to -50% H: +30% to +100%	1
Class 4	1% to 15%	Study or Feasibility	Equipment Factored or Parametric Models	L: -15% to -30% H: +20% to +50%	2 to 4
Class 3	10% to 40%	Budget, Authorization, or Control	Semi-Detailed Unit Costs with Assembly Level Line Items	L: -10% to -20% H: +10% to +30%	3 to 10
Class 2	30% to 70%	Control or Bid/Tender	Detailed Unit Cost with Forced Detailed Take-Off	L: -5% to -15% H: +5% to +20%	4 to 20
Class 1	50% to 100%	Check Estimate or Bid/Tender	Detailed Unit Cost with Detailed Take-Off	L: -3% to -10% H: +3% to +15%	5 to 100

Cost Estimate Classification System  
 (from AACE International Recommended Practices and Standards,

**APPENDIX N-1: Public Participation Meetings February 17, 2010**

## City of Fort Wayne Use Attainability Analysis


February 17, 2010  
Brandi Wallace  
Justin Brugger  
Todd Trinkle (IDEM)

## Presentation Outline

- Water Quality Impacts of CSO Overflows
- Reducing Overflows
  - Long-Term Control Plan (LTCP)
  - Benefits of LTCP
- Request for Recreational Use Change in Water Quality Standards
- Basis for Use Attainability Analysis
- Next Steps




## Why Our Combined Sewers Overflow



## We Are Not Alone!

- Nationwide problem, especially in Midwest and Northeast



## Where Sewers Overflow


- Maumee
- St. Joseph
- St. Mary's
- Spy Run Creek
- Baldwin Ditch
- Other tributaries



## Water Quality Problems

- Maumee River, St. Joseph River, St. Mary's River impaired by bacteria, according to IDEM
- On average, waterways exceed *E. coli* standards 85 days per year
- Many sources of waterborne bacteria: Combined sewer overflows, failing septic systems, urban stormwater, agricultural runoff and, rarely, overflows from sanitary sewers





### Plan (LTCP) Overview



Program Element	Cost (millions)
Combined Sewer Capacity (partial sewer separation)	\$68.3
Interceptor sewers	\$72.4
Satellite storage/treatment	\$34.8
Combined sewer overflow pond storage improvements	\$53.9
Treatment plant improvements	\$10
<b>Total Cost</b>	<b>\$239.4</b>

(All cost estimates based on 2005 dollar value)

### Benefits of City's Plan

- Reduced odors, untreated sewage and trash in our rivers and streams
- Reduces annual sewer overflow volume by 91 percent
- Reduces overflow frequency from 71 times in a typical year to:
  - 1 storm per year causing overflows to St. Joseph River\*
  - 4 storms per year causing overflows to St. Mary's and Maumee rivers\*
- Reduced bacteria in our waterways

\*Predictions based on a year with average rainfall



- Controls go beyond the point of diminishing returns from a cost-effectiveness perspective.
- Even if all CSOs were eliminated, Fort Wayne's receiving streams will not appear or be pristine. (Clay soils result in rivers appearing murky).
- Stormwater from the City and surrounding area will still run into waterways carrying pollutants, including bacteria, and sediment.