

Area Source Existing, Non-Emergency Use, SI 2-Stroke Lean Burn Stationary Engines (2SLB)
(not in remote areas operating more than 24 hours per year)

Requirements	40 CFR 63 Subpart ZZZZ
Change oil and filter every 4320 hours of operation or annually. An oil analysis program may be used instead of the prescribed oil change frequency.	Table 2d to Subpart ZZZZ of Part 63
Inspect spark plugs every 4320 hours of operation or annually and replace as necessary.	Table 2d to Subpart ZZZZ of Part 63
Inspect all hoses and belts every 4320 hours of operation or annually and replace as necessary.	Table 2d to Subpart ZZZZ of Part 63
Operate and maintain the engine per the manufacturer's instructions or owner developed maintenance plan.	§ 63.6625
Keep records of maintenance for five (5) years.	§ 63.6660
Compliance date of October 19, 2013.	§ 63.6595