



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

100 N. Senate Avenue • Indianapolis, IN 46204
(800) 451-6027 • (317) 232-8603 • Fax (317) 233-6647 • www.idem.in.gov

Mike Braun
Governor

Clint Woods
Commissioner

PUBLIC NOTICE: 6/19/2026

DATE COMMENTS DUE: 7/19/2026

DATE OF NOTICE: 6/19/2026

The Indiana Department of Environmental Management (IDEM) has received an application for a construction permit from WAKARUSA WATER WORKS, public water system 5220029, this project is described as Pre-filtration Chlorination Addition.

Pre-filtration chlorination is being added to the existing system. This change includes a new day tank and modifications to the plumbing within the chemical room. This is the only change within this permit application. This change is being implemented to provide additional treatment options and functionality of oxidizing iron such that the pressure filters can most effectively remove iron, as well as providing backup when the induced draft aerator is offline. This change is being made per recommendations from the aerator/filter equipment manufacturer Kurita/Tonka Water. The chemical applied for chlorination will be sodium hypochlorite, 12.5%, which is already being applied at the end of the treatment process to disinfect finished water and fulfill chlorine residual requirements.

If approved the permit will become effective on the date of issuance.

Indiana Department of Environmental Management
Office of Water Quality - Drinking Water Branch
Public Water System Permit Section
100 North Senate Avenue
Indianapolis, IN 46206-2273

Email to: dwpermits@idem.in.gov

All comments must be postmarked no later than the date above to be considered in the formulation of the final determination. All comments will be considered by IDEM when we make a decision to issue or deny the permit application. Comments that are most likely to affect the decision are those based on the rules and laws governing this permitting process (327 IAC 8-3). The permit, if issued, will be available through IDEM's virtual file cabinet. Any questions concerning this project should be directed to the Construction Permits Section of the Drinking Water Branch, Office of Water Quality, IDEM at 317-234-7425.

Visit on.in.gov/survey or scan the QR code to provide feedback.

We appreciate your input!

