



Clinton Laboratories

Energy Savings through Capital Improvements and Procedural Changes

*2017 Pollution Prevention
Conference
and
Trade Show*

Elanco

Energy Savings through Capital Improvements and Procedural Changes

➤ **Site should perform an energy assessment**

➤ **Capital Improvements**


- Variable Frequency Drives on Well Pump Motors
- Optimized Operation of Chilled Water Systems in Free Cooling
- Replaced Process Air Compressors and Aftercoolers

➤ **Procedural Changes**

- Shutting off steam to evaporators when process is off-line greater than eight (8) hours


Variable Frequency Drives on Well Pump Motors

- **Before Project:** Well flow manually throttled with discharge valves
- **After Project:** VFD controls pump speed to maintain reservoir levels




Variable Frequency Drives on Well Pump Motors

- **After Project:** Wells run more efficiently due to Affinity Law
- Reducing speed by 20% requires only 50% of the power*




Optimized Operation of Chilled Water Systems in Free Cooling



- **Before Project:** 4+ hours to manually position valves for free cooling
- **After Project:** <20 minutes with automated valves & updated tower process control

Optimized Operation of Chilled Water Systems in Free Cooling (continued)



- **After Project:** Typical drop in site load, from approximately 36,000 kw to 31,000 kw

Replaced Process Air Compressors and Aftercoolers



- **Before Project:** Operated 4 of 5 installed Turbonetic Air Compressors (2000HP motors) to meet the desired airflow rate to fermentation tanks
- **After Project:** Now operate 3 of 5 new HSI Centrifugal Blowers to meet system requirements
(<http://www.hsiblowsers.com/products.html>)

Replaced Process Air Compressors and Aftercoolers

- Capital Project Cost:
\$2.5 million
- Former power requirement:
57,000 MW-hr/year
(\$3.5 million/year)
- Current power requirement:
50,000 MW-hr/year
(\$3.0 million/year)
- \$0.5 million/year savings, plus an additional \$0.13 million/year savings in cooling (chilled water), since the air being discharged from the new blowers is cooler



Shutting off steam to evaporators when process is off-line greater than eight (8) hours

- **Before SOP Revision:** Steam on Evaporator Jets 24x7x365
- **After SOP Revision:** Steam shut off when process is expected to be down >8 hours (with freeze protection taken into account).
- **40.9 MM lbs steam saved**
 - ✓ 4.9 million gallons water saved
 - ✓ Treatment of waste water avoided
- **58,000 MMBTU/Year savings**
- **Total Emissions Reduction:**
6,000 US Tons CO₂e/Year



Energy Savings through Capital Improvements and Procedural Changes

➤ Summary:

- Energy assessment will provide opportunities
- Engineering First Principles and modeling can provide insights to potential savings
- Consider both capital improvements and procedure/methods changes

➤ Final Point:

- **Not just about saving energy and the environment – this is good business!**