



September 30, 2020

BY ELECTRONIC MAIL ONLY

Ms. Jean Boling
Senior Environmental Engineer
Indiana Department of Environmental Management
Office of Air Quality, Room 1003
100 North Senate Avenue
Indianapolis, IN 46204-2251
jboling@idem.IN.gov

Re: ArcelorMittal USA LLC – Indiana Harbor West Facility (-00318)
Regional Haze State Implementation Plan Second Planning Period
Four-Factor Analysis Report

Dear Ms. Boling,

ArcelorMittal USA LLC is timely submitting the enclosed Four-Factor Analysis Report for the Indiana Harbor West facility in response to the Indiana Department of Environmental Management's (IDEM's) June 18, 2020 Request for Information (RFI) Letter in support of the State's work on the second planning period state implementation plan (SIP) revisions for Regional Haze (RH).

If there are any questions, please contact me at (219) 399-1091.

Sincerely,

Tom Maicher
ArcelorMittal USA LLC – Indiana Harbor West

Enclosure

cc: Mark Derf, IDEM Office of Air Quality
Scott Deloney, IDEM Office of Air Quality
Rich Zavoda, ArcelorMittal USA

Regional Haze Four-Factor Analysis with Visibility Benefits Evaluation for NO_x and SO₂ Emissions Control

- *Basic Oxygen Furnaces*
- *Boiler House - #8 Boiler (S8G)*
- *H-3 and H-4 Blast Furnaces*

Prepared for
ArcelorMittal USA, LLC
Indiana Harbor West Facility

September 30, 2020

Regional Haze Four-Factor Analysis with Visibility Benefits Evaluation for NO_x and SO₂ Emissions Control

September 30, 2020

Contents

1	Executive Summary	1
2	Introduction	4
2.1	Four-Factor Analysis Regulatory Background	4
2.1.1	Four-Factor Analysis Overview	5
2.1.1.1	Identifying Available Emission Control Measures	5
2.1.1.2	Factor 1 – Cost of Compliance	6
2.1.1.3	Factor 2 – Time Necessary for Compliance	8
2.1.1.4	Factor 3 – Energy and Non-Air Quality Environmental Impacts of Compliance	8
2.1.1.5	Factor 4 – Remaining Useful Life of the Source	8
2.1.1.6	Visibility Benefits	8
2.2	Affected Emission Unit Description and Existing Emission Control Measures	9
2.2.1	Basic Oxygen Furnaces	9
2.2.2	Boiler House - #8 Boiler (S8G)	9
2.2.3	H-3 and H-4 Blast Furnaces	10
2.3	Facility-wide NO _x and SO ₂ Emission Trends	11
3	Basic Oxygen Furnaces	13
3.1	Four-Factor Analysis – NO _x	13
3.1.1	NO _x Emission Control Measures	13
3.1.2	Baseline Emission Rates	13
3.1.3	Factor 1 – Cost of Compliance	13
3.1.4	Factor 2 – Time Necessary for Compliance	13
3.1.5	Factor 3 – Energy and Non-Air Quality Environmental Impacts of Compliance	13
3.1.6	Factor 4 – Remaining Useful Life of the Source	14
3.1.7	Visibility Benefits	14
3.1.8	Proposed NO _x Emission Control Measures	14
4	Boiler House - #8 Boiler (S8G)	15
4.1	Four-Factor Analysis - NO _x	15
4.1.1	NO _x Emission Control Measures	15

4.1.2	Baseline Emission Rates	16
4.1.3	Factor 1 – Cost of Compliance	16
4.1.4	Factor 2 – Time Necessary for Compliance.....	16
4.1.5	Factor 3 – Energy and Non-Air Quality Environmental Impacts of Compliance	16
4.1.6	Factor 4 – Remaining Useful Life of the Source	16
4.1.7	Visibility Benefits.....	17
4.1.8	Proposed NO _x Emission Control Measures	17
4.2	Four-Factor Analysis - SO ₂	17
4.2.1	SO ₂ Emission Control Measures	17
4.2.2	Baseline Emission Rates	17
4.2.3	Factor 1 – Cost of Compliance	17
4.2.4	Factor 2 – Time Necessary for Compliance.....	17
4.2.5	Factor 3 – Energy and Non-Air Quality Environmental Impacts of Compliance	18
4.2.6	Factor 4 – Remaining Useful Life of the Source	18
4.2.7	Visibility Benefits.....	18
4.2.8	Proposed SO ₂ Emission Control Measures	18
5	H-3 and H-4 Blast Furnaces.....	19
5.1	Four-Factor Analysis - NO _x	19
5.1.1	NO _x Emission Control Measures	19
5.1.1.1	H-3 and H-4 Blast Furnace Stoves	19
5.1.1.2	H-3 and H-4 Blast Furnace Casthouses	20
5.1.1.3	H-3 and H-4 Blast Furnace Flares	20
5.1.2	Baseline Emission Rates	21
5.1.3	Factor 1 – Cost of Compliance	21
5.1.4	Factor 2 – Time Necessary for Compliance.....	21
5.1.5	Factor 3 – Energy and Non-Air Quality Environmental Impacts of Compliance	21
5.1.6	Factor 4 – Remaining Useful Life of the Source	21
5.1.7	Visibility Benefits.....	21
5.1.8	Proposed NO _x Emission Control Measures	21
5.2	Four-Factor Analysis – SO ₂	22
5.2.1	SO ₂ Emission Control Measures	22
5.2.1.1	H-3 and H-4 Blast Furnace Stoves.....	22
5.2.1.2	H-3 and H-4 Blast Furnace Casthouses	22
5.2.1.3	H-3 and H-4 Blast Furnace Flares	22

5.2.2	Baseline Emission Rates	23
5.2.3	Factor 1 – Cost of Compliance	23
5.2.4	Factor 2 – Time Necessary for Compliance.....	23
5.2.5	Factor 3 – Energy and Non-Air Quality Environmental Impacts of Compliance	23
5.2.6	Factor 4 – Remaining Useful Life of the Source	23
5.2.7	Visibility Benefits.....	23
5.2.8	Proposed SO ₂ Emission Control Measures.....	24
6	Visibility Impacts Review.....	25
6.1	Visibility Conditions in the Closest Class I Areas.....	26
6.2	Emission Trend Analyses.....	30
6.3	Visibility Impacts in the Closest Class I Areas.....	34
6.3.1	BART Modeling	35
6.3.2	Mammoth Cave and Mingo Trajectory Analysis	37
6.3.3	Seney and Isle Royale Back Trajectory Analysis	38
6.3.4	Visibility Impacts Conclusion	41
7	Conclusion	42

List of Tables

Table 1-1	Summary of NO _x Four-Factor Analyses with Visibility Benefits Evaluations	3
Table 1-2	Summary of SO ₂ Four-Factor Analyses with Visibility Benefits Evaluations	3
Table 2-1	Identified Emission Units.....	4
Table 6-1	Planned Emission Reduction Projects (IL, IN, MI, MN, WI) through 2028	33
Table 6-2	Sulfate and Nitrate Culpability at Mingo National Wildlife Refuge.....	38

List of Figures

Figure 2-1	Facility-wide NO _x and SO ₂ Emissions from 2005 to 2018	12
Figure 6-1	Location of Class I Areas in Relation to the Indiana Harbor West Facility	25
Figure 6-2	Visibility Trend versus URP – Mammoth Cave National Park (499 km).....	27
Figure 6-3	Visibility Trend versus URP – Mingo National Wildlife Refuge (561 km).....	28
Figure 6-4	Visibility Trend versus URP – Isle Royale National Park (699 km).....	29
Figure 6-5	Visibility Trend versus URP – Seney National Wildlife Refuge (513 km).....	30
Figure 6-6	National NO _x and SO ₂ Emission Trends.....	31
Figure 6-7	Upper Midwest NO _x and SO ₂ Emission Trends.....	32
Figure 6-8	Seney National Wildlife Refuge: Most Impaired Trajectories for 2017-2018 from Reverse Trajectory Analysis.....	40

Figure 6–9	Isle Royale National Park: Most Impaired Trajectories for 2017-2018 from Reverse Trajectory Analysis.....	41
------------	---	----

List of Appendices

Appendix A	RBLC Search Summary for Pertinent Emission Units at Similar Sources
Appendix B	Air Permit Summary for II&S Mills
Appendix C	2008 ArcelorMittal Burns Harbor BART Modeling

Abbreviations

2010 Nucor BACT	Nucor Steel Louisiana Best Available Control Technology Analyses, March 1, 2010
2019 RH SIP Guidance	EPA Guidance on Regional Haze State Implementation Plans for the Second Implementation Period, August 20, 2019
AOI	Area of Influence
BACT	best available control technology
Barr	Barr Engineering
BART	best available retrofit technology
BOF	Basic Oxygen Furnace
CENRAP	Central Regional Air Planning Association
CenSARA	Central States Air Resources Agencies
dv	deciview
EPA	U.S. Environmental Protection Agency
EPA Control Cost Manual	EPA Air Pollution Control Cost Manual
FLAG	Federal Land Managers' Air Quality Related Values Work Group
IDEM	Indiana Department of Environmental Management
IHW	ArcelorMittal Indiana Harbor West
II&S mills	Integrated iron and steel mills
IMPROVE	Interagency Monitoring of Protected Visual Environments
Isle Royale	Isle Royale National Park
km	kilometer
LADCO	Lake Michigan Air Directors Consortium
LAER	lowest achievable emission rate
LNB	Low-NO _x Burners
Mammoth Cave	Mammoth Cave National Park
Mingo	Mingo National Wildlife Refuge
NO _x	nitrogen oxides
O&M	operating and maintenance
PM	particulate matter
PSAT	Particulate Matter Source Apportionment Technology
PSD	Prevention of Significant Deterioration
RACT	reasonably available control technology
RBLC	RACT/BACT/LAER Clearinghouse
RFI	Request for Information
RHR	Regional Haze Rule
SCR	Selective Catalytic Reduction
Seney	Seney National Wildlife Refuge
SIP	State Implementation Plan
SO ₂	sulfur dioxide

tpy	tons per year
ULNB	Ultra Low-NO _x Burners
URP	Universal Rate of Progress
VISTAS	Visibility Improvement State and Tribal Association of the Southeast

1 Executive Summary

In accordance with the Indiana Department of Environmental Management's (IDEM's) June 18, 2020 Request for Information (RFI) Letter,¹ ArcelorMittal Indiana Harbor West (IHW) evaluated potential emission control measures for nitrogen oxides (NO_x) and sulfur dioxide (SO₂) for the Boiler House - #8 Boiler (S8G), H-3 and H-4 Blast Furnaces, and the Basic Oxygen Furnaces (BOF) (NO_x only).² This report addresses the four statutory factors, laid out in 40 CFR 51.308(f)(2)(i), for the reasonable set of emission control measures pursuant to the final U.S. Environmental Protection Agency (EPA) Regional Haze Rule (RHR) State Implementation Plan (SIP) guidance³ that was issued on August 20, 2019 (2019 RH SIP Guidance). The four statutory factors are as follows:

1. Cost of compliance
2. Time necessary for compliance
3. Energy and non-air quality environmental impacts of compliance
4. Remaining useful life of the source

This report, commonly referred to as a four-factor analysis, describes the background and analysis for identifying the reasonable set of emission control measures and conducting the review of the four statutory factors. Additionally, this analysis evaluates the potential for visibility benefits at the associated Class I areas from the installation of additional emission control measures, consistent with the 2019 RH SIP Guidance. However, data and information from the Lake Michigan Air Directors Consortium (LADCO) necessary to complete CAMx air quality modeling as part of the visibility benefits analysis was unavailable at the time of this report submission. IHW reserves the right to amend and/or supplement this report and analysis once CAMx modeling has been completed.

The four-factor analyses with visibility benefits evaluations for the Basic Oxygen Furnaces (NO_x, Section 3.1), the Boiler House - #8 Boiler (S8G) (NO_x, Section 4.1; SO₂, Section 4.2), and the H-3 and H-4 Blast Furnace (NO_x, Section 5.1; SO₂, Section 5.2), concluded that:

- There is no reasonable set of NO_x and SO₂ emission control measures beyond what is currently installed and operated for these emission units. The reasonable set of additional NO_x and SO₂ emission control measures is not technically feasible for these emission units.

¹ June 18, 2020 letter from Mathew Stuckey of IDEM to Thomas Maicher of ArcelorMittal USA, LLC.

² IDEM's RFI included 84" Hot Strip Mill Boilers 1, 2, and 3. The 84" Hot Strip Mill is permanently shut down and is being demolished. Therefore, it is not appropriate to review these units as part of this analysis.

³ US EPA, "Guidance on Regional Haze State Implementation Plans for the Second Implementation Period," August 20, 2019, EPA-457/B-19-003.

- Therefore, the existing NO_x and SO₂ emission performance for these emission units are sufficient for the IDEM's regional haze reasonable progress goal.

The NO_x and SO₂ four-factor analyses with visibility benefits evaluations conclusions are summarized in Table 1-1 and Table 1-2, respectively.

As discussed above, in addition to the four statutory factors, this report also considers the current visibility and the potential visibility benefits to applicable Class I areas (the closest of which is nearly 500 km away from IHW) from installing additional emission control measures on the associated sources at the facility. An analysis of current visibility conditions was completed for Mammoth Cave National Park (Mammoth Cave, 499 km), Mingo National Wildlife Refuge (Mingo, 561 km), Seney National Wildlife Refuge (Seney, 513 km) and Isle Royale National Park (Isle Royale, 699 km). The analysis compared the current visibility conditions to the natural visibility goal, the 2028 Universal Rate of Progress (URP), and to the possible reasonable progress goals for the SIP. As shown in Section 6.1, the 5-year average visibility impairment on the most impaired days is already below the 2028 URP (Mammoth Cave (499 km), Seney (513 km) and Isle Royale (699 km)), or trending towards and expected to attainment to the 2028 URP (Mingo (561 km)) without additional emission reductions. Furthermore, there are other emission reductions that are already planned to occur prior to 2028 which will continue to improve the visibility in these Class I areas. For example, several electrical utilities intend to transition away from coal-fired generation to a more diverse generation mix that includes a combination of wind, solar, natural gas and storage. Thus, it is not necessary for IHW to install additional emission control measures for reasonable progress to occur at these distant Class I areas.

Moreover, a visibility impacts analysis was conducted for these same Class I areas (Mammoth Cave (499 km), Mingo (561 km), Seney (513 km) and Isle Royale (699 km)) to determine how emissions from IHW could impact visibility in Class I areas on the 20% most impaired days. As shown in Section 6.3.1, the previous CALPUFF modeling conducted demonstrates that the facility does not contribute to visibility impairment; this analysis is still relevant and appropriate based on the overly conservative nature of the analysis. Likewise, the recent visibility impacts screening analyses conducted by two regional planning organizations demonstrated that no additional control measures analyses were necessary for IHW because the visibility impacts were less than the screening thresholds which were applied (see Section 6.3.2). Additionally, a back-trajectory analysis was conducted for Seney (513 km) and Isle Royale (699 km) that demonstrates emission reductions at IHW are unlikely to improve visibility on the most impaired days at these Class I areas (see Section 6.3.3). Finally, further analysis through CAMx modeling that is underway is anticipated to confirm that IHW does not have a perceptible⁴ visibility impact on these Class I areas. IHW reserves the right to amend and/or supplement this report and visibility analysis once CAMx modeling has been completed.

⁴ Federal Register Vol. 70, No. 128, 07/06/2005, Page 39119. (<https://www.federalregister.gov/documents/2005/07/06/05-12526/regional-haze-regulations-and-guidelines-for-best-available-retrofit-technology-bart-determinations>)

Table 1-1 Summary of NO_x Four-Factor Analyses with Visibility Benefits Evaluations

List of Emission Control Measure	Factor #1 – Cost of Compliance	Factor #2 – Time Necessary for Compliance	Factor #3 – Energy and Non-Air Quality Environmental Impacts of Compliance	Factor #4 – Remaining Useful Life of the Source	Visibility Benefits	Does this Analysis Support the Installation of this Emission Control Measure?
Basic Oxygen Furnaces						
No reasonable set of NO _x emission control measures beyond what is currently installed and operated.	Not Applicable	Not Applicable	Not Applicable	Not Applicable	Not Applicable	No – There is no reasonable set of NO _x emission control measures beyond what is currently installed and operated.
Boiler House - #8 Boiler (S8G)						
No reasonable set of NO _x emission control measures beyond what is currently installed and operated.	Not Applicable	Not Applicable	Not Applicable	Not Applicable	Not Applicable	No – There is no reasonable set of NO _x emission control measures beyond what is currently installed and operated.
H-3 and H-4 Blast Furnace						
No reasonable set of NO _x emission control measures beyond what is currently installed and operated.	Not Applicable	Not Applicable	Not Applicable	Not Applicable	Not Applicable	No – There is no reasonable set of NO _x emission control measures beyond what is currently installed and operated.

Table 1-2 Summary of SO₂ Four-Factor Analyses with Visibility Benefits Evaluations

Reasonable Set of Emission Control Measures	Factor #1 – Cost of Compliance	Factor #2 – Time Necessary for Compliance	Factor #3 – Energy and Non-Air Quality Environmental Impacts of Compliance	Factor #4 – Remaining Useful Life of the Source	Visibility Benefits	Does this Analysis Support the Installation of this Emission Control Measure?
Boiler House - #8 Boiler (S8G)						
No reasonable set of SO ₂ emission control measures beyond what is currently installed and operated.	Not Applicable	Not Applicable	Not Applicable	Not Applicable	Not Applicable	No – There is no reasonable set of SO ₂ emission control measures beyond what is currently installed and operated.
H-3 and H-4 Blast Furnace						
No reasonable set of SO ₂ emission control measures beyond what is currently installed and operated.	Not Applicable	Not Applicable	Not Applicable	Not Applicable	Not Applicable	No – There is no reasonable set of SO ₂ emission control measures beyond what is currently installed and operated.

2 Introduction

Barr Engineering (Barr) was asked to prepare this four-factor analysis to determine the effect of IHW on visibility at the applicable Class I areas, as well as determine whether additional emission control measures at identified IHW units are necessary and reasonable in order to achieve reasonable progress towards national visibility goals. Section 2.1 discusses the RFI provided to IHW by IDEM, pertinent regulatory background and relevant information from the 2019 RH SIP Guidance. Section 2.2 provides a description of the emission units which IDEM identified in the RFI, and Section 2.3 presents the facility-wide NO_x and SO₂ emissions data trends.

2.1 Four-Factor Analysis Regulatory Background

The RHR requires state regulatory agencies to submit a series of SIPs in ten-year increments to protect visibility in certain national parks and wilderness areas, known as mandatory Federal Class I areas. The original state SIPs were due on December 17, 2007 and included milestones for establishing reasonable progress towards the visibility improvement goals, with the ultimate goal to achieve natural background visibility by 2064. The initial SIP was informed by best available retrofit technology (BART) analyses that were completed on all BART-subject sources. The second RHR implementation period ends in 2028 and requires development and submittal of a comprehensive SIP update by July 31, 2021.

As part of the SIP development process, IDEM sent an RFI to IHW on June 18, 2020. The RFI states that data from the Interagency Monitoring of Protected Visual Environments (IMPROVE) monitoring site at Bondville, Illinois indicates that sulfates and nitrates continue to be the largest contributors to visibility impairment in Indiana. The primary precursors of sulfates and nitrates are emissions of SO₂ and NO_x that react with available ammonia. The RFI stated that IDEM's source selection identified iron and steel mills as one of the source categories for analysis of emission control measures based on estimates of visibility impacts analysis. Therefore, IDEM requested that IHW submit a four-factor analysis evaluating potential emission control measures, pursuant to 40 CFR 51.308(f)(2)(i), by September 30, 2020 for the emission units identified in Table 2-1.

Table 2-1 Identified Emission Units

Unit	Applicable Pollutants
Basic Oxygen Furnaces	NO _x
Boiler House - #8 Boiler (S8G)	NO _x , SO ₂
H-3 Blast Furnace	NO _x , SO ₂
H-4 Blast Furnace	NO _x , SO ₂

Note: IDEM's RFI included 84" Hot Strip Mill Boilers 1, 2, and 3. The 84" Hot Strip Mill is permanently shutdown and is being demolished. Therefore it is not appropriate to review these units as part of this analysis.

This analysis addresses the four statutory factors which are laid out in 40 CFR 51.308(f)(2)(i) and explained in the 2019 RH SIP Guidance:

1. Cost of compliance
2. Time necessary for compliance
3. Energy and non-air quality environmental impacts of compliance
4. Remaining useful life of the source

Additionally, this analysis evaluates the potential for visibility benefits at four Class I areas (Mammoth Cave (499 km), Mingo (561 km), Seney (513 km) and Isle Royale (699 km)) from the installation of potential emission control measures, consistent with the 2019 RH SIP Guidance.

2.1.1 Four-Factor Analysis Overview

The following sections describe the approach that was used to determine the reasonable set of emission control measures and summarize the approach for the four-factor analysis with visibility benefits evaluation as detailed in the 2019 RH SIP guidance.

2.1.1.1 Identifying Available Emission Control Measures

The identification of potentially available emission control measures for NO_x and SO₂ are discussed in Sections 3.1.1, 4.1.1, 4.2.1, 5.1.1, and 5.2.1. The approach that was used to identify the emission control measures is described below.

The 2019 RH SIP Guidance states that the first step of the four-factor analysis is to identify the technically feasible control options.⁵ However, EPA recognizes that “there is no statutory or regulatory requirement to consider all technically feasible measures or any particular measures,”⁶ and states that “a range of technically feasible measures available to reduce emissions would be one way to justify a reasonable set.”⁷ Potentially available emission control measures include both physical and operational changes. Operational changes that would fundamentally redefine the source were not considered; for example, the analysis did not consider changes to allowable fuels or changes in raw materials.⁸ For any technically feasible emission control measures that were identified, IHW then evaluated these emission control measures against the four statutory factors along with visibility benefits evaluation (used to define the reasonable set).

⁵ US EPA, “Guidance on Regional Haze State Implementation Plans for the Second Implementation Period,” August 20, 2019, EPA-457/B-19-003., Page 28.

⁶ Ibid, Page 29.

⁷ Ibid.

⁸ Ibid, Page 30 (“States may also determine that it is unreasonable to consider some fuel-use changes because they would be too fundamental to the operation and design of a source.”)

For the purposes of this analysis, an emission control measure was considered to be technically feasible if it has been previously installed and operated successfully on a similar source under similar physical and operating conditions. Novel emission control measures that have not been demonstrated on full-scale industrial operations are not considered as part of this analysis. Instead, this evaluation focuses on commercially demonstrated control options on similar sources in integrated iron and steel mills (II&S mills).

For purposes of this analysis, IHW evaluated only those emission control measures that have the potential to achieve an overall pollutant reduction greater than the performance of the existing systems.

The following tasks were completed to develop the reasonable set of emission control measures to be considered against the four statutory factors with visibility benefits evaluation:

1. Review the EPA's Reasonably Available Control Technology (RACT), Best Available Control Technology (BACT), and Lowest Achievable Emission Rate (LAER) Clearinghouse (RBLC), which contains "case-specific information on the 'Best Available' air pollution technologies that have been required to reduce the emission of air pollutants from stationary sources." The RBLC provided limited and dated information; the most recent pertinent information for many sources was provided in the BACT evaluation for Nucor Steel Louisiana⁹ (2010 Nucor BACT). A summary of the RBLC data reviewed is provided in Appendix A.
2. Review air permits for other II&S mills to identify emission control measures and emission limits, which are being used in practice; a comparison of air permits from similar II&S mills is provided in Appendix B.
3. Review the 2010 Nucor BACT analysis, which provides additional detail regarding specific control technologies that were evaluated for technical feasibility.
4. Select the reasonable set of emission control measures for the four-factor analysis, by process operation and by pollutant, that are most likely to be considered technically feasible; the reasonable set was selected based on the frequency of installation as identified in the RBLC, the air permits that were reviewed, and the technical discussion provided in the 2010 Nucor BACT.

In addition to the literature review, Barr interviewed process engineers from the affected areas of the IHW facility to review potential emission control measures, discuss technical feasibility, and compare to the current configuration.

2.1.1.2 Factor 1 – Cost of Compliance

Factor #1 considers and estimates, as needed, the capital and annual operating and maintenance (O&M) costs of the emission control measure. As directed by the 2019 RH SIP Guidance at page 31, costs of emission control measures follow the accounting principles and generic factors from the EPA Air Pollution

⁹ Consolidated Environmental Management Inc – Nucor Steel Louisiana, Best Available Control Technology Analyses, March 1, 2010, PSD-LA-740.

Control Cost Manual (EPA Control Cost Manual)¹⁰ unless more refined site-specific estimates were available. Under this step, the annualized cost of installation and operation on a dollars per ton of pollutant removed (\$/ton) of the emission control measure, referred to as “average cost effectiveness,” is compared to a cost-effectiveness threshold that is relative to the expected visibility improvements. As stated in the 2019 RH SIP Guidance, the “balance between the cost of compliance and the visibility benefits will be an important consideration in a state’s decisions.”¹¹

Generally, if the average cost-effectiveness is greater than the threshold and/or if there is no expected perceptible visibility improvements, the cost is considered to not be reasonable, pending an evaluation of other factors. Conversely, if the average cost-effectiveness is less than the threshold and the emission control measures will result in a perceptible improvement in visibility in Class I areas, then the cost is considered reasonable for purposes of Factor #1, pending an evaluation of whether the absolute cost of control (i.e., costs in absolute dollars, not normalized to \$/ton) is unreasonable.

The cost of an emission control measure is derived using capital and annual O&M costs. Capital costs generally refer to the money required to design and build the system. This includes direct costs, such as equipment purchases and installation costs. Indirect costs, such as engineering and construction field expenses and lost revenue due to additional unit downtime in order to install the additional emission control measure(s), are also considered as part of the capital calculation. Annual O&M costs include labor, supplies, utilities, etc., as used to determine the annualized cost in the numerator of the cost-effectiveness value. The denominator of the cost-effectiveness value (tons of pollutant removed) is derived as the difference in: 1) projected emissions using the current emission control measures (baseline emissions), in tons per year (tpy), and 2) expected annual emissions performance through the installation of the additional emission control measure (controlled emissions), also in tpy.

Neither the RHR nor 2019 RH SIP Guidance provides a cost-effectiveness threshold because the analysis must consider what emission reductions are necessary to make reasonable progress. The 2019 RH SIP Guidance says that the state has the “discretion to consider the anticipated visibility benefits of an emission control measure” when making these decisions.¹² For example, the installation of additional emission control measures at IHW would not improve visibility at the associated Class I areas (as described in Section 6.3). The guidance also says “a state may be able to demonstrate, based on careful consideration of the relevant factors for its selected sources, that no additional measures are necessary to

¹⁰ US EPA, “EPA Air Pollution Control Cost Manual, Sixth Edition,” January 2002, EPA/452/B-02-001. The EPA has updated certain sections and chapters of the manual since January 2002. These individual sections and chapters may be accessed at <https://www.epa.gov/economic-and-cost-analysis-air-pollution-regulations/cost-reports-and-guidance-air-pollution> as of the date of this report.

¹¹ US EPA, “Guidance on Regional Haze State Implementation Plans for the Second Implementation Period,” August 20, 2019, Page 37.

¹² Ibid.

make reasonable progress in the second implementation period.”¹³ For example, the current visibility in some Class I areas is already below the 2028 URP glidepath and some facilities are already committed to additional emission reductions (as described in Section 6.1).

2.1.1.3 Factor 2 – Time Necessary for Compliance

Factor #2 considers the time needed for IHW to comply with potential emission control measures. This includes the planning, designing, installing, and commissioning of the selected control based on experiences with similar sources and source-specific factors.

For purposes of this analysis and if a given NO_x or SO₂ emission control measure requires a unit outage as part of its installation, IHW considers the forecasted outage schedule for the associated units in conjunction with the expected timeframe for engineering and equipment procurement following IDEM and EPA approval of the given emission control measure.

2.1.1.4 Factor 3 – Energy and Non-Air Quality Environmental Impacts of Compliance

Factor #3 considers the energy and non-air environmental impacts of each emission control measure. Energy impacts to be considered are the direct energy consumed at the source, in terms of kilowatt-hours or mass of fuels used. Non-air quality impacts may include solid or hazardous waste generation, wastewater discharges from a control device, increased water consumption, and land use. The analysis is conducted based on the consideration of site-specific circumstances.

2.1.1.5 Factor 4 – Remaining Useful Life of the Source

Factor #4 considers the remaining useful life of the source, which is the difference between the date that additional emission control measures will be put in place and the date that the emission unit is anticipated to permanently cease operation. Generally, the remaining useful life of the emission unit is assumed to be longer than the useful life of the emission control measure unless the source is under an enforceable requirement to cease operation. In the presence of an enforceable end date, the cost calculation can use a shorter period to amortize the capital cost.

For the purpose of this evaluation, the remaining useful life for the units is assumed to be longer than the useful life of the additional emission control measures. Therefore, the expected useful life of the emission control measure is used to calculate the emissions reductions, amortized costs, and the resulting cost per ton removed.

2.1.1.6 Visibility Benefits

In addition to the four statutory factors, this analysis considers the potential visibility benefits from installing additional emission control measures at the source. The 2019 RH SIP Guidance states that

¹³ Ibid, Page 36.

"visibility benefits may again be considered in that control analysis to inform the determination of whether it is reasonable to require a certain measure."¹⁴

For the purpose of this evaluation, additional emission control measures would be inappropriate and unnecessary to make reasonable progress at the associated Class I areas if any of the following conditions are satisfied:

1. The current visibility conditions are already below (Mammoth Cave (499 km), Seney (513 km) and Isle Royale (699 km)), or trending towards and expected to attain without additional emission reductions (Mingo (561 km)), the 2028 URP,
2. The facility is not a contributor to perceptible visibility impairment on the most impaired days at the associated Class I areas, or
3. The additional emission control measure does not provide sufficient incremental visibility benefits to justify the other four factors (cost, time to implement, energy and non-air quality environmental impacts, and remaining useful life).

2.2 Affected Emission Unit Description and Existing Emission Control Measures

IHW is an integrated steel mill located in East Chicago, Indiana. Operations include raw material handling, ironmaking, steelmaking, and manufacturing of hot-rolled, and hot-dipped galvanized sheet products, as well as on-site utility generation. The three emission unit groups addressed in IDEM's RFI are described below.

2.2.1 Basic Oxygen Furnaces

BOFs charge molten iron from the blast furnaces, flux, alloys, and scrap with high-purity oxygen. This process oxidizes or removes excess carbon, silicon, manganese, and other impurities from the hot metal to produce molten steel. When the temperature and composition are satisfactory, the molten steel is tapped into a transfer ladle for subsequent processing. Off-gas resulting from the basic oxygen process are controlled with an electrostatic precipitator for particulate matter (PM) control.

NO_x emissions are generated from atmospheric nitrogen in proximity with the combustion of carbon upon contact with the high-purity oxygen injection. These emissions are assumed to be primarily thermal NO_x.

2.2.2 Boiler House - #8 Boiler (S8G)

The Boiler House - #8 Boiler (S8G) produces utility steam for operating turbo-blowers in the generation of cold blast (wind) to the blast furnace(s), high pressure steam for power generation at the turbine, and low pressure steam for use throughout the IHW facility. The boiler predominantly fires blast furnace gas and

¹⁴ US EPA, "Guidance on Regional Haze State Implementation Plans for the Second Implementation Period," August 20, 2019, Page 34.

supplements natural gas to maintain fuel header pressure and flame stability during periods of blast furnace startup/shutdown.

The Boiler House - #8 Boiler (S8G) generates NO_x emissions from natural gas and blast furnace gas combustion. Blast furnace gas is considered a low-NO_x fuel because it has a lower heating value compared to natural gas (approximately 10% of the heating value) which creates a lower flame temperature and generates significantly less thermal NO_x. The Boiler House - #8 Boiler (S8G) utilizes low-NO_x fuel and good combustion practices as NO_x emission control measures.

The Boiler House - #8 Boiler (S8G) generates SO₂ emissions from natural gas and blast furnace gas combustion. Natural gas and blast furnace gas are considered low-sulfur fuels when compared to other solid and liquid fuels, and are utilized as an SO₂ emission control measure.

2.2.3 H-3 and H-4 Blast Furnaces

The H-3 and H-4 Blast Furnaces combine coke, limestone, sinter, iron ore pellets, and other iron sources with high heat to produce molten iron. Hot air must be injected into the blast furnace to ignite the added coke. This hot air is produced in the blast furnace stoves, which fire blast furnace gas and supplemental natural gas to heat fresh air for injection. Blast furnace gas is the partially combusted, CO-rich gas that is produced within the blast furnace itself. This gas has a low heating value and is cleaned for PM via the integrated scrubbing system prior to combustion as a fuel source to offset purchased fuels and improve energy efficiency.

Once the molten iron is produced, the furnace is tapped and the molten iron flows through a series of troughs into refractory lined bottle cars for rail transfer to the steel shop(s).

The H-3 and H-4 Blast Furnace Stoves resulting NO_x emissions are generated from primarily firing blast furnace gas and natural gas enrichment to raise the fuel's heating value enough to hit furnace dome temperature by the end of the heating cycles. The heat is then transferred out of the stove to preheat fresh air (cold blast) for recovering heat back to the furnace through "hot blast" injection. Blast furnace gas is considered a low-NO_x fuel because it has a lower heating value compared to natural gas (approximately 10% of the heating value) which creates a lower flame temperature and generates significantly less thermal NO_x. Therefore, the use of blast furnace gas in the H-3 and H-4 Blast Furnace Stoves is an existing NO_x emission control measure.

The H-3 and H-4 Blast Furnace Stoves generate SO₂ emissions through oxidation of sulfur compounds present in the fuel (blast furnace gas and natural gas). Blast furnace gas and natural gas are considered low-sulfur fuels, compared to other solid and liquid fuels, and are utilized as SO₂ emission control measures.

The NO_x emissions from the H-3 and H-4 Blast Furnace Casthouses are not significant (35.38 ton NO_x per year in 2018). NO_x emissions may be generated during the casting process and are a result of reactions of nitrogen in ambient air.

The H-3 and H-4 Blast Furnace Casthouses' molten iron and slag streams contain sulfur compounds that oxidize to form SO₂ upon contact with ambient air during the casting process. For the H-4 Blast Furnace, taphole drilling/plugging and iron ladle filling emissions are collected and routed to the H-4 casthouse baghouse for particulate control. Emissions from slag runners and pits are either uncaptured or outside of the casthouse and fugitive-in-nature (i.e., not emitted from a stack).

The H-3 and H-4 Blast Furnace Flares produce NO_x and SO₂ due to the combustion of blast furnace waste gas and natural gas pilots. Blast furnace gas is a low-NO_x fuel and is utilized as an existing NO_x emission control measure. Blast furnace gas and natural gas are considered low-sulfur fuels and are SO₂ emission control measures.

2.3 Facility-wide NO_x and SO₂ Emission Trends

The goal of the RHR is to improve the visibility at Class I areas of interest through visibility-impairing pollutant emission reductions. Independent of any RHR requirements, IHW has achieved substantial facility-wide NO_x and SO₂ emission reductions in the recent years as a result of shut down of operations, including the No. 2 Sinter Plant and 84" Hot Strip Mill Reheat Furnaces 1, 2, and 3, and eliminated oil burning capability on facility boilers. Figure 2-1 presents the facility-wide NO_x and SO₂ emissions from 2005 to 2018. IHW has already reduced NO_x and SO₂ emissions by 18% from 2005 (2005 = 3,267 tons/year NO_x and SO₂, 2018 = 2,664 tons/year NO_x and SO₂) and, therefore, additional emission control measures are not necessary to achieve reasonable progress when considered in conjunction with the current visibility trends (see Section 6.1) and the lack of visibility impacts at the associated Class I areas from IHW (see Section 6.3). Note, the 2009 emissions reflect an economic downturn that resulted in reduced production rates.




Figure 2-1 Facility-wide NO_x and SO₂ Emissions from 2005 to 2018

3 Basic Oxygen Furnaces

The following section describes the four-factor analysis with visibility benefits evaluation for NO_x emission control measures for the Basic Oxygen Furnaces.

3.1 Four-Factor Analysis – NO_x

The following sections describe the analysis for determining the reasonable set of NO_x emission control measures (Section 3.1.1), the four-factor analysis with visibility benefits evaluation (Sections 3.1.3 through 3.1.7), and the proposed emission control measures (Section 3.1.8) for the Basic Oxygen Furnaces.

3.1.1 NO_x Emission Control Measures

The RBLC search (summarized in Appendix A) and search of air permits for II&S mills and similar sources (Appendix B) for Basic Oxygen Furnaces did not identify any NO_x emission control measures. The RBLC search (Appendix A) listed that no additional NO_x emission control measures were required for a 2005 BACT determination for Wheeling Pittsburgh Steel Corporation (RBLCID = OH-0292).

There are no additional NO_x emission control measures based on the emission control measures described in the RBLC (Appendix A) and air permits for II&S mills (Appendix B). As such, the Basic Oxygen Furnaces have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units.

3.1.2 Baseline Emission Rates

Since the four-factor analysis concluded the Basic Oxygen Furnaces have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units, it is not necessary to represent a projected 2028 emissions scenario.

3.1.3 Factor 1 – Cost of Compliance

Since the four-factor analysis concluded the Basic Oxygen Furnaces have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units, it is not appropriate to estimate the cost of compliance for additional NO_x emission control measures.

3.1.4 Factor 2 – Time Necessary for Compliance

Since the four-factor analysis concluded the Basic Oxygen Furnaces have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units, it is not appropriate to describe the time that is necessary to achieve compliance for additional NO_x emission control measures.

3.1.5 Factor 3 – Energy and Non-Air Quality Environmental Impacts of Compliance

Since the four-factor analysis concluded the Basic Oxygen Furnaces have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units, it is

not appropriate to describe the energy and non-air quality environmental impacts for additional NO_x emission control measures.

3.1.6 Factor 4 – Remaining Useful Life of the Source

Since the four-factor analysis concluded the Basic Oxygen Furnaces have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units, it is not appropriate to describe the remaining useful life of the source.

3.1.7 Visibility Benefits

Since the four-factor analysis concluded the Basic Oxygen Furnaces have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units, it is not appropriate to describe the potential visibility benefits for additional NO_x emission control measures.

3.1.8 Proposed NO_x Emission Control Measures

The four-factor analysis concluded that additional NO_x emission control measures at the Basic Oxygen Furnaces beyond those described in Section 2.2.1 are not required to make reasonable progress. As such, this analysis proposes to maintain the existing NO_x emission control measures.

4 Boiler House - #8 Boiler (S8G)

The following sections describe the four-factor analyses with visibility benefits evaluations for NO_x and SO₂ emission control measures for the Boiler House - #8 Boiler (S8G).

4.1 Four-Factor Analysis - NO_x

The following sections describe the analysis for determining the reasonable set of NO_x emission control measures (Section 4.1.1), the four-factor analysis with visibility benefits evaluation (Sections 4.1.3 through 4.1.7), and the proposed emission control measures (Section 4.1.8) for the Boiler House - #8 Boiler (S8G).

4.1.1 NO_x Emission Control Measures

The RBLC search (summarized in Appendix A) and search of air permits for I&S mills and similar sources (Appendix B) for Boilers NO_x emission control measures identified the use of low-NO_x fuel, Selective Catalytic Reduction (SCR)¹⁵, Low-NO_x Burners (LNB), and/or Ultra Low-NO_x Burners (ULNB) at some sources. As described in Section 2.2.2, the Boiler House - #8 Boiler (S8G) already utilizes low-NO_x fuel combustion (blast furnace gas) and good combustion practices as existing NO_x emission control measures.

The RBLC search (Appendix A) listed many references to the installation of SCR, LNB, and ULNB for natural gas only-fired boilers. The Boiler House - #8 Boiler (S8G) is not directly comparable to boilers that strictly fire natural gas because the Boiler House - #8 Boiler (S8G) fires blast furnace gas (a low-NO_x fuel) and supplements with natural gas to maintain flame temperature.

SCR is excluded from the reasonable set because it has not been installed and successfully operated on a similar source under similar physical and operating conditions (i.e., blast furnace gas as a primary fuel source).

The Briefing Sheet accompanying the 2010 Nucor Permit to Construct (PSD-LA-740) stated that LNB was eliminated as technically infeasible for the following rationale:

*"Low NO_x burners limit the formation of NO_x by staging the addition of air to create a longer, cooler flame. The combustion of BFG in the topgas boilers requires the supplement of natural gas in order to maintain flame stability and prevent flame-outs of the burners. The use of low NO_x burners would attempt to stage fuel gas at the limits of combustibility and potentially prevent combustion of the fuel from occurring. Thus, Low NO_x burners are not a feasible control technology for the topgas boilers."*¹⁶

¹⁵ SCR reduces NO_x emissions with ammonia or urea injection in the presence of a catalyst.

¹⁶ Louisiana Department of Environmental Quality, Nucor Steel Permit to Construct (PSD-LA-740) Briefing Sheet, 2010, Page 80.

Since LNB, and by extension ULNB which uses the same principles (longer, cooler flame), represent a negligible or potentially small emission reduction potential, compared to the current NO_x emission control measures, and have potential operational challenges, LNB and ULNB are not considered as part of the reasonable set of NO_x emission control measures for the Boiler House - #8 Boiler (S8G) and are not evaluated further in this analysis.

There are no additional NO_x emission control measures based on the emission control measures described in the RBLC (Appendix A) and air permits for II&S mills (Appendix B). As such, Boiler House - #8 Boiler (S8G) has no reasonable set of NO_x emission control measures beyond what is currently installed and operated for this emission unit.

4.1.2 Baseline Emission Rates

Since the four-factor analysis concluded the Boiler House - #8 Boiler (S8G) has no reasonable set of NO_x emission control measures beyond what is currently installed and operated for this emission unit, it is not necessary to represent a projected 2028 emissions scenario.

4.1.3 Factor 1 – Cost of Compliance

Since the four-factor analysis concluded the Boiler House - #8 Boiler (S8G) has no reasonable set of NO_x emission control measures beyond what is currently installed and operated for this emission unit, it is not appropriate to estimate the cost of compliance for additional NO_x emission control measures.

4.1.4 Factor 2 – Time Necessary for Compliance

Since the four-factor analysis concluded the Boiler House - #8 Boiler (S8G) has no reasonable set of NO_x emission control measures beyond what is currently installed and operated for this emission unit, it is not appropriate to describe the time that is necessary to achieve compliance for additional NO_x emission control measures.

4.1.5 Factor 3 – Energy and Non-Air Quality Environmental Impacts of Compliance

Since the four-factor analysis concluded the Boiler House - #8 Boiler (S8G) has no reasonable set of NO_x emission control measures beyond what is currently installed and operated for this emission unit, it is not appropriate to describe the energy and non-air quality environmental impacts for additional NO_x emission control measures.

4.1.6 Factor 4 – Remaining Useful Life of the Source

Since the four-factor analysis concluded the Boiler House - #8 Boiler (S8G) has no reasonable set of NO_x emission control measures beyond what is currently installed and operated for this emission unit, it is not appropriate to describe the remaining useful life of the source.

4.1.7 Visibility Benefits

Since the four-factor analysis concluded the Boiler House - #8 Boiler (S8G) has no reasonable set of NO_x emission control measures beyond what is currently installed and operated for this emission unit, it is not appropriate to describe the potential visibility benefits for additional NO_x emission control measures.

4.1.8 Proposed NO_x Emission Control Measures

The four-factor analysis concluded that additional NO_x emission control measures at the Boiler House - #8 Boiler (S8G) beyond those described in Section 2.2.2 are not required to make reasonable progress. As such, this analysis proposes to maintain the existing NO_x emission control measures.

4.2 Four-Factor Analysis - SO₂

The following sections describe the analysis for determining the reasonable set of SO₂ emission control measures (Section 4.2.1), the four-factor analysis with visibility benefits evaluation (Sections 4.2.3 through 4.2.7), and the proposed emission control measures (Section 4.2.8) for the Boiler House - #8 Boiler (S8G).

4.2.1 SO₂ Emission Control Measures

The RBLC search (summarized in Appendix A) and search of air permits for II&S mills and similar sources (Appendix B) for Boilers SO₂ emission control measures identified the use of low-sulfur fuels at some sources. As described in Section 2.2.2, the Boiler House - #8 Boiler (S8G) already utilizes low-sulfur fuel combustion (natural gas and blast furnace gas) as an existing SO₂ emission control measure.

There are no additional SO₂ emission control measures based on the emission control measures described in the 2010 Nucor BACT, the RBLC (Appendix A), and air permits for II&S mills (Appendix B). As such, the Boiler House - #8 Boiler (S8G) has no reasonable set of SO₂ emission control measures beyond what is currently installed and operated.

4.2.2 Baseline Emission Rates

Since the four-factor analysis concluded the Boiler House - #8 Boiler (S8G) has no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for this emission unit, it is not necessary to represent a projected 2028 emissions scenario.

4.2.3 Factor 1 – Cost of Compliance

Since the four-factor analysis concluded the Boiler House - #8 Boiler (S8G) has no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for this emission unit, it is not appropriate to estimate the cost of compliance for additional SO₂ emission control measures.

4.2.4 Factor 2 – Time Necessary for Compliance

Since the four-factor analysis concluded the Boiler House - #8 Boiler (S8G) has no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for this emission unit, it is not appropriate to describe the time that is necessary to achieve compliance for additional SO₂ emission control measures.

4.2.5 Factor 3 – Energy and Non-Air Quality Environmental Impacts of Compliance

Since the four-factor analysis concluded the Boiler House - #8 Boiler (S8G) has no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for this emission unit, it is not appropriate to describe the energy and non-air quality environmental impacts for additional SO₂ emission control measures.

4.2.6 Factor 4 – Remaining Useful Life of the Source

Since the four-factor analysis concluded the Boiler House - #8 Boiler (S8G) has no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for this emission unit, it is not appropriate to describe the remaining useful life of the source.

4.2.7 Visibility Benefits

Since the four-factor analysis concluded the Boiler House - #8 Boiler (S8G) has no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for this emission unit, it is not appropriate to describe the potential visibility benefits for additional SO₂ emission control measures.

4.2.8 Proposed SO₂ Emission Control Measures

The four-factor analysis concluded that additional SO₂ emission control measures at the Boiler House - #8 Boiler (S8G) beyond those described in Section 2.2.2 are not required to make reasonable progress in reducing SO₂ emissions. As such, this analysis proposes to maintain the existing SO₂ emission control measures.

5 H-3 and H-4 Blast Furnaces

The following sections describe the four-factor analyses with visibility benefits evaluations for NO_x and SO₂ emission control measures for the H-3 and H-4 Blast Furnaces.

5.1 Four-Factor Analysis - NO_x

The following sections describe the analysis for determining the reasonable set of NO_x emission control measures (Section 5.1.1), the four-factor analysis with visibility benefits evaluation (Sections 5.1.3 through 5.1.7), and the proposed emission control measures (Section 5.1.8) for the H-3 and H-4 Blast Furnaces Stoves, Casthouse, and Flares.

5.1.1 NO_x Emission Control Measures

5.1.1.1 H-3 and H-4 Blast Furnace Stoves

The RBLC search (summarized in Appendix A) and search of air permits for I&S mills and similar sources (Appendix B) for Blast Furnace Stoves NO_x emission control measures identified the use of low-NO_x fuel or LNB at some sources. As described in Section 2.2.3, the H-3 and H-4 Blast Furnace Stoves already utilize low-NO_x fuel combustion (blast furnace gas) as an existing NO_x emission control measure.

The AK Steel Dearborn B and C Furnaces have LNB installed as part of a 2014 Prevention of Significant Deterioration (PSD) Permit; however, it is not clear that LNB offer any additional emission reduction potential compared to the existing NO_x emission control measures (blast furnace gas – low-NO_x fuel). EPA stated the following in a document titled “Alternative Control Techniques Document -- NO_x Emissions From Iron and Steel Mills”¹⁷:

“[...] the primary fuel is BFG, which is largely CO, has a low heating value, and contains inerts, factors that reduce flame temperature. Thus, the NO_x concentration in blast furnace stove flue gas tends to be low and the potential for NO_x reduction is considered to be small.”

Additionally, the Briefing Sheet accompanying the 2010 Nucor Permit to Construct (PSD-LA-740) stated that LNB was eliminated as technically infeasible for the following rationale:

“Low NO_x burners limit the formation of NO_x by staging the addition of air to create a longer, cooler flame. The combustion of BFG in the hot blast stoves requires the supplement of a small amount of natural gas in order to maintain flame stability and prevent flame-outs of the burners. The use of low NO_x burners would attempt to stage fuel gas at the limits of combustibility and would prevent

¹⁷ EPA, “Alternative Control Techniques Document – NO_x Emissions from Iron and Steel Mills” (EPA-453/R-94-065), 1994, Page 5-22

the operation of the hot blast stoves. Thus, low NO_x burners are not a feasible control technology for the hot blast stoves.”¹⁸

Since LNB represent a negligible or potentially small emission reduction potential (if any), compared to the current NO_x emission control measures, and have potential operational challenges, LNB are not considered as part of the reasonable set of NO_x emission control measures for the H-3 and H-4 Blast Furnace Stoves and are not evaluated further in this analysis.

Therefore, the H-3 and H-4 Blast Furnace Stoves have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units based on the 2010 Nucor BACT, emission control measures described in the RBLC (Appendix A) and air permits for similar sources (Appendix B).

5.1.1.2 H-3 and H-4 Blast Furnace Casthouses

The RBLC search (summarized in Appendix A) and search of air permits for II&S mills and similar sources (Appendix B) for Blast Furnace Casthouses did not identify any NO_x emission control measures.

The 2010 Nucor BACT analysis did not evaluate NO_x emission control measures because Nucor Steel Louisiana did not estimate NO_x emissions for the casthouse in the associated permit application. This implies that the casthouse NO_x emissions were considered negligible for that project.

There are no additional NO_x emission control measures based on the emission control measures described in the RBLC (Appendix A) and air permits for II&S mills (Appendix B). As such, the H-3 and H-4 Blast Furnace Casthouses have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units.

5.1.1.3 H-3 and H-4 Blast Furnace Flares

The RBLC search (summarized in Appendix A) and search of air permits for II&S mills and similar sources (Appendix B) for Blast Furnace Flares did not identify any NO_x emission control measures.

There are no additional NO_x emission control measures based on the emission control measures described in the RBLC (Appendix A) and air permits for II&S mills (Appendix B). As such, the H-3 and H-4 Blast Furnace Flares have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units.

¹⁸ Louisiana Department of Environmental Quality, Nucor Steel Permit to Construct (PSD-LA-740) Briefing Sheet, 2010, Page 23.

5.1.2 Baseline Emission Rates

Since the four-factor analysis concluded the H-3 and H-4 Blast Furnace Stoves, Casthouses, and Flares have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units, it is not necessary to represent a projected 2028 emissions scenario.

5.1.3 Factor 1 – Cost of Compliance

Since the four-factor analysis concluded the H-3 and H-4 Blast Furnace Stoves, Casthouses, and Flares have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units, it is not appropriate to estimate the cost of compliance for additional NO_x emission control measures.

5.1.4 Factor 2 – Time Necessary for Compliance

Since the four-factor analysis concluded the H-3 and H-4 Blast Furnace Stoves, Casthouses, and Flares have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units, it is not appropriate to describe the time that is necessary to achieve compliance for additional NO_x emission control measures.

5.1.5 Factor 3 – Energy and Non-Air Quality Environmental Impacts of Compliance

Since the four-factor analysis concluded the H-3 and H-4 Blast Furnace Stoves, Casthouses, and Flares have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units, it is not appropriate to describe the energy and non-air quality environmental impacts for additional NO_x emission control measures.

5.1.6 Factor 4 – Remaining Useful Life of the Source

Since the four-factor analysis concluded the H-3 and H-4 Blast Furnace Stoves, Casthouses, and Flares have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units, it is not appropriate to describe the remaining useful life of the source.

5.1.7 Visibility Benefits

Since the four-factor analysis concluded the H-3 and H-4 Blast Furnace Stoves, Casthouses, and Flares have no reasonable set of NO_x emission control measures beyond what is currently installed and operated for these emission units, it is not appropriate to describe the potential visibility benefits for additional NO_x emission control measures.

5.1.8 Proposed NO_x Emission Control Measures

The four-factor analysis concluded that additional NO_x emission control measures at the H-3 and H-4 Blast Furnace Stoves, Casthouses, and Flares beyond those described in Section 2.2.3 are not required to make reasonable progress. As such, this analysis proposes to maintain the existing NO_x emission control measures.

5.2 Four-Factor Analysis – SO₂

The following sections describe the analysis for determining the reasonable set of SO₂ emission control measures (Section 5.2.1), the four-factor analysis with visibility benefits evaluation (Sections 5.2.3 through 5.2.7), and the proposed emission control measures (Section 5.2.8) for the H-3 and H-4 Blast Furnaces Stoves, Casthouse, and Flares.

5.2.1 SO₂ Emission Control Measures

5.2.1.1 H-3 and H-4 Blast Furnace Stoves

The RBLC search (summarized in Appendix A) and search of air permits for II&S mills and similar sources (Appendix B) for Blast Furnace Stoves SO₂ emission control measures identified the use of low-sulfur fuel at one source. As described in Section 2.2.3, the H-3 and H-4 Blast Furnace Stoves routinely fire low-sulfur fuels (blast furnace gas and natural gas) as an existing SO₂ emission control measure.

AK Steel Dearborn (RBLCID = MI-0413) underwent SO₂ BACT in 2014 and concluded that BACT did not require additional SO₂ emission control measures. The 2010 Nucor BACT determined that other than the low-sulfur fuels (blast furnace gas and natural gas), no additional add-on SO₂ emission control measures are technically feasible.

There are no additional SO₂ emission control measures based on the 2010 Nucor BACT, emission control measures described in the RBLC (Appendix A) and air permits for II&S mills (Appendix B). As such, the H-3 and H-4 Blast Furnace Stoves have no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for these emission units.

5.2.1.2 H-3 and H-4 Blast Furnace Casthouses

The RBLC search (summarized in Appendix A) and search of air permits for II&S mills and similar sources (Appendix B) for Blast Furnace Casthouses did not identify any SO₂ emission control measures.

AK Steel Dearborn (RBLCID = MI-0413) underwent SO₂ BACT in 2014 and concluded that BACT did not require additional SO₂ emission control measures. The 2010 Nucor BACT stated that there are no feasible SO₂ emission control measures because of the corresponding low SO₂ concentration (~4 ppm SO₂) and high exhaust flow rate.

There are no additional SO₂ emission control measures based on the 2010 Nucor BACT, emission control measures described in the RBLC (Appendix A) and air permits for II&S mills (Appendix B). As such, the H-3 and H-4 Blast Furnace Casthouses have no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for these emission units.

5.2.1.3 H-3 and H-4 Blast Furnace Flares

The RBLC search (summarized in Appendix A) and search of air permits for II&S mills and similar sources (Appendix B) for Blast Furnace Flares did not identify any SO₂ emission control measures.

There are no additional SO₂ emission control measures based on the 2010 Nucor BACT, emission control measures described in the RBLC (Appendix A) and air permits for I&S mills (Appendix B). As such, the H-3 and H-4 Blast Furnace Flares have no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for these emission units.

5.2.2 Baseline Emission Rates

Since the four-factor analysis concluded the H-3 and H-4 Blast Furnace Stoves, Casthouses, and Flares have no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for these emission units, it is not necessary to represent a projected 2028 emissions scenario.

5.2.3 Factor 1 – Cost of Compliance

Since the four-factor analysis concluded the H-3 and H-4 Blast Furnace Stoves, Casthouses, and Flares have no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for these emission units, it is not appropriate to estimate the cost of compliance for additional SO₂ emission control measures.

5.2.4 Factor 2 – Time Necessary for Compliance

Since the four-factor analysis concluded the H-3 and H-4 Blast Furnace Stoves, Casthouses, and Flares have no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for these emission units, it is not appropriate to describe the time that is necessary to achieve compliance for additional SO₂ emission control measures.

5.2.5 Factor 3 – Energy and Non-Air Quality Environmental Impacts of Compliance

Since the four-factor analysis concluded the H-3 and H-4 Blast Furnace Stoves, Casthouses, and Flares have no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for these emission units, it is not appropriate to describe the energy and non-air quality environmental impacts for additional SO₂ emission control measures.

5.2.6 Factor 4 – Remaining Useful Life of the Source

Since the four-factor analysis concluded the H-3 and H-4 Blast Furnace Stoves, Casthouses, and Flares have no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for these emission units, it is not appropriate to describe the remaining useful life of the source.

5.2.7 Visibility Benefits

Since the four-factor analysis concluded the H-3 and H-4 Blast Furnace Stoves, Casthouses, and Flares have no reasonable set of SO₂ emission control measures beyond what is currently installed and operated for these emission units, it is not appropriate to describe the potential visibility benefits for additional SO₂ emission control measures.

5.2.8 Proposed SO₂ Emission Control Measures

The four-factor analysis concluded that additional SO₂ emission control measures at the H-3 and H-4 Blast Furnace Stoves, Casthouses, and Flares beyond those described in Section 2.2.3 are not required to make reasonable progress in reducing SO₂ emissions. As such, this analysis proposes to maintain the existing SO₂ emission control measures.

6 Visibility Impacts Review

The RHR requires state regulatory agencies to submit a series of SIPs in ten-year increments to protect visibility in certain national parks and wilderness areas, known as mandatory Federal Class I areas.

Figure 6-1 shows a map of the IHW facility relative to the four closest Class I areas. The Class I areas and the distance from the facility are:

- Mammoth Cave National Park – Kentucky (499 km)
- Seney National Wildlife Refuge – Michigan (513 km)
- Mingo National Wildlife Refuge – Missouri (561 km)
- Isle Royale National Park – Michigan (699 km)




Figure 6-1 Location of Class I Areas in Relation to the Indiana Harbor West Facility

Section 6.1 provides an analysis of current visibility conditions at the four Class I areas presented in Figure 6-1 while Section 6.2 evaluates the emission trends that are impacting visibility in these Class I areas. Section 6.3 provides a review of previously completed visibility modeling and screening analysis which illustrate that emission reductions at IHW are unlikely to improve visibility on the most impaired days at these Class I areas.

6.1 Visibility Conditions in the Closest Class I Areas

The RHR requires that the SIP include an analysis of “baseline, current, and natural visibility conditions; progress to date; and the uniform rate of progress”¹⁹ for the relevant Class I areas. This information is used to establish the reasonable progress goals to be achieved by the end of the implementation period in 2028.²⁰ Barr conducted an analysis of the current visibility conditions at relevant Class I areas to determine the progress to date and status versus the 2028 URP glidepath. The relevant Class I areas are shown in Figure 6-1.

Visibility improvement is measured using data from the IMPROVE monitoring sites. The visibility metric is based on the 20% most anthropogenically impaired days and the 20% clearest days, with visibility being measured in deciviews (dv).

Figure 6-2 through Figure 6-5 show the rolling 5-year average visibility impairment based on IMPROVE monitoring data compared with the URP glidepath at Mammoth Cave (499 km), Mingo (561 km), Isle Royale (699 km), and Seney (513 km), respectively. As shown in these figures, the five-year average visibility metric has been improving for more than one decade at all four Class I areas. Impacts on the most impaired days at Mammoth Cave (499 km) (Figure 6-2), Isle Royale (699 km) (Figure 6-4), and Seney (513 km) (Figure 6-5) are already below the 2028 glidepath and have continued trending downward since. The visibility at Mingo (561 km) (Figure 6-3) is slightly above the 2028 glidepath but has been on a downward trend since 2007 and is expected to attain this threshold without additional emission reductions.

¹⁹ 40 CFR 51.308(f)(1)

²⁰ 40 CFR 51.308(f)(3)




Figure 6-2 Visibility Trend versus URP – Mammoth Cave National Park (499 km)²¹

²¹ Jim Boylan – Georgia Department of Natural Resources, "VISTAS Regional Haze Project Update," 5/20/2020, Page 25. (<https://www.metro4-sesarm.org/sites/default/files/VISTAS%20Pres%20Stakeholders%20Final%20200520.pdf>)




Figure 6-3 Visibility Trend versus URP – Mingo National Wildlife Refuge (561 km)²²

²² Jim Boylan - Georgia Department of Natural Resources, "VISTAS Regional Haze Project Update," 5/20/2020, Page 37. (<https://www.metro4-sesarm.org/sites/default/files/VISTAS%20Pres%20Stakeholders%20Final%20200520.pdf>)




Figure 6-4 Visibility Trend versus URP – Isle Royale National Park (699 km)²³

²³ Visibility trend from the Minnesota Pollution Control Agency website

(https://public.tableau.com/profile/mpca.data.services#!/vizhome/RegionalHaze_visibility_metrics_public/Visibilityprogress)




Figure 6-5 Visibility Trend versus URP – Seney National Wildlife Refuge (513 km)²⁴

6.2 Emission Trend Analyses

The downward visibility trend for each of the Class I monitors illustrated above can be attributed to a number of different actions taken to reduce emissions NO_x and SO₂ from several sources, including:

- Installation of BART during the first RHR implementation period
- Emission reductions from a variety of industries, including the integrated iron and steel industry, due to equipment shutdowns and updated rules/regulations
- Transition of power generation systems from coal to natural gas and renewables, such as wind and solar

The trends for NO_x and SO₂ emissions are illustrated on a national and regional basis in Figure 6-6 and Figure 6-7, respectively.

²⁴ IMPROVE monitoring network (<http://vista.cira.colostate.edu/improve/>)




Figure 6-6 National NO_x and SO₂ Emission Trends

The national trends show a consistent pattern of emission reductions that will continue throughout the 2nd round of regional haze planning. There is a 35% reduction from 2016 to 2028 in national NO_x and SO₂ emissions. The emissions from 2002 – 2018 were developed based on information contained in the EPA's Air Pollutant Emission Trends Data²⁵ and the 2028 data was obtained from page 18 of EPA's regional haze modeling summary which includes the summary of modeled emissions²⁶.

²⁵ [EPA Air Pollutant Emission Trends Data, National Annual Emission Trend](#)

²⁶ https://www.epa.gov/sites/production/files/2019-10/documents/epa_rh_modeling_summary_101519-final_0.pdf




Figure 6-7 Upper Midwest NO_x and SO₂ Emission Trends

The regional summary also exhibits a significant reduction in NO_x and SO₂ emissions (35% from 2016 to 2028). The Upper Midwest region includes Illinois, Indiana, Michigan, Minnesota, and Wisconsin as areas that may impact the Class I areas near IHW. The 2002-2018 emissions contained in the included state summaries was obtained from the EPA's state annual emission trends²⁷ and the 2028 data was obtained from the EPA's 2016v1 modeling platform that also includes 2028 modeling data²⁸.

In addition to these figures which provide confirmation of additional planned emission reductions, there are specific emission reductions that are planned prior to 2028 which will further improve the visibility in these Class I areas. Table 6-1 shows some of the upcoming emission reduction projects from states within the LADCO (IL, IN, MI, MN, and WI) except for Ohio since emission sources in Ohio are generally downwind of the affected Class I areas. In addition, many of the utility companies listed in Table 6-1 have

²⁷ [EPA Air Pollutant Emission Trends Data, State Annual Emission Trend](#)

²⁸ [EPA 2016v1 Modeling Inventory Platform FTP Reports](#)

carbon emission reduction goals beyond 2028, which will further reduce combustion and, therefore, NO_x and SO₂ emissions.

Table 6-1 Planned Emission Reduction Projects (IL, IN, MI, MN, WI) through 2028

Year	State	Company	Additional Emissions Reductions Expected/Projected
2020	IL	City Water, Light and Power	Dallman Units 31 & 32 Retirement ⁽¹⁾
2020	MI	Lansing Board of Water & Light	Eckert Plant Retirement ⁽²⁾
2021	MN	Otter Tail Power Company	Hoot Lake Plant Retirement ⁽³⁾
2021	WI	Dairyland Power Cooperative	Genoa Station No. 3 Retirement ⁽⁴⁾
2022	IL	Vistra Corp.	Edwards Plant Retirement ⁽⁵⁾
2022	MI	DTE Energy	Trenton Channel Power Plant Retirement ⁽⁶⁾
2022	MI	DTE Energy	St. Clair Power Plant Retirement ⁽⁶⁾
2022	WI	Alliant Energy	Edgewater Plant Retirement ⁽⁷⁾
2023	IL	City Water, Light and Power	Dallman Unit 33 Retirement ⁽¹⁾
2023	IN	Duke Energy	Gallagher Units 2 & 4 Retirement ⁽⁸⁾
2023	IN	Hoosier Energy	Merom Generating Station Retirement ⁽⁹⁾
2023	IN	Hoosier Energy	Transition to a more diverse generation mix including wind, solar, natural gas and storage ⁽⁹⁾
2023	IN	Indianapolis Power & Light	Petersburg Units 1 & 2 Retirement ⁽¹⁰⁾
2023	IN	NIPSCO	R.M. Schahfer Units 14, 15, 17, & 18 Retirement ⁽¹¹⁾
2023	IN	Vectren	Brown Units 1 & 2 and Culley Unit 2 Retirement ⁽¹²⁾
2023	IN	Vectren	Exit joint operations Warrick 4 coal unit ⁽¹²⁾
2023	MI	Consumers Energy	Karn Units 1 & 2 Retirement ⁽¹³⁾
2023	MI	DTE Energy	River Rouge Power Plant Retirement ⁽⁶⁾
2023	MN	Xcel Energy	Sherco Unit 2 Retirement ⁽¹⁴⁾
2025	MI	Lansing Board of Water & Light	Erickson Plant Retirement ⁽²⁾
2026	IN	Duke Energy	Gibson Unit 4 Retirement ⁽⁸⁾
2026	IN	Indiana Municipal Power Agency	Whitewater Valley Station Retirement ⁽¹⁵⁾
2026	MN	Xcel Energy	Sherco Unit 1 Retirement ⁽¹⁴⁾
2028	IN	Duke Energy	Cayuga Units 1-4 Retirement ⁽⁸⁾
2028	IN	Indiana Michigan Power	Rockport Unit 1 Retirement ⁽¹⁶⁾
2028	IN	NIPSCO	Michigan City Unit 12 Retirement ⁽¹¹⁾

Year	State	Company	Additional Emissions Reductions Expected/Projected
2028	MN	Xcel Energy	Allen S. King Plant Retirement ⁽¹⁴⁾

- (1) City Water Light and Power Integrated Resource Plan Update. Generation Unit Retirements. Public Forum Meeting. 1/29/2020.
- (2) Lansing Board of Water & Light 2020 Integrated Resource Plan
- (3) Otter Tail Power Company Application for Resource Plan Approval 2017-2031
- (4) <https://www.powermag.com/wisconsin-co-op-will-close-coal-fired-plant/>
- (5) <https://investor.vistracorp.com/investor-relations/news/press-release-details/2019/Environmental-Groups-Illinois-Power-Resources-Generating-LLC-Propose-Settlement-Agreement-to-Retire-Edwards-Coal-Plant-and-Fund-Community-Projects/default.aspx>
- (6) DTE 2019 Integrated Resource Plan Summary
- (7) <https://www.power-eng.com/2020/05/26/alliant-energy-closing-edgewater-coal-fired-plant-adding-six-solar-projects-in-wisconsin/>
- (8) Duke Energy Indiana Updated 2018 Integrated Resource Plan, 3/23/2020.
- (9) Hoosier Energy, "Hoosier Energy Announces New 20-Year Resource Plan," 01/21/2020.
<https://www.hoosierenergy.com/press-releases/hoosier-energy-announces-new-20-year-resource-plan/>
- (10) Indianapolis Power & Light Company 2019 Integrated Resource Plan
- (11) Northern Indiana Public Service Company LLC 2018 Integrated Resource Plan
- (12) Vectren 2019/2020 Integrated Resource Plan
- (13) Consumers Energy 2019 Clean Energy Plan
- (14) Xcel Energy Upper Midwest Integrated Resource Plan 2020-2034
- (15) Indiana Municipal Power Agency 2017 Integrated Resource Plan
- (16) Indiana Michigan Power Integrated Resource Planning Report, 7/1/2019.

The 2019 RH SIP Guidance says that the state will determine which emission control measures are necessary to make reasonable progress in the affected Class I areas.²⁹ However, as illustrated above, (1) the IMPROVE monitoring network data demonstrates sustained progress towards visibility goals, (2) the 5-year average visibility impairment on the most impaired days is already below the 2028 URP glidepath, and (3) additional emission reductions are already scheduled to occur.

Furthermore, additional emission reductions are already scheduled to occur. The IDEM should use the current trends of visibility improvement and the documented future emission reductions to demonstrate reasonable progress rather than imposing emissions reductions that are not cost effective in any event. The 5-year average visibility impairment on the most impaired days is already below the 2028 URP glidepath and additional emission reduction projects are scheduled to occur at other facilities with the potential to impact visibility in the affected Class I areas. Therefore, additional NO_x and SO₂ emission control measures at IHW are not required to make reasonable progress in reducing NO_x and SO₂ emissions.

6.3 Visibility Impacts in the Closest Class I Areas

The 2019 RH SIP Guidance says that a state has "reasonable discretion to consider the anticipated visibility benefits of an emission control measure along with the other factors when determining whether a

²⁹ US EPA, "Guidance on Regional Haze State Implementation Plans for the Second Implementation Period," 08/20/2019, Page 9.

measure is necessary to make reasonable progress.”³⁰ This guidance also says that “the decision-making process by a state regarding a control measure may most often depend on how the state assesses the balance between the cost of compliance and the visibility benefits.”³¹ Although IHW determined that there were no reasonable set of emission control measures for all of the associated emission units as presented in Sections 3.1.1, 4.1.1, 4.2.1, 5.1.1, and 5.2.1, Barr completed an evaluation to determine if an emissions reduction at the facility would result in visibility improvements at the nearest Class I areas.

6.3.1 BART Modeling

As part of the previous regional haze planning evaluation, and to demonstrate that the Burns Harbor facility cannot reasonably be anticipated to cause or contribute to visibility impairment in a Class I area, ArcelorMittal completed site-specific visibility modeling of Burns Harbor’s steel manufacturing operations in 2008 (see Appendix C). This effort included modeling the visibility impacts of baseline emissions (2002, 2003, and 2004 baseline periods) to determine whether the BART-eligible sources at the facility were subject to BART. According to the RHR, a facility was considered to “cause” visibility impairment if it is responsible for a 1.0 deciview change (delta-dV).³² Furthermore, a facility would be exempt from BART if its 98th percentile visibility impacts for baseline emissions are less than 0.5 delta-dv in each Class I area for each modeled year (i.e., determined to not contribute to visibility impairment).

Although the 2008 site specific BART modeling report was conducted for Burns Harbor, the IHW facility is approximately 16 miles west of Burns Harbor and, therefore is located at similar distances and locations relative to the closest Class I areas. Furthermore, the results of a long-range transport model are more dependent on the total emission rate as opposed to the individual stack parameters (velocity and temperature) and facility downwash characteristics. Thus, the modeling analysis conducted for Burns Harbor was used as an indicator of visibility impact from this facility because of the relative locations of the two facilities compared to the modeled Class I areas, and because the modeled emissions from Burns Harbor are much higher than the emissions from IHW.

The 2008 site-specific visibility modeling for Burns Harbor was conducted using CALPUFF which, at the time, was the only EPA-approved model for predicting impacts for long-range emission transport beyond 50 km. The modeling analyzed the facility’s impact on visibility impairment at the four closest Class I areas: Mammoth Cave (499 km), Seney (513 km), Mingo (561 km), and Isle Royale (699 km). All Class I areas in the analysis are further than 300 km. The distance from the Class I areas is relevant to the analysis because

³⁰ US EPA, “Guidance on Regional Haze State Implementation Plans for the Second Implementation Period,” 08/20/2019, Page 37.

³¹ US EPA, “Guidance on Regional Haze State Implementation Plans for the Second Implementation Period,” 08/20/2019, Page 37.

³² Federal Register Vol. 70, No. 128, 07/06/2005, Page 39118. (<https://www.federalregister.gov/documents/2005/07/06/05-12526/regional-haze-regulations-and-guidelines-for-best-available-retrofit-technology-bart-determinations>)

CALPUFF is known to over predict impacts beyond 300 km.³³ Thus, the results from this analysis are likely an over prediction, suggesting that the impact would be even less than reported.

EPA modeling guidance after the 2008 site-specific CALPUFF modeling suggests that photochemical modeling is the preferred method for identifying long-range transport source visibility impacts.³⁴ However, with the 2017 revisions to the *Guideline on Air Quality Models*³⁵, the EPA established the use of Lagrangian models such as CALPUFF as a very conservative screening method in order to streamline the time and resources necessary to conduct such long-range transport analyses. In addition, CALPUFF is still used as the first-level screening model by the Federal Land Managers' Air Quality Related Values Work Group (FLAG).³⁶ Thus, the results of the 2008 site-specific visibility modeling using CALPUFF are still relevant and appropriate.

The 2008 site-specific CALPUFF modeling was conducted with extremely conservative assumptions for the maximum emission rates. The modeling was conducted using the highest calculated 24-hour SO₂ and NO_x emission rates for each of the 26 emission units individually (plus 3 volume sources). This provided a fictitious worst-case scenario because a complex facility such as Burns Harbor cannot achieve the 24-hour maximum emission rates at all emission units simultaneously. Therefore, the modeled worst case scenario conservatively overestimates the impacts on the Class I areas. However, even with these conservative assumptions, the modeled visibility impact was less than 0.5 delta-dV at all Class I areas and, therefore, the facility did not contribute a perceptible³⁷ amount to visibility impairment and was exempt from BART.

The current emissions of SO₂ and NO_x from IHW are significantly less than the conservatively high emission rates which were used in the Burns Harbor 2008 CALPUFF modeling. Therefore, the current visibility impacts from IHW would be even less than that concluded in the 2008 report.

CAMx modeling is also underway to further support this analysis. CAMx modeling for 2028 is planned to further support this analysis based on LADCO's 2016 base year emission inventory. The CAMx analysis is being conducted to calculate the individual facility impact on downwind Class I areas of interest. It includes full atmospheric chemistry and national emissions to best approximate the concentrations of pollutants in the Class I areas to allow for the calculation of specific impacts. IHW reserves the right to amend and/or supplement this analysis once CAMx modeling has been completed, and which is similarly not expected to show a perceptible visibility impact from IHW, even on the most impaired days.

³³ Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 Summary Report and Recommendations for Modeling Long Range Transport Impacts, Page 18. (<https://www3.epa.gov/scram001/7thconf/calpuff/phase2.pdf>)

³⁴ CALPUFF Regulatory Status, <http://www.src.com/calpuff/regstat.htm>

³⁵ Appendix W to 40 CFR Part 51

³⁶ 2010 FLAG Phase I Report Revised, <https://irma.nps.gov/DataStore/DownloadFile/420352>, October 2010, Page 23.

³⁷ Federal Register Vol. 70, No. 128, 07/06/2005, Page 39119. (<https://www.federalregister.gov/documents/2005/07/06/05-12526/regional-haze-regulations-and-guidelines-for-best-available-retrofit-technology-bart-determinations>)

6.3.2 Mammoth Cave and Mingo Trajectory Analysis

Consistent with the EPA Guidance on Regional Haze SIPs for the Second Implementation Plan, the VISTAS³⁸ and CENRAP³⁹ multi-state collaboratives developed tools that were used by their respective states to screen out sources from further analyses (i.e., the four-factor analysis). These analyses could be conducted using different approaches, including emissions / distance (Q/d), trajectory analyses to determine the likelihood of impact from sources on visibly impaired days, residence time analyses which was typically a more refined trajectory analyses, and/or photochemical grid modeling techniques.

In May 2020, Jim Boylan of the Georgia Department of Natural Resources provided a project update to VISTAS.⁴⁰ This update provides additional information related to IHW and the lack of impact on Mammoth Cave (499 km). As described in the project update, VISTAS performed a reasonable progress screening approach using a 2028-emission based Area of Influence (AOI) trajectory/residence time analysis and a Particulate Matter Source Apportionment Technology (PSAT) individual source evaluation for a number of Class I areas in the southeast and other Class I areas that could be impacted by VISTAS states' sources.

For the AOI trajectory analysis, the state of Kentucky used a threshold of 2% for sulfate or nitrate contribution to visibility impact at Mammoth Cave (499 km). Generally, the analysis evaluated 72-hour back trajectories on 20% most impaired days at each area and was used to identify facilities that were in the path of the trajectory to see how frequently their emissions potentially impacted the Class I area. Based on those analyses performed by VISTAS for Mammoth Cave (499 km), there were five sources in Indiana that were flagged for further analyses using photochemical modeling (i.e., flagged for the PSAT modeling analysis). IHW was not identified in the AOI analysis as each of the flagged facilities were electric generating units. The VISTAS findings indicate that no additional analyses are necessary for IHW as it was not included as a specifically "flagged" source in the PSAT modeling analysis.

Similarly, CENRAP also conducted AOI trajectory/residence time visibility impact analysis to screen out sources from further visibility analyses. The details of this analysis are described in documents obtained from the CENSARA website⁴¹. The level of detailed provided by CENRAP allows for a specific evaluation of the impacts from IHW when compared to the state-selected threshold of 1% visibility culpability at Mingo in southeastern Missouri (561 km). The Missouri Department of Natural Resources used this 1% threshold (combined nitrate and sulfate) from the trajectory / residence time analysis to identify sources for further evaluation. Based on this analysis, IHW did not exceed the 1% threshold as shown in Table 6-2.

³⁸ Visibility Improvement State and Tribal Association of the Southeast (VISTAS), <https://www.metro4-sesarm.org/>.

³⁹ Central Regional Air Planning Association (CENRAP), <https://www.cenrap.org/>.

⁴⁰ Jim Boylan - Georgia Department of Natural Resources, "VISTAS Regional Haze Project Update," 5/20/2020. (<https://www.metro4-sesarm.org/sites/default/files/VISTAS%20Pres%20Stakeholders%20Final%20200520.pdf>)

⁴¹ Central States Air Resources Agencies (CenSARA), "Determining Areas of Influence – CenSARA Round Two Regional Haze", November 2018, <https://censara.org/ftpfiles/Ramboll/>.

Table 6-2 Sulfate and Nitrate Culpability at Mingo National Wildlife Refuge

Facility	Sulfate Culpability	Nitrate Culpability	Sulfate + Nitrate Culpability
Indiana Harbor (East and West, combined)	0.07%	0.16%	0.09%

The CENRAP findings indicate that no additional analyses are necessary for either of the ArcelorMittal Indiana Harbor facilities as the combined impact from the facilities was less than the 1% threshold for sulfate plus nitrate culpability.

6.3.3 Seney and Isle Royale Back Trajectory Analysis

In addition to the screening approach completed using the CENRAP AOI trajectories, Barr completed a specific set of reverse particle trajectory analyses from Seney (513 km) and Isle Royale (699 km) to determine if emissions from IHW could be contributing to visibility impacts in these Class I areas on the most impaired days. These analyses could also be used to determine if emission reductions at IHW could result in visibility improvement on the most impaired days at these Class I areas.

A trajectory analysis considers the transport path of a particular air mass and the associated particles within the air mass to see if the air mass traveled over certain locations within a specified time range. A reverse trajectory analysis was performed beginning at each Class I area for the most impaired days during 2017-2018. The impairment metric (dv) from the IMPROVE Aerosol RHR III dataset⁴² was used to calculate the 20% most impaired days for 2017 and 2018. The NOAA Hysplit model⁴³ was used to calculate 48-hour reverse trajectories beginning at 6:00 PM at a height of 10m from each Class I area on the day from the calculated 20% most impaired days (“the most impaired trajectories”). This methodology was modeled after the Minnesota Pollution Control Agency’s trajectory analysis for their Class I areas.⁴⁴

The analysis considered the 20% most impaired trajectories for each Class 1 area based on 2017 and 2018 IMPROVE data. The data set is generated by monitoring every third day. As shown in Figure 6–8 and Figure 6–9, only one of the most impaired trajectories crosses near IHW for Seney (513 km) and none of the most impaired trajectories passes near IHW for Isle Royale (699 km). In addition, these figures

⁴² Malm, W. C., J. F. Sisler, D. Huffman, R. A. Eldred, and T. A. Cahill (1994), Spatial and seasonal trends in particle concentration and optical extinction in the United States, J. Geophys. Res., 99, 1347-1370.
<http://views.cira.colostate.edu/fed/SiteBrowser/Default.aspx>

⁴³ Stein, A.F., Draxler, R.R, Rolph, G.D., Stunder, B.J.B., Cohen, M.D., and Ngan, F., (2015). NOAA's HYSPLIT atmospheric transport and dispersion modeling system, Bull. Amer. Meteor. Soc., 96, 2059-2077, <http://dx.doi.org/10.1175/BAMS-D-14-00110.1>

⁴⁴ MPCA – Regional Haze Tableau Public.
https://public.tableau.com/profile/mpca.data.services#!/vizhome/RegionalHaze_visibility_metrics_public/Visibilityprogress

illustrate that the majority of the most impaired trajectories are not traveling from the general direction of IHW or the greater Chicago area. Furthermore, most of the 48-hour reverse trajectories end before reaching IHW and the greater Chicago area, indicating that Seney (513 km) and Isle Royale (699 km) are at a distance far enough away from the facility that a perceptible visibility impairment from the IHW facility is extremely unlikely. These figures also demonstrate that sources from other regions, and not IHW, are contributing to the visibility on the most impaired days at the monitors.





Figure 6–8 Seney National Wildlife Refuge: Most Impaired Trajectories for 2017-2018 from Reverse Trajectory Analysis



Note: ISLE1 IMPROVE Monitor is located at Eagle Harbor due to year-round accessibility purposes.

Figure 6–9 Isle Royale National Park: Most Impaired Trajectories for 2017-2018 from Reverse Trajectory Analysis

6.3.4 Visibility Impacts Conclusion

Based on the previous conservative BART modeling, the screening analyses conducted by VISTAS (Mammoth Cave (499 km)) and CENRAP (Mingo (561 km)), the culpability screening analyses for Seney (513 km) and Isle Royale (699 km), and the back trajectory analyses for Seney (513 km) and Isle Royale (699 km), Barr concludes that emissions from IHW are not a contributor to perceptible visibility impairment on the most impaired days at the closest Class I areas. Thus, additional control measures implemented at the facility are unlikely to provide any improvement in perceptible visibility on the most impaired days and do not support imposing emissions reductions that are not cost effective in any event.

7 Conclusion

The four-factor analyses with visibility benefits evaluations for the Basic Oxygen Furnaces (NO_x, Section 3.1), the Boiler House - #8 Boiler (S8G) (NO_x, Section 4.1; SO₂, Section 4.2), and the H-3 and H-4 Blast Furnace (NO_x, Section 5.1; SO₂, Section 5.2), concluded that:

- There is no reasonable set of NO_x and SO₂ emission control measures beyond what is currently installed and operated for these emission units. The reasonable set of additional NO_x and SO₂ emission control measures is not technically feasible for these emission units.
- Therefore, the existing NO_x and SO₂ emission performance for these emission units are sufficient for the IDEM's regional haze reasonable progress goal.

Appendix A

RBLC Search Summary for Pertinent Emission Units at Similar Sources

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix A: EPA RACT BACT LAER Clearinghouse Data
Basic Oxygen Furnace (BOF)

Nitrogen Oxides (NOx)

NOTE: Draft determinations are marked with a " * " beside the RBLC ID.

RBLCID	FACILITY NAME	CORPORATE OR COMPANY NAME	FACILITY STATE	PERMIT NUM	NAICS CODE	PERMIT DATE	FACILITY DESCRIPTION	Process Name	Fuel	Through-put	UNITS	Pollutant	Emission Control Description	Emission Limit 1	Limits Units 1	Avg Time	CASE-BY-CASE BASIS	Emission Limit 2	Limits Units2	Avg Time2	Standard Emission Limit	Standard Limit Units	Standard Limit Avg Time
OH-0292	WHEELING PITTSBURGH STEEL CORPORATION	WHEELING PITTSBURGH STEEL CORPORATION	OH	06-07507	331110	1/6/2005	STEEL MANUFACTURING	BASIC OXYGEN FURNACES (2 VESSELS), FUGITIVE		375	t/h	Nitrogen Oxides (NOx)		7.5	LB/H		BACT-PSD	16.4	T/YR		0		
OH-0292	WHEELING PITTSBURGH STEEL CORPORATION	WHEELING PITTSBURGH STEEL CORPORATION	OH	06-07507	331110	1/6/2005	STEEL MANUFACTURING	BASIC OXYGEN FURNACE (2 VESSELS) SCRUBBER		375	t/h	Nitrogen Oxides (NOx)		30	LB/H		BACT-PSD	56.6	T/YR		0		

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix A: EPA RACT BACT LAER Clearinghouse Data
Gas Fired Boilers

Nitrogen Oxides (NOx)

NOTE: Draft determinations are marked with a " * " beside the RBLC ID.

RBLCID	FACILITY NAME	CORPORATE OR COMPANY NAME	FACILITY STATE	PERMIT NUM	NAICS CODE	PERMIT DATE	FACILITY DESCRIPTION	Process Name	Fuel	Through-put	UNITS	Pollutant	Emission Control Description	Emission Limit 1	Limits Units 1	Avg Time	CASE-BY-CASE BASIS	Emission Limit 2	Limits Units2	Avg Time2	Standard Emission Limit	Standard Limit Units	Standard Limit Avg Time
*LA-0346	GULF COAST METHANOL COMPLEX	IGP METHANOL LLC	LA	PSD-LA-820	325199	01/04/2018 ACT	proposed facility to produce 20,000 metric tons of methanol per day	Auxiliary Boiler	natural gas	773	mm btu/hr	Nitrogen Oxides (NOx)	LNB + FGR	0			BACT-PSD	0			0		
MD-0044	COVE POINT LNG TERMINAL	DOMINION COVE POINT LNG, LP	MD	PSC CASE NO. 9318	221119	06/09/2014 ACT	LIQUIFIED NATURAL GAS PROCESSING FACILITY AND 130 MEGAWATT GENERATING STATIONFACILITY-WIDE PM10 EMISSION LIMIT = 124.2 TONS/YR FACILITY-WIDE PM2.5 EMISSION LIMIT= 124/2 TONS/YR	2 AUXILIARY BOILERS	PROCESS GAS	435	MMBTU/H	Nitrogen Oxides (NOx)	EXCLUSIVE USE OF FACILITY PROCESS FUEL GAS DURING NORMAL OPERATION AND USE OF A POST-COMBUSTION SCR SYSTEM AND LOW-NOX BURNERS	0.0099	LB/MMBTU	3-HOUR BLOCK AVERAGE, EXCLUDING SU/SD	LAER	2946.2	LB/EVENT	FOR ALL STARTUPS	0		
AK-0083	KENAI NITROGEN OPERATIONS	AGRIUM U.S. INC.	AK	AQ0083CPT06	325311	01/06/2015 ACT	The Kenai Nitrogen Operations Facility is located at Mile 21 of the Kenai Spur Highway, near Kenai Alaska. It is classified as a nitrogenous fertilizer manufacturing facility under Standard Industrial Classification code 2873 and under North American Industrial	Three (3) Package Boilers	Natural Gas	243	MMBTU/H	Nitrogen Oxides (NOx)	Ultra Low NOx Burners	0.01	LB/MMBTU	30-DAY AVERAGE	BACT-PSD	0			0		
TX-0656	GAS TO GASOLINE PLANT	NATGASOLINE	TX	PSDTX1340 AND 107764	325199	05/16/2014 ACT	Chemical Plant	Boiler	natural gas and fuel gas	950	MMBTU/H	Nitrogen Oxides (NOx)	SCR	0.01	LB/MMBTU		BACT-PSD	0			0		
TX-0659	DEER PARK PLANT	ROHM AND HAAS TEXAS INC	TX	PSDTX1320, 2165	325188	12/20/2013 ACT		Boiler	Natural gas	515	MMBTU/H	Nitrogen Oxides (NOx)	Selective catalytic reduction	0.01	LB/MMBTU	1-HR	BACT-PSD	0			0		
TX-0698	BAYPORT COMPLEX	AIR LIQUIDE LARGE INDUSTRIES U.S., L.P.	TX	9346 PSDTX612M2	325120	09/05/2013 ACT	Air Liquid currently operates a cogeneration facility in Pasadena, Texas (Bayou Cogeneration Plant). The permit amendment submitted by Air Liquide will authorize a redevelopment project of its cogeneration plant. The proposed project will involve the	(3) gas-fired boilers	natural gas	550	MMBTU/H	Nitrogen Oxides (NOx)	Selective Catalytic Reduction (SCR)	0.01	LB/MMBTU	3 HOUR ROLLING AVERAGE	BACT-PSD	0			0		
TX-0704	UTILITY PLANT	M & G RESINS USA LLC	TX	108819 PSDTX1354	221112	12/02/2014 ACT	In support of the new PET (polyethylene terephthalate) unit and new PTA (terephthalic acid) plant proposed by M&G Resins USA LLC, the company also proposes a Utility Plant that will consist of either one of two options. All steam generated from the Utility Plant will be	(2) boilers	natural gas	450	MMBTU/H	Nitrogen Oxides (NOx)	Selective Catalytic Reduction	0.01	LB/MMBTU	3-HR ROLLING AVERAGE	BACT-PSD	0			0		
TX-0704	UTILITY PLANT	M & G RESINS USA LLC	TX	108819 PSDTX1354	221112	12/02/2014 ACT	In support of the new PET (polyethylene terephthalate) unit and new PTA (terephthalic acid) plant proposed by M&G Resins USA LLC, the company also proposes a Utility Plant that will consist of either one of two options. All steam generated from the Utility Plant will be	boiler	natural gas	250	MMBTU/H	Nitrogen Oxides (NOx)	Selective Catalytic Reduction	0.01	LB/MMBTU	3-HR ROLLING AVERAGE	BACT-PSD	0			0		
TX-0707	CHEMICAL MANUFACTURING FACILITY	ROHM AND HAAS TEXAS INCORPORATED	TX	2165 PSDTX1320	325110	12/20/2013 ACT	RH is proposing to install two 515 million British thermal unit per hour (MMBtu/hr) gas-fired boilers to produce additional steam for the RH Texas Deer Park Plant manufacturing facilities and give the plant the ability to perform planned maintenance on other steam	(2) boilers	natural gas	515	MMBTU/H	Nitrogen Oxides (NOx)	Selective Catalytic Reduction	0.01	LB/MMBTU	1 HOUR	BACT-PSD	0			0		
WY-0074	GREEN RIVER SODA ASH PLANT	SOLVAY CHEMICALS	WY	MD-13083	212391	11/18/2013 ACT	Trona Mine and Refinery	Natural Gas Package Boiler	Natural Gas	254	MMBTU/H	Nitrogen Oxides (NOx)	low NOx burners and flue gas recirculation	0.011	LB/MMBTU	30-DAY ROLLING	BACT-PSD	2.8	LB/H	30-DAY ROLLING	0		
*FL-0330	PORT DOLPHIN ENERGY LLC		FL	DPA-EPA-R4001	213112	12/01/2011 ACT	Port Dolphin is a deepwater port designed to moor liquefied natural gas shuttle and regasification vessels 28 miles off the cost of Florida.	Boilers (4 - 278 mmbtu/hr each)	natural gas	0		Nitrogen Oxides (NOx)	Selective Catalytic Reduction (SCR)	0.012	LB/MMBTU	3-HOUR ROLLING AVERAGE	BACT-PSD	0			0		
IL-0114	CRONUS CHEMICALS, LLC	CRONUS CHEMICALS, LLC	IL	13060007	325311	09/05/2014 ACT	Plant will produce urea and ammonia, but ammonia production will be limited to a maximum of 3 months of the year (4,880 tpd urea and 2,789 tpd ammonia).	Boiler	natural gas	864	MMBTU/H	Nitrogen Oxides (NOx)	low-nox burners, scr (or equivalent)	0.012	LB/MMBTU	30-DAY AVERAGE ROLLED DAILY	BACT-PSD	0			0		
IA-0105	IOWA FERTILIZER COMPANY	IOWA FERTILIZER COMPANY	IA	12-219	325311	10/26/2012 ACT	NITROGENEOUS FERTILIZER MANUFACTURING	Auxiliary Boiler	natural gas	472.4	MMBTU/H	Nitrogen Oxides (NOx)	Low NOx Burners (LNB) and Flue Gas Recirculation (FGR)	0.0125	LB/MMBTU	ROLLING 30 DAY AVERAGE	BACT-PSD	5.52	TONS/YR	ROLLING 12 MONTH TOTAL	0		
IN-0166	INDIANA GASIFICATION, LLC	INDIANA GASIFICATION, LLC	IN	T147-30464-00060	221210	06/27/2012 ACT	THE PERMITTEE OWNS AND OPERATES A STATIONARY SUBSTITUTE NATURAL GAS (SNG) AND LIQUEFIED CARBON DIOXIDE (CO2) PRODUCTION PLANT	TWO (2) AUXILIARY BOILERS	NATURAL GAS	408	MMBTU/H, EACH	Nitrogen Oxides (NOx)	ULTRA LOW NOX BURNER WITH FGR	0.0125	LB/MMBTU	24 HR	BACT-PSD	0			0		
LA-0305	LAKE CHARLES METHANOL FACILITY	LAKE CHARLES METHANOL, LLC	LA	PSD-LA-803(M1)	325199	06/30/2016 ACT	Proposed facility to produce methanol, H2, H2SO4, CO2, Argon and electricity from Pet Coke	Auxiliary Boilers and Superheaters	Natural Gas	0		Nitrogen Oxides (NOx)	SCR	0.015	LBS/MM BTU	30 ROLLING AVG., EXCEPT SCR SU OR MAINT.	BACT-PSD	0			0		
*TX-0888	ORANGE POLYETHYLENE PLANT	CHEVRON PHILLIPS CHEMICAL COMPANY LP	TX	155952 PSDTX1556 GHGSPDTX192	325211	04/23/2020 ACT	An initial NSR, PSD, and GHG project to construct and operate an Olefins Unit, two Polyethylene (PE) Units, and auxiliary support facilities. This permit will consist of furnaces, boilers, heaters, storage tanks, emergency engines, fugitive piping, thermal oxidizers, flares,	BOILERS	Natural gas, ethane, fuel, or vent gas	250	MMBTU	Nitrogen Oxides (NOx)	SCR	0.015	LB/MMBTU	HOURLY	BACT-PSD	0.01	LB/MMBTU	ANNUAL	0		
DE-0020	VALERO DELAWARE CITY REFINERY	VALERO ENERGY CORP	DE	AQM-003/00016	324110	02/26/2010 ACT	191,100 BARREL PER DAY REFINERY AKA THE PREMCOR REFINING GROUP INC.	PACKAGE BOILERS (2009)	REFINERY FUEL GAS	99.9	MMBTu per hour	Nitrogen Oxides (NOx)	SCR AND LOW NOX BURNERS	0.015	LB/MMBTU		RACT	0			0		
DE-0020	VALERO DELAWARE CITY REFINERY	VALERO ENERGY CORP	DE	AQM-003/00016	324110	02/26/2010 ACT	191,100 BARREL PER DAY REFINERY AKA THE PREMCOR REFINING GROUP INC.	DCPP BOILER 1	REFINERY FUEL GAS	618	MMBTU/H	Nitrogen Oxides (NOx)	SCR WITH MODIFICATIONS TO EXISTING BURNERS AND AIR DISTRIBUTION TO BURNERS, OPTIMIZATION TO OVER-FIRE AIR SYSTEMS, INSTALLATION OF INDUCED FLUE	0.015	LB/MMBTU	24-HOUR ROLLING AVERAGE	BACT-PSD	40.6		12-MONTHS	0		
DE-0020	VALERO DELAWARE CITY REFINERY	VALERO ENERGY CORP	DE	AQM-003/00016	324110	02/26/2010 ACT	191,100 BARREL PER DAY REFINERY AKA THE PREMCOR REFINING GROUP INC.	DCPP BOILER 3	REFINERY FUEL GAS	618	MMBTU/H	Nitrogen Oxides (NOx)	SCR WITH MODIFICATIONS TO EXISTING BURNERS AND AIR DISTRIBUTION TO BURNERS, OPTIMIZATION TO OVER-FIRE AIR SYSTEMS, INSTALLATION OF INDUCED FLUE	0.015	LB/MMBTU	24-HOUR ROLLING AVERAGE	BACT-PSD	40.6	T	12-MONTHS	0		
TX-0763	BORGER REFINERY	PHILLIPS 66 COMPANY	TX	85872, PSDTX1158M1, GHGSPDTX13	324110	09/04/2015 ACT	The refinery processes crude oil and other feedstocks into products including gasoline, furnace oil, jet fuels, kerosene, petrochemicals, and blendstocks for liquid fuels.	Utility and Industrial Boiler greater than 250 million British	refinery fuel	560	MMBTU/H	Nitrogen Oxides (NOx)	SCR	0.015	LB/MMBTU		BACT-PSD	0			0		
TX-0763	BORGER REFINERY	PHILLIPS 66 COMPANY	TX	85872, PSDTX1158M1, GHGSPDTX13	324110	09/04/2015 ACT	The refinery processes crude oil and other feedstocks into products including gasoline, furnace oil, jet fuels, kerosene, petrochemicals, and blendstocks for liquid fuels.	Utility and Industrial Boiler greater than 250 million British	refinery fuel	364.6	MMBTU/H	Nitrogen Oxides (NOx)	selective catalytic reduction (SCR)	0.015	LB/MMBTU		BACT-PSD	0			0		
ND-0032	SPIRITWOOD NITROGEN PLANT	CHS, INC.	ND	PTC14027	325311	06/20/2014 ACT	Fertilizer manufacturing plant to manufacture nitrogen-based products ammonia, urea, urea ammonium nitrate (UAN) and diesel exhaust fluid. The facility will produce both feedstock and saleable products in the following capacities: 2,425 tpd ammonia; 3,000 tpd	Package boiler	Natural gas	280	MMBTU/H	Nitrogen Oxides (NOx)	ultra low NOx burners and flue gas recirculation	0.018	LB/MMBTU	30 DAY ROLLING AVERAGE	BACT-PSD	0			0		

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix A: EPA RACT BACT LAER Clearinghouse Data
Gas Fired Boilers

Nitrogen Oxides (NOx)

NOTE: Draft determinations are marked with a " * " beside the RBLC ID.

RBLCID	FACILITY NAME	CORPORATE OR COMPANY NAME	FACILITY STATE	PERMIT NUM	NAICS CODE	PERMIT DATE	FACILITY DESCRIPTION	Process Name	Fuel	Through-put	UNITS	Pollutant	Emission Control Description	Emission Limit 1	Limits Units 1	Avg Time	CASE-BY-CASE BASIS	Emission Limit 2	Limits Units2	Avg Time2	Standard Emission Limit	Standard Limit Units	Standard Limit Avg Time
*ND-0033	GRAND FORKS FERTILIZER PLANT	NORTHERN PLAINS NITROGEN	ND	PTC15052	325311	08/10/2015 ACT	Fertilizer manufacturing plant designed to produce both feedstock and saleable products in the following nominal capacities: 2425 tpd ammonia, 2540 tpd ammonium nitrate solution, 300 tpd DEF, 3000 tpd urea solution, 3000 tpd granular urea, 2000 tpd nitric acid, 5620	Boilers	Natural gas	187.5	MMBTU/H	Nitrogen Oxides (NOx)	Ultra Low NOx Burners and Flue Gas Recirculation	0.018	LB/MM BTU	30 DAY ROLLING AVERAGE	BACT-PSD	0			0		
AL-0271	GEORGIA PACIFIC BRETON LLC	GEORGIA PACIFIC LLC	AL	502-0001-X049	322130	06/11/2014 ACT	Kraft Pulp & Paper mdu	No.4 Power Boiler	Natural Gas	425	MMBTU/H	Nitrogen Oxides (NOx)	Low NOx Burner with FGR	0.02	LB/MMBTU		BACT-PSD	8.5	LB/H		0		
DE-0020	VALERO DELAWARE CITY REFINERY	VALERO ENERGY CORP	DE	AQM-003/00016	324110	02/26/2010 ACT	191,100 BARREL PER DAY REFINERY AKA THE PREMCOR REFINING GROUP INC.	PACKAGE BOILERS (2004)	REFINERY FUEL GAS	216	MMBtu per hour	Nitrogen Oxides (NOx)		0.02	LB/MMBTU	3-HR AVERAGE	RACT	24.9	T	12 MONTHS	0		
OH-0378	PTTGCA PETROCHEMICAL COMPLEX	PTTGCA PETROCHEMICAL COMPLEX	OH	P0124972	325110	12/21/2018 ACT	Petrochemical Complex	Natural Gas and Ethane-Fired Steam Boilers (8007 - 8009)	Natural gas and ethane	400	MMBTU/H	Nitrogen Oxides (NOx)	ultra-low NOx burners (ULNB) and flue gas recirculation (FGR)	0.02	LB/MMBTU	DURING STARTUP AND SHUTDOWN. SEE NOTES.	BACT-PSD	4	LB/H	AS ROLLING 30-DAY AVG. SEE NOTES.	0.01	LB/MMBTU	AS ROLLING 30-DAY AVG. SEE NOTES.
TX-0776	BISHOP FACILITY	TICONA POLYMERS, INC.	TX	123077, PSDTX1436, AND GHGSPDT	324199	11/12/2015 ACT	The three new boilers will provide steam to existing steam users at the Bishop Site and to a new Methanol Unit Project proposed in a concurrent air permit application (Permit No. 123216 and PSDTX1438). The new Boiler Project will authorize construction and	Boiler	natural gas	452	MMBTU/H	Nitrogen Oxides (NOx)	Selective Catalytic Reduction, Low NOx Burners, Flue Gas Recirculation	0.02	PPM	1-HR AVG	BACT-PSD	0.01	PPM	ROLLING MONTHLY AVERAGE	0		
FL-0344	OKEELANTA COGENERATION PLANT	NEW HOPE POWER COMPANY	FL	0990332-021-AC	221119	08/27/2013 ACT	Cogeneration facility, fired with bagasse, wood, and natural gas. Four boilers, total electrical generating capacity of 140 MW. Also generates steam for co-located sugar refinery and sugar mill.	Natural Gas Boiler	Natural gas	589	MMBTU/H	Nitrogen Oxides (NOx)	Ultra-low NOx burners with over-fire air	0.035	LB/MMBTU	30-DAY ROLLING AVERAGE BY CEMS	BACT-PSD	18.8	LB/H	30-DAY ROLLING AVERAGE BY CEMS	0		
LA-0323	MONSANTO LULING PLANT	MONSANTO COMPANY	LA	PSD-LA-890	325320	01/09/2017 ACT	Chemical Manufacture	No. 9 Boiler - Natural Gas Fired	Natural Gas	325	MMBTU/h	Nitrogen Oxides (NOx)	Ultra Low NOx Burners	0.035	LB/MMBTU	ANNUAL AVERAGE	BACT-PSD	0			0		
LA-0323	MONSANTO LULING PLANT	MONSANTO COMPANY	LA	PSD-LA-890	325320	01/09/2017 ACT	Chemical Manufacture	No. 10 Boiler - Natural Gas Fired	Natural Gas	325	MMBTU/h	Nitrogen Oxides (NOx)	Ultra Low NOx Burners	0.035	LB/MMBTU	ANNUAL AVERAGE	BACT-PSD	0			0		
*MI-0440	MICHIGAN STATE UNIVERSITY	MICHIGAN STATE UNIVERSITY	MI	139-18	611310	05/22/2019 ACT	New natural gas electric and steam generation.	EUSTMBOILER	natural gas	300	MMBTU/H	Nitrogen Oxides (NOx)	Low-NOx burners and internal flue gas recirculation (FGR)	0.04	LB/MMBTU	30 DAY ROLL AVG WHEN FIRING NAT. GAS	BACT-PSD	0.07	LB/MMBTU	30 DAY ROLL AVG WHEN FIRING NO2 FUEL OIL	0		
NE-0054	CARGILL, INCORPORATED	CARGILL, INCORPORATED	NE	12-042	311221	09/12/2013 ACT		Boiler K	natural gas	300	mmbtu/h	Nitrogen Oxides (NOx)	LOW NOX BURNERS AND INDUCED FLUE GAS RECIRCULATION	0.04	LB/MMBTU	30-DAY ROLLING AVERAGE	BACT-PSD	12	LB/H	3-HOUR ROLLING AVERAGE	0		
TX-0763	BORGER REFINERY	PHILLIPS 66 COMPANY	TX	85872, PSDTX1158M1, GHGSPSDTX13	324110	09/04/2015 ACT	The refinery processes crude oil and other feedstocks into products including gasoline, furnace oil, jet fuels, kerosene, petrochemicals, and blendstocks for liquid fuels.	Utility and Industrial Boiler greater than 250 million British	refinery fuel	462.3	MMBTU/H	Nitrogen Oxides (NOx)		0.04	LB/MMBTU		BACT-PSD	0			0		
IN-0234	GRAIN PROCESSING CORPORATION	GRAIN PROCESSING CORPORATION	IN	027-35177-00046	311221	12/08/2015 ACT	THIS FACILITY IS A STATIONARY CORN WET MILLING PLANT.	BOILER 1	NATURAL GAS	271	MMBTU/H	Nitrogen Oxides (NOx)	LOW-NOX BURNER AND FLUE GAS RECIRCULATION SYSTEM	0.05	LB/MMBTU	NORMAL OPERATION	BACT-PSD	0.2	LB/MMBTU	DURING SSM	0		
IN-0234	GRAIN PROCESSING CORPORATION	GRAIN PROCESSING CORPORATION	IN	027-35177-00046	311221	12/08/2015 ACT	THIS FACILITY IS A STATIONARY CORN WET MILLING PLANT.	BOILER 2	NATURAL GAS	271	MMBTU/H	Nitrogen Oxides (NOx)	LOW-NOX BURNERS AND FLUE GAS RECIRCULATION	0.05	LB/MMBTU	NORMAL OPERATION	BACT-PSD	0.2	LB/MMBTU	DURING SSM	0		
OH-0368	PALLAS NITROGEN LLC	PALLAS NITROGEN LLC	OH	P0118959	325311	04/19/2017 ACT	Natural gas-based facility for the manufacture of nitrogenous products.	Package Boilers (2 identical, B003 and B004)	Natural gas	265	MMBTU/H	Nitrogen Oxides (NOx)	Low NOx burners and flu gas recirculation (FGR)	3.3	LB/H		BACT-PSD	14.5	T/YR	PER ROLLING 12 MONTH PERIOD	0.0125	LB/MMBTU	
*LA-0312	ST. JAMES METHANOL PLANT	SOUTH LOUISIANA METHANOL LP	LA	PSD-LA-780(M-1)	325998	06/30/2017 ACT	New MeOH plant designed to produce 5,275 metric tons per day of refined methanol from natural gas and carbon dioxide (CO2) feedstock	81-13 - Boiler 1 (EQT0003)	Natural Gas	350	MM BTU/hr	Nitrogen Oxides (NOx)	Selective Catalytic Reduction, Low NOx Burners, & Good Combustion Practices	3.5	LB/HR		BACT-PSD	0.01	LB/MMMTU	12 MONTH AVERAGE	0		
*LA-0312	ST. JAMES METHANOL PLANT	SOUTH LOUISIANA METHANOL LP	LA	PSD-LA-780(M-1)	325998	06/30/2017 ACT	New MeOH plant designed to produce 5,275 metric tons per day of refined methanol from natural gas and carbon dioxide (CO2) feedstock	82-13 - Boiler 2 (EQT0004)	Natural Gas	350	MM BTU/hr	Nitrogen Oxides (NOx)	Selective Catalytic Reduction, Low NOx Burners, & Good Combustion Practices	3.5	LB/HR		BACT-PSD	0.01	LB/MMBTU	12-MONTH AVERAGE	0		
*LA-0315	G2G PLANT	BIG LAKE FUELS LLC	LA	PSD-LA-781	325110	05/23/2014 ACT	The G2G Plant will be a natural gas to gasoline production facility which will use natural gas to produce methanol that will be subsequently converted into gasoline.	Utility Boiler 1	Natural Gas	656	MMBTU/HR	Nitrogen Oxides (NOx)	Selective Catalytic Reduction (SCR)	3.94	LB/H	HOURLY MAXIMUM	BACT-PSD	17.25	T/YR	ANNUAL MAXIMUM	0.2	LB/MMBTU	30-DAY ROLLING AVERAGE
*LA-0315	G2G PLANT	BIG LAKE FUELS LLC	LA	PSD-LA-781	325110	05/23/2014 ACT	The G2G Plant will be a natural gas to gasoline production facility which will use natural gas to produce methanol that will be subsequently converted into gasoline.	Utility Boiler 2	Natural Gas	656	MMBTU/HR	Nitrogen Oxides (NOx)	Selective Catalytic Reduction (SCR)	3.94	LB/H	HOURLY MAXIMUM	BACT-PSD	17.25	T/YR	ANNUAL MAXIMUM	0.2	LB/MMBTU	30-DAY ROLLING AVERAGE
*LA-0315	G2G PLANT	BIG LAKE FUELS LLC	LA	PSD-LA-781	325110	05/23/2014 ACT	The G2G Plant will be a natural gas to gasoline production facility which will use natural gas to produce methanol that will be subsequently converted into gasoline.	Utility Boiler 3	Natural Gas	656	MMBTU/HR	Nitrogen Oxides (NOx)	Selective Catalytic Reduction (SCR)	3.94	LB/H	HOURLY MAXIMUM	BACT-PSD	17.25	T/YR	ANNUAL MAXIMUM	0.2	LB/MMBTU	30-DAY ROLLING AVERAGE
TX-0803	PL PROPYLENE HOUSTON OLEFINS PLANT	FLINT HILLS RESOURCES HOUSTON CHEMICAL LLC	TX	18999, PSDTX755M1, N216	325110	07/12/2016 ACT	catalytic process to produce propylene from propane and mixed propane/propylene feed	Waste Heat Boiler	natural gas	1690	MMBTU/H	Nitrogen Oxides (NOx)	selective catalytic reduction	5	PPMVD @ 15% O2	12-MONTH AVG	LAER	9	PPMVD @ 15% O2	3-HR AVERAGE	0		
AK-0083	KENAI NITROGEN OPERATIONS	AGRIUM U.S. INC.	AK	AQ0083CPT06	325311	01/06/2015 ACT	The Kenai Nitrogen Operations Facility is located at Mile 21 of the Kenai Spur Highway, near Kenai Alaska. It is classified as a nitrogenous fertilizer manufacturing facility under Standard Industrial Classification code 2873 and under North American Industrial	Five (5) Waste Heat Boilers	Natural Gas	50	MMBTU/H	Nitrogen Oxides (NOx)	Selective Catalytic Reduction	7	PPMV	3-HR AVG @ 15 % O2	BACT-PSD	0			0		
CA-1214	GROSSMONT HOSPITAL	GROSSMONT HOSPITAL	CA	2012-APP-002050	622110	11/06/2012 ACT		Two 29.4 MMBtu/hr Boilers with low NOx burners	natural gas	0		Nitrogen Oxides (NOx)	Low NOx burners	9	PPMVD@3% O2	1 HOUR	OTHER CASE-BY CASE	0			0		

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix A: EPA RACT BACT LAER Clearinghouse Data
Gas Fired Boilers

Nitrogen Oxides (NOx)

NOTE: Draft determinations are marked with a " * " beside the RBLC ID.

RBLCID	FACILITY NAME	CORPORATE OR COMPANY NAME	FACILITY STATE	PERMIT NUM	NAICS CODE	PERMIT DATE	FACILITY DESCRIPTION	Process Name	Fuel	Through-put	UNITS	Pollutant	Emission Control Description	Emission Limit 1	Limits Units 1	Avg Time	CASE-BY-CASE BASIS	Emission Limit 2	Limits Units2	Avg Time2	Standard Emission Limit	Standard Limit Units	Standard Limit Avg Time
IN-0173	MIDWEST FERTILIZER CORPORATION	MIDWEST FERTILIZER CORPORATION	IN	129-33576-00059	325311	06/04/2014 ACT	A STATIONARY NITROGEN FERTILIZER MANUFACTURING FACILITY	THREE (3) AUXILIARY BOILERS	NATURAL GAS	218.6	MMBTU/H, EACH	Nitrogen Oxides (NOx)	LOW NOX BURNERS, FLUE GAS RECIRCULATION	20.4	LB/MMCF	3-HR AVERAGE	BACT-PSD	0			0		
IN-0180	MIDWEST FERTILIZER CORPORATION	MIDWEST FERTILIZER CORPORATION	IN	129-33576-00059	325311	06/04/2014 ACT	A STATIONARY NITROGEN FERTILIZER MANUFACTURING FACILITY	THREE (3) AUXILIARY BOILERS	NATURAL GAS	218.6	MMBTU/H, EACH	Nitrogen Oxides (NOx)	LOW NOX BURNERS, FLUE GAS RECIRCULATION	20.4	LB/MMCF	3-HR AVERAGE	BACT-PSD	0			0		
LA-0288	LAKE CHARLES CHEMICAL COMPLEX	SASOL CHEMICALS (USA) LLC	LA	PSD-LA-778	325110	05/23/2014 ACT		HP 5H Steam Boilers (EQT 631, 632, & 633)	PROCESS GAS	408.4	MM BTU/HR	Nitrogen Oxides (NOx)	Ultra low NOx burners (ULNBs) and selective catalytic reduction (SCR)	20.59	LB/HR	HOURLY MAXIMUM	BACT-PSD	11.33	TPY	ANNUAL MAXIMUM	0.01	LB/MMBTU	30-DAY ROLLING AVERAGE
LA-0301	LAKE CHARLES CHEMICAL COMPLEX ETHYLENE 2 UNIT	SASOL CHEMICALS (USA) LLC	LA	PSD-LA-779	325110	05/23/2014 ACT		Utility Steam Boiler Nos. 1-3 (EQTs 967, 968, & 969)	Process Gas	662	MM BTU/HR	Nitrogen Oxides (NOx)	Selective catalytic reduction (SCR) and ultra low NOx burners (ULNB)	33.7	LB/HR	HOURLY MAXIMUM	BACT-PSD	70.96	TPY*	ANNUAL MAXIMUM	0.01	LB/MMBTU	30-DAY ROLLING AVERAGE

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix A: EPA RACT BACT LAER Clearinghouse Data
Gas Fired Boilers

Sulfur Dioxide (SO₂)

NOTE: Draft determinations are marked with a " * " beside the RBLC ID.

RBLCID	FACILITY NAME	CORPORATE OR COMPANY NAME	FACILITY STATE	PERMIT NUM	NAICS CODE	PERMIT DATE	FACILITY DESCRIPTION	Process Name	Fuel	Through-put	UNITS	Pollutant	Emission Control Description	Emission Limit 1	Limits Units 1	Avg Time	CASE-BY-CASE BASIS	Emission Limit 2	Limits Units2	Avg Time2	Standard Emission Limit	Standard Limit Units	Standard Limit Avg Time
LA-0288	LAKE CHARLES CHEMICAL COMPLEX	SASOL CHEMICALS (USA) LLC	LA	PSD-LA-778	325110	05/23/2014 ACT		HP SH Steam Boilers (EQT 631, 632, & 633)	PROCESS GAS	408.4	MM BTU/HR	Sulfur Dioxide (SO2)	Use of gaseous fuels with a sulfur content no more than 0.005 gr/scf	24.22	LB/HR	HOURLY MAXIMUM	BACT-PSD	1.67	TPY	ANNUAL MAXIMUM	0		
LA-0301	LAKE CHARLES CHEMICAL COMPLEX ETHYLENE 2 UNIT	SASOL CHEMICALS (USA) LLC	LA	PSD-LA-779	325110	05/23/2014 ACT		Utility Steam Boiler Nos. 1-3 (EQTs 967, 968, & 969)	Process Gas	662	MM BTU/HR	Sulfur Dioxide (SO2)	Use of gaseous fuels with a sulfur content of no more than 0.005 grains per standard cubic foot (annual average)	1.98	LB/HR	HOURLY MAXIMUM	BACT-PSD	10.43	TPY*	ANNUAL MAXIMUM	0		
*FL-0330	PORT DOLPHIN ENERGY LLC		FL	DPA-EPA-R4001	213112	12/01/2011 ACT	Port Dolphin is a deepwater port designed to moor liquefied natural gas shuttle and regasification vessels 28 miles off the cost of Florida.	Boilers (4 - 278 mmbtu/hr each)	natural gas	0		Sulfur Dioxide (SO2)	use of natural gas	0.0006	LB/MMBTU	3-HOUR ROLLING AVERAGE	BACT-PSD	0			0		
IN-0166	INDIANA GASIFICATION, LLC	INDIANA GASIFICATION, LLC	IN	T147-30464-00060	221210	06/27/2012 ACT	THE PERMITTEE OWNS AND OPERATES A STATIONARY SUBSTITUTE NATURAL GAS (SNG) AND LIQUEFIED CARBON DIOXIDE (CO2) PRODUCTION PLANT	TWO (2) AUXILIARY BOILERS	NATURAL GAS	408	MMBTU/H, EACH	Sulfur Dioxide (SO2)	USE OF NATURAL GAS OR SNG	0.0006	MMBTU/H	3 HR	BACT-PSD	0			0		
IN-0234	GRAIN PROCESSING CORPORATION	GRAIN PROCESSING CORPORATION	IN	027-35177-00046	311221	12/08/2015 ACT	THIS FACILITY IS A STATIONARY CORN WET MILLING PLANT.	BOILER 1	NATURAL GAS	271	MMBTU/H	Sulfur Dioxide (SO2)	SULFUR CONTENT OF ALCOHOL AND BY-PRODUCT WASTE OIL	0.0006	LB/MMBTU	NATURAL GAS ALONE	BACT-PSD	0.0008	LB/MMBTU	NATURAL GAS AND ALCOHOL	0		
LA-0305	LAKE CHARLES METHANOL FACILITY	LAKE CHARLES METHANOL, LLC	LA	PSD-LA-803(M1)	325199	06/30/2016 ACT	Proposed facility to produce methanol, H2, H2SO4, CO2, Argon and electricity from Pet Coke	Auxiliary Boilers and Superheaters	Natural Gas	0		Sulfur Dioxide (SO2)	fuel gases and/or pipeline quality natural gas	0			BACT-PSD	0			0		
*TX-0888	ORANGE POLYETHYLENE PLANT	CHEVRON PHILLIPS CHEMICAL COMPANY LP	TX	155952 PSDTX1556 GHGSPSDTX192	325211	04/23/2020 ACT	An initial NSR, PSD, and GHG project to construct and operate an Olefins Unit, two Polyethylene (PE) Units, and auxiliary support facilities. This permit will consist of furnaces, boilers, heaters, storage tanks, emergency engines, fugitive piping, thermal oxidizers, flares,	BOILERS	Natural gas, ethane, fuel, or vent gas	250	MMBTU	Sulfur Dioxide (SO2)	Good combustion practice and clean fuel	2	GR/100 SCF		BACT-PSD	0			0		

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix A: EPA RACT BACT LAER Clearinghouse Data
Blast Furnace

Nitrogen Oxides (NOx)

NOTE: Draft determinations are marked with a " * " beside the RBLC ID.

RBLCID	FACILITY NAME	CORPORATE OR COMPANY NAME	FACILITY STATE	PERMIT NUM	NAICS CODE	PERMIT DATE	FACILITY DESCRIPTION	Process Name	Fuel	Through-put	UNITS	Pollutant	Emission Control Description	Emission Limit 1	Limits Units 1	Avg Time	CASE-BY-CASE BASIS	Emission Limit 2	Limits Units2	Avg Time2	Standard Emission Limit	Standard Limit Units	Standard Limit Avg Time
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	5/24/2010	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	SLG-104 - Blast Furnace 1 Slag Pit 1		28.66	T/H	Nitrogen Oxides (NOx)		0.71	LB/H		BACT-PSD	0.47	T/YR		0.0248	LB/T OF SLAG	
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	5/24/2010	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	SLG-105 - Blast Furnace 1 Slag Pit 2		28.66	T/H	Nitrogen Oxides (NOx)		0.71	LB/H		BACT-PSD	0.47	T/YR		0.0248	LB/T OF SLAG	
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	5/24/2010	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	SLG-106 - Blast Furnace 1 Slag Pit 3		28.66	T/H	Nitrogen Oxides (NOx)		0.71	LB/H		BACT-PSD	0.47	T/YR		0.0248	LB/T OF SLAG	
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	5/24/2010	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	SLG-204 - Blast Furnace 2 Slag Pit 1		28.66	T/h	Nitrogen Oxides (NOx)		0.71	LB/H		BACT-PSD	0.47	T/YR		0.0248	LB/T OF SLAG	
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	5/24/2010	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	SLG-205 - Blast Furnace 2 Slag Pit 2		28.66	t/h	Nitrogen Oxides (NOx)		0.71	LB/H		BACT-PSD	0.47	T/YR		0.0248	LB/TON OF SLAG	
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	5/24/2010	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	SLG-206 - Blast Furnace 2 Slag Pit 3		28.66	t/h	Nitrogen Oxides (NOx)		0.71	LB/H		BACT-PSD	0.47	T/YR		0.0248	LB/TON OF SLAG	
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	05/24/2010 ACT	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	STV-101-Blast Furnace 1 Hot Blast Stoves Common Stack	Blast Furnace Gas	627.04	MMBTU/H	Nitrogen Oxides (NOx)	Low-NOx fuel combustion	66.29	LB/H		BACT-PSD	161.23	T/YR		0.06	LB/MMBTU	
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	05/24/2010 ACT	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	STV-201-Blast Furnace 2 Hot Blast Stoves Common Stack	Blast Furnace Gas	627.04	MMBTU/H	Nitrogen Oxides (NOx)	Low-NOx fuel combustion	66.29	LB/H		BACT-PSD	161.23	T/YR		0.06	LB/MMBTU	

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix A: EPA RACT BACT LAER Clearinghouse Data
Blast Furnace

Sulfur Dioxide (SO₂)

NOTE: Draft determinations are marked with a * * * beside the RBLC ID.

RBLCID	FACILITY NAME	CORPORATE OR COMPANY NAME	FACILITY STATE	PERMIT NUM	NAICS CODE	PERMIT DATE	FACILITY DESCRIPTION	Process Name	Fuel	Through-put	UNITS	Pollutant	Emission Control Description	Emission Limit 1	Limits Units 1	Avg Time	CASE-BY-CASE BASIS	Emission Limit 2	Limits Units2	Avg Time2	Standard Emission Limit	Standard Limit Units	Standard Limit Avg Time
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	5/24/2010	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	SLG-104 - Blast Furnace 1 Slag Pit 1		28.66	T/H	Sulfur Dioxide (SO2)		3.28	LB/H		BACT-PSD	2.16	T/YR		0.115	LB/ OF SLAG	
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	5/24/2010	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	SLG-105 - Blast Furnace 1 Slag Pit 2		28.66	T/H	Sulfur Dioxide (SO2)		3.28	LB/H		BACT-PSD	2.16	T/YR		0.115	LB/T OF SLAG	
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	5/24/2010	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	SLG-106 - Blast Furnace 1 Slag Pit 3		28.66	T/H	Sulfur Dioxide (SO2)		3.28	LB/H		BACT-PSD	2.16	T/YR		0.115	LB/T OF SLAG	
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	5/24/2010	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	SLG-204 - Blast Furnace 2 Slag Pit 1		28.66	T/h	Sulfur Dioxide (SO2)		3.28	LB/H		BACT-PSD	2.16	T/YR		0.115	LB/TON OF SLAG	
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	5/24/2010	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	SLG-205 - Blast Furnace 2 Slag Pit 2		28.66	t/h	Sulfur Dioxide (SO2)		3.28	LB/H		BACT-PSD	2.16	T/YR		0.115	LB/TON OF SLAG	
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	5/24/2010	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	SLG-206 - Blast Furnace 2 Slag Pit 3		28.66	t/h	Sulfur Dioxide (SO2)		3.28	LB/H		BACT-PSD	2.16	T/YR		0.115	LB/T OF SLAG	
MI-0377	SEVERSTAL NORTH AMERICA, INC.	SEVERSTAL NORTH AMERICA, INC.	MI	182-05	331111	1/31/2006	INTEGRATED IRON AND STEEL PLANT	BLAST FURNACE STOVES	BLAST FURNACE GAS	24003	MMSCF/YR	Sulfur Dioxide (SO2)	NO CONTROLS FEASIBLE. COMPLIANCE VERIFICATION VIA CEMS.	14.37	LB/MMSCF	WHEN B FURNACE OPERATING	BACT-PSD	16.62	LB/MMSCF	WHEN B FURNACE NOT OPERATING	0		
MI-0413	AK STEEL	AK STEEL CORPORATION	MI	182-05C	331111	5/12/2014	Iron and steel manufacturing facility	EUCFURNACE - C Blast Furnace which includes the blast furnace	Nat. gas, BFG, pulv coal, coke	37841	MMCF/YR	Sulfur Dioxide (SO2)		179.65	LB/H	CALENDAR DAY AVG; BAGHOUSE STACK	BACT-PSD	193.6	LB/H	CALENDAR DAY AVG; STOVE STACK	0		
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	05/24/2010 ACT	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	STV-101-Blast Furnace 1 Hot Blast Stoves Common Stack	Blast Furnace Gas	627.04	MMBTU/H	Sulfur Dioxide (SO2)	No feasible control technology for Blast Furnace Gas. (BFG) Limit Natural Gas sulfur content	19.54	LB/H		BACT-PSD	28.19	T/YR		0		
LA-0239	NUCOR STEEL LOUISIANA	CONSOLIDATED ENVIRONMENTAL MANAGEMENT INC	LA	PSD-LA-740	332111	05/24/2010 ACT	THE NUCOR STEEL LOUISIANA FACILITY WILL USE THE BLAST FURNACE PROCESS TO PRODUCE HIGH QUALITY PIG IRON. NUCOR PLANS FOR THE MILL TO REACH AN ANTICIPATED PEAK ANNUAL PRODUCTION RATE OF OVER SIX MILLION METRIC TONNES OF IRON	STV-201-Blast Furnace 2 Hot Blast Stoves Common Stack	Blast Furnace Gas	627.04	MMBTU/H	Sulfur Dioxide (SO2)	No feasible control technology for Blast Furnace Gas. (BFG) Limit Natural Gas sulfur content	19.54	LB/H		BACT-PSD	28.19	T/H		0		
MI-0377	SEVERSTAL NORTH AMERICA, INC.	SEVERSTAL NORTH AMERICA, INC.	MI	182-05	331111	01/31/2006 ACT	INTEGRATED IRON AND STEEL PLANT	C FURNACE CASTHOUSE	PULVERIZED COAL, COKE	6700	T/D	Sulfur Dioxide (SO2)	NO FEASIBLE CONTROLS	14.65	LB/H	AVERAGING TIME PER TEST PROTOCOL	BACT-PSD	0			0		

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix A: EPA RACT BACT LAER Clearinghouse Data
Flares in the Ferrous Metals Industry

Nitrogen Oxides (NOx)

NOTE: Draft determinations are marked with a " * " beside the RBLC ID.

RBLCID	FACILITY NAME	CORPORATE OR COMPANY NAME	FACILITY STATE	PERMIT NUM	NAICS CODE	PERMIT DATE	FACILITY DESCRIPTION	Process Name	Fuel	Through-put	UNITS	Pollutant	Emission Control Description	Emission Limit 1	Limits Units 1	Avg Time	CASE-BY-CASE BASIS	Emission Limit 2	Limits Units2	Avg Time2	Standard Emission Limit	Standard Limit Units	Standard Limit Avg Time
AL-0275	NUCOR STEEL TUSCALOOSA, INC.	NUCOR STEEL TUSCALOOSA, INC.	AL	413-0033	331111	07/22/2014 ACT	Nucor Steel Tuscaloosa, Inc. owns and operates a scrap steel mill. The mill prduces steel coils.	Vacuum Degasser with flare and cooling towers		0		Nitrogen Oxides (NOx)	Flare	0.005	LB/T		BACT-PSD	0			0		
AR-0150	NUCOR YAMATO STEEL COMPANY (LIMITED PARTNERSHIP)	NUCOR YAMATO STEEL COMPANY (LIMITED PARTNERSHIP)	AR	0883-AOP-R15	331111	06/01/2018 ACT	Nucor-Yamato Steel Company (NYS) owns and operates a steel mill located in Blytheville, AR.	Vacuum tank Degasser and Flare	Natural gas	150	tons per hour	Nitrogen Oxides (NOx)	Proper equipment design and operation	0.098	LB/MMBTU		BACT-PSD	0			0		

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix A: EPA RACT BACT LAER Clearinghouse Data
Flares in the Ferrous Metals Industry

Sulfur Dioxide (SO2)
NOTE: Draft determinations are marked with a " * " beside the RBLC ID.

RBLCID	FACILITY NAME	CORPORATE OR COMPANY NAME	FACILITY STATE	PERMIT NUM	NAICS CODE	PERMIT DATE	FACILITY DESCRIPTION	Process Name	Fuel	Through-put	UNITS	Pollutant	Emission Control Description	Emission Limit 1	Limits Units 1	Avg Time	CASE-BY-CASE BASIS	Emission Limit 2	Limits Units2	Avg Time2	Standard Emission Limit	Standard Limit Units	Standard Limit Avg Time
AR-0150	NUCOR YAMATO STEEL COMPANY (LIMITED PARTNERSHIP)	NUCOR YAMATO STEEL COMPANY (LIMITED PARTNERSHIP)	AR	0883-AOP-R15	331111	06/01/2018 &																	

Appendix B

Air Permit Summary for II&S Mills

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix B: Air Permit Summary for II&S Mills

Basic Oxygen Process and Furnace				
	Emission Unit Description	Controls	NO _x Limit	Comments
AM Indiana Harbor West	1968 Basic Oxygen Furnace No. 1 3,728,256 ton metal/yr	Electrostatic Precipitator	None	Listed controls are only for PM
	1968 Basic Oxygen Furnace No. 2 3,728,256 ton metal/yr		None	
	1982 Hot Metal Reladle/Desulf Complex 5,630,208 ton metal/yr	Baghouse	None	Listed controls are only for PM.
AM Indiana Harbor East	1974 No. 10 BOF 2,271,800 tons hot metal and scrap/yr	Flare Scrubber	None	Listed controls are only for PM and CO
	1974 No. 20 BOF 2,271,800 tons hot metal and scrap/yr	Flare Scrubber	None	Listed controls are only for PM and CO
	1974 No. 2 BOF Secondary Ventilation for charging /tapping emissions	scrubber	None	Listed controls are only for PM
	1974 No. 2 BOF Shop Transfer and Desulfurization 4,029,600 tons hot metal/yr	Baghouse	None	Listed controls are only for PM
	1967 No. 50 BOF 2,838,183 tons hot metal and scrap/yr	Common 4 Off-gas scrubber system	None	Listed controls are only for PM
	1967 No. 60 BOF 2,838,183 tons hot metal and scrap/yr		None	
	1977 No. 4 BOF Secondary Ventilation for charging /tapping emissions	Baghouse	None	Listed controls are only for PM
	1977 No. 4 BOF Shop, 2 Transfer and Desulfurization Stations 4,222,320 tons hot metal/yr	2 Baghouses	None	Listed controls are only for PM
AM Burns Harbor	1968 and 1978 3 Hot Metal Transfer/Desulfurization 623 tons/hr metal	Baghouse	None	Listed controls are only for PM
	1968 BOF Shop Vessel #1 300 ton metal/heat	Scrubber Baghouse	None	Listed controls are only for PM
	1968 BOF Shop Vessel #2 300 ton metal/heat	Scrubber Baghouse	None	Listed controls are only for PM
	1978 BOF Shop Vessel #3 300 ton metal/heat	Scrubber Baghouse CO Flare	None	Listed controls are only for PM and CO
AK Dearborn	EUBOFDESULF	None	None	
	1984 Slag Desulfurization			
	EUBOF 1964 Basic Oxygen Furnace	None	162.1 tpy (12-mo. Rolling Sum) 52.9 pph	R 336.1205(1)(a)&(b) R 336.2801(ee) R 336.2802(4) R 336.2803, R 336.2804
AK Middleton	F011 BOF Deslagger, Molten iron deslagging operation	Baghouse	None	
	P926 Basic Oxygen Furnace Vessel, No. 15 basic oxygen furnace	Venturi Scrubber Flare	None	
	P927 Basic Oxygen Furnace Vessel, No. 16 basic oxygen furnace	Venturi Scrubber Flare	None	
	P902 Continuous Caster, BOF Continuous molten steel slab casting operation	None	None	
AM Cleveland	F011 #1 BOF Hot Metal Transfer and Desulfurization	Baghouse	0.1 lb/MMBtu	For ladle reheaters (no stacks). OAC rule 3745-110-03(N)
	F011 #1 BOF Shop Vessels	Venturi Scrubber Flare Baghouse		
	F011 #2 BOF Hot Metal Transfer and Desulfurization	Baghouse		
	F011 #2 BOF Shop Vessels	Electrostatic Precipitator		
Nucor St. James	Facility does not have a basic oxygen furnace			
USS Clairton	Facility does not have a basic oxygen furnace			
USS East Chicago	Facility does not have a basic oxygen furnace			
USS Edgar Thompson	P003 Basic Oxygen Process Shop 3,467,500 tons/yr metal	Baghouse Venturi Scrubber	None	

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix B: Air Permit Summary for II&S Mills

		Basic Oxygen Process and Furnace		
Emission Unit Description		Controls	NOx Limit	Comments
USS Gary Works	SSDS0201, SSMT0203 1965 and 1981 No. 1 and No. 2 Hot metal Transfer and Desulfurization 912 tons/hr Natural Gas	Baghouse	None	
	SSVM0234, SSVE0235, SSVD0236 1965 No. 1 Basic Oxygen Process Vessels 750 tons/hr Natural Gas	Quench Scupper Venturi Scrubbers Separators Gas Coolers	None	
	NSDS0246 1987 2 Hot Metal Transfer and Desulfurization Stations 510 tons/hr Natural Gas	Baghouse	None	
	NSVT0268, NSVW0269, NSVY0270 1973 No. 2 Basic Oxygen Process Vessels 750 tons/hr Natural Gas	Quench Scupper Venturi Scrubbers Separators Gas Coolers	None	
USS Great Lakes	EU2BOPHMTDESULF-S1 1995 #2 BOF Transfer and Desulfurization	None	None	
	EU2BOF-CHARGING-S1 1983 #2 BOF Charging	None	None	
	EU2BOF-TAPPING-S1 1987 and 2006 #2 BOF Tapping	None	None	
	EU2BOF-VESSELS-S1 1968 #2 BOF Vessels	None	None	

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix B: Air Permit Summary for II&S Mills

Boiler			
	Emission Unit Description	Controls	NO _x Limit
			Comments
AM Indiana Harbor West	1952 No. 5 Boiler 454 MMBtu/hr max HI (ea.) Natural Gas, blast furnace gas	None	0.17 lb/MMBtu & 50% Heat Input from BFG Pursuant to 326 IAC 10-3-3: Applies to all 4 boilers, limit for each individual boiler; only applicable during ozone control periods
	1956 No. 6 Boiler 454 MMBtu/hr max HI (ea.) Natural Gas, blast furnace gas	None	
	1956 No. 7 Boiler 454 MMBtu/hr max HI (ea.) Natural Gas, blast furnace gas	None	
	1967 No. 8 Boiler 1,090 MMBtu/hr max HI (ea.) Natural Gas, blast furnace gas	None	
AM Indiana Harbor East	1976 No. 501 Boiler 520 MMBtu/hr max HI (ea.) Natural Gas, Blast Furnace Gas	None	0.17 lb/MMBtu & 50% Heat Input from BFG Pursuant to 326 IAC 10-3-3(c): Applies to all 4 boilers, limit for each individual boiler; only applicable during ozone control periods
	1976 No. 502 Boiler 520 MMBtu/hr max HI (ea.) Natural Gas, Blast Furnace Gas	None	
	1976 No. 503 Boiler 520 MMBtu/hr max HI (ea.) Natural Gas, Blast Furnace Gas	None	
	Approved in 2010 - No. 504 Boiler 561.6 MMBtu/hr max HI (ea.) Natural Gas, Blast Furnace Gas	None	
AM Burns Harbor	1976 No. 7 Boiler 650 MMBtu/hr max HI (ea.) natural gas, coke oven gas, blast furnace gas, and fuel oil	None	0.17 lb/MMBtu & 50% Heat Input from BFG Pursuant to 326 IAC 10-3-3: Applies to all 6 boilers, limit for each individual boiler; only applicable during ozone control periods
	1970 No. 8 Boiler 650 MMBtu/hr max HI (ea.) natural gas, coke oven gas, blast furnace gas, No. 2 fuel oil, No. 6 fuel oil	None	
	1970 No. 9 Boiler 650 MMBtu/hr max HI (ea.) natural gas, coke oven gas, blast furnace gas, No. 2 fuel oil, No. 6 fuel oil	None	
	1969 No. 10 Boiler 650 MMBtu/hr max HI (ea.) natural gas, coke oven gas, blast furnace gas, No. 2 fuel oil, No. 6 fuel oil	None	
	1968 No. 11 Boiler 650 MMBtu/hr max HI (ea.) natural gas, coke oven gas, blast furnace gas, No. 2 fuel oil, No. 6 fuel oil	None	
	1968 No. 12 Boiler 650 MMBtu/hr max HI (ea.) natural gas, coke oven gas, blast furnace gas, No. 2 fuel oil, No. 6 fuel oil	None	
Nucor St. James	Not Constructed - Topgas Boiler No. 1 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low NO _x fuels	1. 0.2 lb/MMBtu 2. 0.092 lb/MMBtu 3. 0.137 lb/MMBtu 1. 40 CFR60.44(a)(1) (NSPS D): For all boilers individually. 2. LAC 33:III.509, BACT: For all boilers individually. Specific to BFG. This limit for Normal operation consists of a fuel mixture of Blast Furnace Top Gas and Natural gas with less than or equal to 41 % natural gas on a MMBTU / hr heat input. 3. LAC 33:III.509, BACT: For all boilers individually. Total for all fuels. This emission rate is based upon any operation with natural gas greater than 41 % heat input of the fuel up to and including 100%. Operating under this alternate operating scenario shall be minimized to the maximum extent possible.
	Not Constructed - Topgas Boiler No. 2 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low NO _x fuels	
	Not Constructed - Topgas Boiler No. 3 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low NO _x fuels	
	Not Constructed - Topgas Boiler No. 4 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low NO _x fuels	
	Not Constructed - Topgas Boiler No. 5 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low NO _x fuels	
	Not Constructed - Topgas Boiler No. 6 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low NO _x fuels	
	Not Constructed - Topgas Boiler No. 7 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low NO _x fuels	
	Not Constructed - Topgas Boiler No. 8 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low NO _x fuels	

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix B: Air Permit Summary for II&S Mills

Boiler				
Emission Unit Description		Controls	NO _x Limit	Comments
USS Clairton	8001 - Boiler No. 1 760 mmbtu/hr heat input Desulfurized Coke Oven Gas and Natural Gas	None	410.40 lb/hr 1,740 tpy 0.54 lb/MMBtu	RACT Plan (shall not exceed at any time)
	8002 - Boiler No. 2 481 mmbtu/hr heat input Desulfurized Coke Oven Gas and Natural Gas	None	259.74 lb/hr 1,285 tpy 0.54 lb/MMBtu	RACT Plan (shall not exceed at any time)
	8005 - R1 Boiler 229 mmbtu/hr heat input Desulfurized Coke Oven Gas and Natural Gas	None	123.66 lb/hr 525 tpy 0.54 lb/MMBtu	RACT Plan (shall not exceed at any time)
	8006 - R2 Boiler 229 mmbtu/hr heat input Desulfurized Coke Oven Gas and Natural Gas	None	123.66 lb/hr 525 tpy 0.54 lb/MMBtu	RACT Plan (shall not exceed at any time)
	8007 - T1 Boiler 156 mmbtu/hr heat input Desulfurized Coke Oven Gas and Natural Gas	None	84.24 lb/hr 358 tpy 0.54 lb/MMBtu	RACT Plan (shall not exceed at any time)
	8008 - T2 Boiler 156 mmbtu/hr heat input Desulfurized Coke Oven Gas and Natural Gas	None	84.24 lb/hr 358 tpy 0.54 lb/MMBtu	RACT Plan (shall not exceed at any time)
AK Dearborn	Facility does not have a boiler			
AK Middleton	P009 No. 3 Slab Reheat Furnace/Waste Heat Boiler 598 MMBtu/hr Slab Furnace 305 MMBtu/hr Waste Heat Boiler Natural gas, fuel oil, coke oven gas	None	None	
	P010 No. 2 Slab Reheat Furnace/Waste Heat Boiler 598 MMBtu/hr Slab Furnace 305 MMBtu/hr Waste Heat Boiler Natural gas, fuel oil, coke oven gas	None	None	
	P011 No. 1 Slab Reheat Furnace/Waste Heat Boiler 598 MMBtu/hr Slab Furnace 305 MMBtu/hr Waste Heat Boiler Natural gas, fuel oil, coke oven gas	None	None	
	P012 No. 4 Slab Reheat Furnace/Waste Heat Boiler 598 MMBtu/hr Slab Furnace 305 MMBtu/hr Waste Heat Boiler Natural gas, fuel oil, coke oven gas	None	None	
AM Cleveland	Facility does not have a boiler			
USS Edgar Thompson	Facility does not have a boiler			
USS East Chicago	8-1 Steam Generation Boiler 181.1 MMBtu/hr max HI (ea.) Natural gas	Low-NO _x burners, Flue gas recirculation	40 tpy (12-mo. Rolling Sum)	NO _x PSD and Emission Offset Minor Limit [326 IAC 2-2] [326 IAC 2-3]

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix B: Air Permit Summary for II&S Mills

Blast Furnace Stoves, Casthouses, and Slag Pits				
	Emission Unit Description	Controls	NO _x Limit	Comments
AM Indiana Harbor West	1953 No. 3 Blast Furnace Including three No. 3 Blast Furnace Stoves 4.5552 Mmtons/yr input 441 MMBtu/hr max HI total	integral gas cleaning system consisting of a dust catcher, separator, two scrubbers (primary and secondary) and one cooling tower, with excess gas exhausting through a flare at stack (S1E)	None	Listed controls are for CO only.
		Three Stoves have no controls for NO _x		Primarily combust BFG which is a low NO _x fuel
		Passive Emission Control (PEC) to suppress fumes in the casthouse, consisting of slag and iron runner covers along with natural gas flame suppression exhausting to the No. 3 Blast Furnace Casthouse Roof Monitor (V1A).		Listed controls are for PM only.
	1967 No. 4 Blast Furnace Including three No. 4 Blast Furnace Stoves 5.490836 Mmtons/yr input 486 MMBtu/hr max HI total	integral gas cleaning system consisting of a dust catcher, separator, two scrubbers (primary and secondary) and one cooling tower with excess gas exhausting through a flare at stack (S1D)	None	Listed controls are for CO only.
		Three Stoves have no controls for NO _x		Primarily combust BFG which is a low NO _x fuel
		Passive Emission Control (PEC) to suppress fumes in the casthouse, consisting of slag and iron runner covers along with natural gas flame suppression exhausting to the No. 4 Blast Furnace Casthouse Roof Monitor (V1B). No. 4 Blast Furnace Casthouse Baghouse used to control emissions from the casthouse with an airflow rate of 147,000 acfm exhausting at stack (S1B) when operating one (1) fan. No. 4 Blast Furnace Casthouse Baghouse has an air flow rate of 240,000 acfm when operating two (2) fans.		Listed controls are for PM only.
AM Indiana Harbor East	2 Ladle Burners 36 MMBtu/hr max HI total	None	None	
	Railcar Thaw Shed Heater 50.4 MMBtu/hr max HI total	None	None	
	1980 No. 7 Blast Furnace Including four No. 7 Blast Furnace Stoves 4.417 Mmtons/yr metal production 953 MMBtu/hr max HI total Pulverized coal (132 tons/hr) / Natural Gas / Blast Furnace Gas	integral gas cleaning system with excess gas exhausting through Three (3) flares, each with a 1.15 MMBtu per hour igniter capacity of flaring one-third of the maximum generated blast furnace gas through stack 195 Four Stoves have no controls for NO _x	None	Listed controls are for CO only.
		Casthouse emissions controlled by two baghouses rated at 500,000 acfm (stack 166) and 300,000 acfm (stack 167) respectively. PCI system has two pulverizers each with cyclone and baghouse (stack 187).		Primarily combust BFG which is a low NO _x fuel Listed controls are for PM only.
AM Burns Harbor	1971 C Blast Furnace Consisting of C Blast Furnace Stoves 623 tons/hr iron (total with D Blast Furnace) 660 MMBtu/hr max HI total	integral gas cleaning system consisting of various components including a dust catcher, separator, and 2 scrubbers (primary and secondary), which provides clean fuel to the plant fuel distribution system with excess gas flared Stoves, exhausting to combustion stack (EP520-3547) with an estimated heat input rate of 660 MMBtu/hr East and West casthouses with iron and slag runner fugitive emissions reporting to roof monitors EP520-3543 and 3545 respectively and tap hole and tilting runner emissions controlled by MACT baghouse installed in 2007	None	Listed controls are for CO only.
				Primarily combust BFG which is a low NO _x fuel Listed controls are for PM only.
	1968 D Blast Furnace Consisting of D Blast Furnace Stoves 623 tons/hr iron (total with C Blast Furnace) 660 MMBtu/hr max HI total	integral gas cleaning system consisting of various components including a dust catcher, separator, and 2 scrubbers (primary and secondary), which provides clean fuel to the plant fuel distribution system with excess gas flared Stoves, exhausting to combustion stack (EP520-3560) with an estimated heat input rate East and West casthouses with iron and slag runner fugitive emissions reporting to roof monitors EP520-3556 and 3558 respectively and respectively and tap hole and tilting runner emissions controlled by MACT baghouse installed in 2007	None	Listed controls are for CO only.
				Primarily combust BFG which is a low NO _x fuel Listed controls are for PM only.
USS Gary Works	IDBF0369 No. 14 Blast Furnace Comprised of three No. 14 Blast Furnace Stoves (IDST0359) 450 tons metal production/hr 700 MMBtu/hr max HI total Natural gas / Pulverized coal (80 tons/hr) / Oil (150	Stockhouse Baghouse	None	
Nucor St. James	Not Constructed Blast Furnace 1 1,088 MMBtu/hr Natural gas, Blast furnace gas	Low NO _x fuels	0.06 lb/MMBtu	LAC 33:III.509, BACT
	Not Constructed Casthouse No. 1	None	None	
	Not Constructed Blast Furnace 2 1,088 MMBtu/hr Natural gas, Blast furnace gas	Low NO _x fuels	0.06 lb/MMBtu	LAC 33:III.509, BACT
	Not Constructed Casthouse No. 2	None	None	
USS Clairton	Facility does not have a blast furnace			
AK Dearborn	1/1/1922 EUBFURNACE (part of FGB&CFURNACES), group of 4 stoves with a common stack, cast house emission control system (collection hoods, baghouse, stack), a blast furnace gas scrubber and dust collector, semi-clean bleeder, and dirty gas bleeder. 3,321,500 tons iron/yr (material limit on FGB&CFURNACES) Natural gas, Blast furnace gas	Stoves: Low-Nox Technology Casthouse: Baghouse Venturi scrubber and mechanical collector for blast furnace pre-cleaning	25.74 tons/yr (12mo rolling)	Limit on: FGB&CFURNACES baghouse stacks R336.2801 - R336.2804 -- PSD
	1/1/1948, 10/1/2007 EUCFURNACE (part of FGB&CFURNACES), group of 4 stoves with a		439.2 tons/yr (12mo rolling)	Limit on: FGB&CFURNACES stove stacks R336.2801 - R336.2804 -- PSD
AK Middletown	P925 No. 3 Blast Furnace 740 tons metal production/hr	For PM control: equipped with a casthouse baghouse, a settling chamber/dustcatcher (cyclone), a wet venturi scrubber system (Bischoff), stoves, and a blast furnace gas flare	None	

ArcelorMittal Indiana Harbor West

Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control

Appendix B: Air Permit Summary for II&S Mills

Blast Furnace Stoves, Casthouses, and Slag Pits				
Emission Unit Description		Controls	NO _x Limit	Comments
AM Cleveland	P903 Blast Furnace C5	equipped with a venturi scrubber for cleaning reusable blast furnace gas, natural gas suppression, oxygen enrichment, dirty and clean gas bleeders, and flue dust handling with passive emission control (PEC) system, and flare	0.06 lbs/MMBtu	for furnace stoves
	P904 Blast Furnace C6	equipped with a venturi scrubber for cleaning reusable blast furnace gas, natural gas suppression, oxygen enrichment, dirty and clean gas bleeders, and flue dust handling with passive emission control (PEC) system and a flare	0.06 lbs/MMBtu	for furnace stoves
USS Edgar Thompson	P001a Blast Furnace No. 1 Casthouse 1,752,000 tpy (production capacity) Coke, Iron-bearing materials, fluxes	Stack S002, Casthouse Baghouse (shared between P001a and P002a)	None	
	P001b Blast Furnace No. 1 Stoves 495 MMBtu/hr BFG, COG, Natural Gas	Stack S001, Dust Catch/Venturi scrubber for BFG cleaning	None	
	P001c BFG Flare 3 MMcfh BFG	Stack S003	None	
	P002a Blast Furnace No. 3 Casthouse 1,752,000 tpy (production capacity) Coke, Iron-bearing materials, fluxes	Stack S002, Casthouse Baghouse (shared between P001a and P002a)	None	
	P002b Blast Furnace No. 3 Stoves 495 MMBtu/hr BFG, COG, Natural Gas	Stack S004, Dust Catch/Venturi scrubber for BFG cleaning	None	
	Facility does not have a blast furnace			
USS East Chicago				

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix B: Air Permit Summary for II&S Mills

Boilers				
	Emission Unit Description	Controls	SO2 Limit	Comments
AM Indiana Harbor West	1952 No. 5 Boiler 454 MMBtu/hr max HI (ea.) Natural Gas, blast furnace gas	None	1. 0.594 lb/MMBtu	1. Pursuant to 326 IAC 7-4.1-10(a)(1): Limit applies to all 4 boilers, for each individual stack
	1956 No. 6 Boiler 454 MMBtu/hr max HI (ea.) Natural Gas, blast furnace gas	None	2. 1,456.5 lbs/hr	
	1956 No. 7 Boiler 454 MMBtu/hr max HI (ea.) Natural Gas, blast furnace gas	None	3. 5,871.61 tpy	
	1967 No. 8 Boiler 1,090 MMBtu/hr max HI (ea.) Natural Gas, blast furnace gas	None		2. Pursuant to 326 IAC 7-4.1-10(a)(1): Limit applies to all 4 boilers in total
				3. Pursuant to 326 IAC 7-4.1-10(a)(1): Limit applies to all 4 boilers in total, also with Ironside Energy, LLC Utility Boiler No. 9
AM Indiana Harbor East	1976 No. 501 Boiler 520 MMBtu/hr max HI (ea.) Natural Gas, Blast Furnace Gas	None	0.198 lb/MMBtu	Pursuant to 326 IAC 7-4.1-11(a): Limits are for all 4 boilers in total
	1976 No. 502 Boiler 520 MMBtu/hr max HI (ea.) Natural Gas, Blast Furnace Gas	None	265.2 lb/hr	
	1976 No. 503 Boiler 520 MMBtu/hr max HI (ea.) Natural Gas, Blast Furnace Gas	None		
	Approved in 2010 - No. 504 Boiler 561.6 MMBtu/hr max HI (ea.)	None		
AM Burns Harbor	1976 No. 7 Boiler 650 MMBtu/hr max HI (ea.) natural gas, coke oven gas, blast furnace gas, and fuel oil	None	None	
	1970 No. 8 Boiler 650 MMBtu/hr max HI (ea.) natural gas, coke oven gas, blast furnace gas, No. 2 fuel oil, No. 6 fuel oil	None		
	1970 No. 9 Boiler 650 MMBtu/hr max HI (ea.) natural gas, coke oven gas, blast furnace gas, No. 2 fuel oil, No. 6 fuel oil	None		
	1969 No. 10 Boiler 650 MMBtu/hr max HI (ea.) natural gas, coke oven gas, blast furnace gas, No. 2 fuel oil, No. 6 fuel oil	None		
	1968 No. 11 Boiler 650 MMBtu/hr max HI (ea.) natural gas, coke oven gas, blast furnace gas, No. 2 fuel oil, No. 6 fuel oil	None		
	1968 No. 12 Boiler 650 MMBtu/hr max HI (ea.) natural gas, coke oven gas, blast furnace gas, No. 2 fuel oil, No. 6 fuel oil	None		
Nucor St. James	Not Constructed - Topgas Boiler No. 1 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low sulfur fuels	1. 1.2 lb/MMBtu	1. 40 CFR60.43(a)(2) (NSPS D): For all boilers individually 2. LAC 33:III.509, BACT: For all boilers individually. Specific to BFG. This limit for Normal operation consists of a fuel mixture of Blast Furnace Top Gas and Natural gas with less than or equal to 41 % natural gas on a MMBTU / hr heat input. 3. LAC 33:III.509, BACT: Sulfur content in natural gas 4. LAC 33:III.509, BACT: For all boilers individually. Total for all fuels. This emission rate is based upon any operation with natural gas greater than 41 % heat input of the fuel up to and including 100%. Operating under this alternate operating scenario shall be minimized to the maximum extent possible.
	Not Constructed - Topgas Boiler No. 2 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low sulfur fuels	2. 0.008 lb/MMBtu	
	Not Constructed - Topgas Boiler No. 3 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low sulfur fuels	3. 0.002 gr/dscf	
	Not Constructed - Topgas Boiler No. 4 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low sulfur fuels	4. 0.022 lb/MMBtu	
	Not Constructed - Topgas Boiler No. 5 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low sulfur fuels		
	Not Constructed - Topgas Boiler No. 6 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low sulfur fuels		
	Not Constructed - Topgas Boiler No. 7 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low sulfur fuels		
	Not Constructed - Topgas Boiler No. 8 436.61 MMBtu/hr Natural Gas, blast furnace gas	Low sulfur fuels		

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix B: Air Permit Summary for II&S Mills

Boilers				
Emission Unit Description		Controls	SO ₂ Limit	Comments
USS Clairton	B001 - Boiler No. 1 760 mmbtu/hr heat input Desulfurized Coke Oven Gas and Natural Gas	None	163.50 lb/hr 716.11 tpy	County-only enforceable, per permit County-only enforceable, per permit
	B002 - Boiler No. 2 481 mmbtu/hr heat input Desulfurized Coke Oven Gas and Natural Gas	None	103.48 lb/hr 453.22 tpy	County-only enforceable, per permit County-only enforceable, per permit
	B005 - R1 Boiler 229 mmbtu/hr heat input Desulfurized Coke Oven Gas and Natural Gas	None	49.26 lb/hr 215.78 tpy	County-only enforceable, per permit County-only enforceable, per permit
	B006 - R2 Boiler 229 mmbtu/hr heat input Desulfurized Coke Oven Gas and Natural Gas	None	49.26 lb/hr 215.78 tpy	County-only enforceable, per permit County-only enforceable, per permit
	B007 - T1 Boiler 156 mmbtu/hr heat input Desulfurized Coke Oven Gas and Natural Gas	None	33.56 lb/hr 146.99 tpy	
	B008 - T2 Boiler 156 mmbtu/hr heat input Desulfurized Coke Oven Gas and Natural Gas	None	33.56 lb/hr 146.99 tpy	
AK Dearborn	Facility does not have a boiler			
AK Middletown	P009 No. 3 Slab Reheat Furnace/Waste Heat Boiler 598 MMBtu/hr Slab Furnace 305 MMBtu/hr Waste Heat Boiler Natural gas, fuel oil, coke oven gas	None	1.10 lbs/MMBtu	OAC rule citation(s)
	P010 No. 2 Slab Reheat Furnace/Waste Heat Boiler 598 MMBtu/hr Slab Furnace 305 MMBtu/hr Waste Heat Boiler Natural gas, fuel oil, coke oven gas	None	1.10 lbs/MMBtu	OAC rule citation(s)
	P011 No. 1 Slab Reheat Furnace/Waste Heat Boiler 598 MMBtu/hr Slab Furnace 305 MMBtu/hr Waste Heat Boiler Natural gas, fuel oil, coke oven gas	None	1.10 lbs/MMBtu	OAC rule citation(s)
	P012 No. 4 Slab Reheat Furnace/Waste Heat Boiler 598 MMBtu/hr Slab Furnace 305 MMBtu/hr Waste Heat Boiler Natural gas, fuel oil, coke oven gas	None	1.10 lbs/MMBtu	OAC rule citation(s)
AM Cleveland	Facility does not have a boiler			
USS Edgar Thompson	Facility does not have a boiler			
USS East Chicago	B-1 Steam Generation Boiler 181.1 MMBtu/hr max HI (ea.) Natural gas	Flue gas recirculation	None	

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix B: Air Permit Summary for IIS Mills

Blast Furnace Stoves, Casthouses, and Slag Pits				
	Emission Unit Description	Controls	SO ₂ Limit	Comments
AM Indiana Harbor West	1953 No. 3 Blast Furnace Comprised of three No. 3 Blast Furnace Stoves 4,5552 Mmtons/yr input 441 MMBtu/hr max HI total	Integral gas cleaning system consisting of a dust catcher, separator, two scrubbers (primary and secondary) and one cooling tower, with excess gas exhausting through a flare at stack (S1E)	None	Listed controls are for CO only.
		Three Stoves have no controls for SO ₂	0.29 lb/MMBtu 127.89 lb/hr	Pursuant to 326 IAC 7-4.1-10(a)(4)(A) Limit on: Blast Furnace No. 3 Stove Stack
		Passive Emission Control (PEC) to suppress fumes in the casthouse, consisting of slag and iron runner covers along with natural gas flame suppression exhausting to the No. 3 Blast Furnace Casthouse Roof Monitor (V1A).	None	Listed controls are for PM only.
	1967 No. 4 Blast Furnace Comprised of three No. 4 Blast Furnace Stoves 5,490836 Mmtons/yr input 486 MMBtu/hr max HI total	Integral gas cleaning system consisting of a dust catcher, separator, two scrubbers (primary and secondary) and one cooling tower with excess gas exhausting through a flare at stack (S1D)	None	Listed controls are for CO only.
		Three Stoves have no controls for SO ₂	0.29 lb/MMBtu 140.94 lb/hr	Pursuant to 326 IAC 7-4.1-10(a)(4)(B) Limit on: Blast Furnace No. 4 Stove Stack
		Passive Emission Control (PEC) to suppress fumes in the casthouse, consisting of slag and iron runner covers along with natural gas flame suppression exhausting to the No. 4 Blast Furnace Casthouse Roof Monitor (V1B). No. 4 Blast Furnace Casthouse Baghouse used to control emissions from the casthouse with an airflow rate of 147,000 acfm exhausting at stack (S1B) when operating one (1) fan. No. 4 Blast Furnace Casthouse Baghouse has an air flow rate of 240,000 acfm when operating two (2) fans.	0.18 lb/ton 69.9 lb/hr	Pursuant to 326 IAC 7-4.1-10(a)(6) Limit on : Blast Furnace No. 4 Casting Listed controls are for PM only.
AM Indiana Harbor East	2 Ladle Burners 36 MMBtu/hr max HI total	None	None	
	Railcar Thaw Shed Heater 50.4 MMBtu/hr max HI total	None	None	
	1980 No. 7 Blast Furnace Comprised of four No. 7 Blast Furnace Stoves 4,417 Mmtons/yr metal production 953 MMBtu/hr max HI total Pulverized coal (132 tons/hr) / Natural Gas / Blast Furnace Gas	Integral gas cleaning system with excess gas exhausting through Three (3) flares, each with a 1.15 MMBtu per hour igniter capacity of flaring one-third of the maximum generated blast furnace gas through stack 195 Four Stoves have no controls for SO ₂ Casthouse emissions controlled by two baghouses rated at 500,000 acfm (stack 166) and 300,000 acfm (stack 167) respectively. PCI system has two pulverizers each with cyclone and baghouse (stack 187).	None 0.195 lb/MMBtu 162 lb/hr 0.22 lb/ton 50.4 lb/hr per BH None	Listed controls are for CO only. Pursuant to 326 IAC 7-4.1-11(a) Limit on: Blast Furnace No. 7 Stove Stack Pursuant to 326 IAC 7-4.1-11(a) Limit on: Blast Furnace No. 7 Casthouse Listed controls are for PM only. Listed controls are for PM only.
AM Burns Harbor	1971 C Blast Furnace Consisting of C Blast Furnace Stoves 623 tons/hr iron (total with D Blast Furnace) 660 MMBtu/hr max HI total	Integral gas cleaning system consisting of various components including a dust catcher, separator, and 2 scrubbers (primary and secondary), which provides clean fuel to the plant fuel distribution system with excess gas flared Stoves, exhausting to combustion stack (EP520-3547) with an estimated heat input rate of 660 MMBtu/hr East and West casthouses with iron and slag runner fugitive emissions reporting to roof monitors EP520-3543 and 3545 respectively and tap hole and tilting runner emissions controlled by MACT baghouse installed in 2007	None	Listed controls are for CO only. Primarily combust BFG which is a low NO _x fuel Listed controls are for PM only.
		Integral gas cleaning system consisting of various components including a dust catcher, separator, and 2 scrubbers (primary and secondary), which provides clean fuel to the plant fuel distribution system with excess gas flared Stoves, exhausting to combustion stack (EP520-3560) with an estimated heat input rate of 660 MMBtu/hr East and West casthouses with iron and slag runner fugitive emissions reporting to roof monitors EP520-3556 and 3558 respectively and respectively and tap hole and tilting runner emissions controlled by MACT baghouse installed in 2007	None	Listed controls are for CO only. Primarily combust BFG which is a low NO _x fuel Listed controls are for PM only.
	1968 D Blast Furnace Consisting of D Blast Furnace Stoves 623 tons/hr iron (total with C Blast Furnace) 660 MMBtu/hr max HI total			
USS Gary Works	IDBF0369 No. 14 Blast Furnace Comprised of three No. 14 Blast Furnace Stoves (IDST0359) 450 tons metal production/hr 700 MMBtu/hr max HI total Natural gas / Pulverized coal (80 tons/hr) / Oil (150 gal/min) and/or coal tar (150 gal/min)	Stockhouse Baghouse	0.134 lb/MMBtu	Limit on: Blast Furnace No. 14 Stove Stack
			93.5 lb/hr total	Limit on: Blast Furnace No. 14 Stove Stack
			115 lb/hr	Limit on: Blast Furnace No. 14 Casthouse Baghouse Stack
Nucor St. James	Not Constructed Blast Furnace 1 1,088 MMBtu/hr Natural gas, Blast furnace gas	Low sulfur fuels	0.002 gr/dscf Natural Gas (SO ₂ as H ₂ S) 0.00874 gr/dscf BFG	LAC 33.III.509, BACT: Sulfur content in natural gas
	Not Constructed Casthouse No. 1	None	0.040 lb/ton hot metal	LAC 33.III.509, BACT
	Not Constructed Blast Furnace 2 1,088 MMBtu/hr Natural gas, Blast furnace gas	Low sulfur fuels	0.002 gr/dscf Natural Gas (SO ₂ as H ₂ S) 0.00874 gr/dscf BFG	LAC 33.III.509, BACT: Sulfur content in natural gas
	Not Constructed Casthouse No. 2	None	0.040 lb/ton hot metal	LAC 33.III.509, BACT
USS Clairton	Facility does not have a blast furnace			

ArcelorMittal Indiana Harbor West
Regional Haze Four-Factor Analyses for NO_x and SO₂ Emissions Control
Appendix B: Air Permit Summary for II&S Mills

Blast Furnace Stoves, Casthouses, and Slag Pits				
	Emission Unit Description	Controls	SO2 Limit	Comments
AK Dearborn	1/1/1922 EUBFURNACE (part of FGB&CFURNACES), group of 4 stoves with a common stack, cast house emission control system (collection hoods, baghouse, stack), a blast furnace gas scrubber and dust collector, semi-clean bleeder, and dirty gas bleeder. 3,321,500 tons iron/yr (material limit on FGB&CFURNACES) Natural gas, Blast furnace gas	Stoves: No SO2 controls Casthouse: Baghouse Venturi scrubber and mechanical collector for blast furnace pre-cleaning	1,188 tpy (12mo rolling)	Limit on: FGB&CFURNACES baghouse and stove stacks R336.2803, R336.2804 -- PSD
	1/1/1948, 10/1/2007 EUCFURNACE (part of FGB&CFURNACES), group of 4 stoves with a			
AK Middleton	P925 No. 3 Blast Furnace 740 tons metal production/hr	For PM control: equipped with a casthouse baghouse, a settling chamber/dustcatcher (cyclone), a wet venturi scrubber system (Bischoff), stoves, and a blast furnace gas flare	None	
AM Cleveland	P903 Blast Furnace C5	Equipped with a venturi scrubber for cleaning reusable blast furnace gas, natural gas suppression, oxygen enrichment, dirty and clean gas bleeders, and flue dust handling with passive emission control (PEC) system, and flare	33 lb/hr	from the blast furnace casthouse when combusting coke oven gas d. These emission limitations are not applicable because coke oven gas is no longer capable of being burned in this emissions unit.
			53 lb/hr	from the blast furnace stoves when combusting coke oven gas d. These emission limitations are not applicable because coke oven gas is no longer capable of being burned in this emissions unit.
	P904 Blast Furnace C6	Equipped with a venturi scrubber for cleaning reusable blast furnace gas, natural gas suppression, oxygen enrichment, dirty and clean gas bleeders, and flue dust handling with passive emission control (PEC) system and a flare	33 lb/hr	A maximum of 390 grains of hydrogen sulfide per 100 dry standard cubic feet of coke oven gas, and the daily average not to exceed 33 lbs of SO2 per hour from the blast furnace casthouse when combusting coke oven gas.
			53 lb/hr	Maximum of 390 grains of hydrogen sulfide per 100 dscf of coke oven gas and the daily average not to exceed 53 lbs SO2/hr from the blast furnace stoves when combusting coke oven gas.
USS Edgar Thompson	P001a Blast Furnace No. 1 Casthouse 1,752,000 tpy (production capacity) Coke, Iron-bearing materials, fluxes	Stack S002, Casthouse Baghouse (shared between P001a and P002a)	None	
	P002a Blast Furnace No. 3 Casthouse 1,752,000 tpy (production capacity) Coke, Iron-bearing materials, fluxes	Stack S002, Casthouse Baghouse (shared between P001a and P002a)	None	
	P001b Blast Furnace No. 1 Stoves 495 MMBtu/hr BFG, COG, Natural Gas	Stack S001, Dust Catch/Venturi scrubber for BFG cleaning	1. 353.03 lb/hr	1. Applies to each set of stoves (No. 1 Blast furnace stoves & No. 3 Blast furnace stoves) Permit References: (§2104.03.a.2.B, §2104.02.b, §2103.12.a.2.B)
	P002b Base Furnace No. 3 Stoves 495 MMBtu/hr BFG, COG, Natural Gas	Stack S004, Dust Catch/Venturi scrubber for BFG cleaning	2. 108.41 tpy	
	P001c BFG Flare 3 MMcfh BFG	Stack S003	3. A = 1.7 E ^{-0.14}	
USS East Chicago	Facility does not have a blast furnace			

Appendix C

2008 ArcelorMittal Burns Harbor BART Modeling

Prepared for: ArcelorMittal Burns Harbor LLC
Burns Harbor, Indiana



Source-Specific BART Modeling Report: ArcelorMittal Burns Harbor LLC


ENSR Corporation
August 2008
Document No.: 12591-001-0600

Prepared for: Mittal Steel USA
Burns Harbor, Indiana

Source-Specific BART Modeling Report: ArcelorMittal Burns Harbor LLC



Prepared By: Jeffrey Connors



Reviewed By: Olga Kostrova

ENSR Corporation
August 2008
Document No.: 12591-001-0600

Contents

1.0 Introduction	1-1
1.1 Objectives	1-1
1.2 Location of Source vs. Relevant Class I Areas	1-1
1.3 Organization of Report Document	1-2
2.0 Emissions and Source Parameters	2-1
3.0 Meteorological Data.....	3-1
3.1 Elements of the Refined Analysis	3-1
3.2 CALMET Processing	3-1
4.0 CALPUFF Modeling	4-1
4.1 CALPUFF Modeling Domain and Receptors.....	4-1
4.2 Technical Options Used in the Modeling	4-1
4.3 Natural Conditions and Monthly f(RH) at Class I Areas	4-1
4.4 Light Extinction and Haze Impact Calculations	4-3
5.0 Modeling Results	5-1
6.0 References	6-1

List of Appendices

- Appendix A: Meteorological Stations used in CALMET Processing
- Appendix B: Re-Calculating CALPOST Visibility Outputs with the New IMPROVE Algorithm

List of Tables

Table 2-1	Burns Harbor Facility Baseline Emission Rates - Maximum by Emission Unit.....	2-3
Table 2-2	Burns Harbor Facility Modeling Stack Parameters	2-4
Table 2-3	Burns Harbor Facility Baseline Emission Rates - Plant-wide Maximum Emission Day	2-5
Table 2-4	Combustion Unit Emission Factors Used In Emissions Calculations.....	2-6
Table 2-5	Process Unit Emission Factors Used In Emissions Calculations	2-7
Table 3-1	CALMET User-Defined Fields Not Specified in IWAQM Appendix A.....	3-2
Table 4-1	MWRPO Ozone and Ammonia Seasonal Concentrations	4-1
Table 4-2	Annual Average Natural Background Concentrations	4-3
Table 4-3	New IMPROVE Equation Background Sea Salt Concentration and Site-specific Rayleigh Scattering Coefficient	4-3
Table 5-1	BART Exemption Modeling Results - Maximum by Emission Unit.....	5-1
Table 5-2	BART Exemption Modeling Results - Plant-wide Maximum Emission Day	5-1

List of Figures

Figure 1-1	Location of Class I Areas in Relation the Burns Harbor Facility	1-3
Figure 3-1	Burns Harbor CALMET and CALPUFF Modeling Domain	3-3
Figure 3-2	Location of Meteorological Stations used in CALMET Processing	3-4

1.0 Introduction

1.1 Objectives

The Regional Haze Rule regulations require Best Available Retrofit Technology (BART) for any BART-eligible source that “emits any air pollutant which may reasonably be anticipated to cause or contribute to any impairment of visibility” in any mandatory Class I federal area. Pursuant to federal regulations, states and/or local regulatory agencies have the option of exempting a BART-eligible source from the BART requirements based on dispersion modeling demonstrating that the source cannot reasonably be anticipated to cause or contribute to visibility impairment in a Class I area. Indiana’s BART rule at 326 IAC 26-1-6 allows Burns Harbor to submit an analysis sufficient to demonstrate that it is not subject to BART. That analysis was timely submitted in May 2008 within ninety (90) days after receiving IDEM’s BART notice. IDEM identified some outdated emission factors that were inadvertently included in the May 2008 Report. This revised Source-Specific BART Modeling Report updates the May 2008 Report with improved model inputs based on the most recent and accurate emission information available for each emissions unit.

ArcelorMittal Burns Harbor LLC (Burns Harbor) is a facility located on Lake Michigan in northwestern Indiana, approximately 50 miles southeast of Chicago. The Burns Harbor facility is a steelmaking facility that has been identified by Indiana Department of Environmental Management (IDEM) as being a BART-eligible source. The purpose of this Report is to summarize the procedures by which a refined air dispersion modeling analysis was conducted for the Burns Harbor facility and to transmit an analysis of the modeling results in accordance with 326 IAC 26-1-6 in support of a refined assessment of Burns Harbor’s contribution to visibility impairment in Class I areas.

The first step in the BART process is to model the visibility impact of baseline emissions to determine whether the BART-eligible sources at a facility are subject to BART. According to the BART rule (326 IAC 26-1-4), a facility will be exempt from BART if its 98th percentile visibility impacts for baseline emissions are less than 0.5 delta-deciviews (delta-dv) in each Class I area for each modeled year. The refined modeling provided in this Report demonstrates that Burns Harbor’s impact on all relevant Class I Areas is comfortably below 0.5 deciviews and cannot reasonably be anticipated to cause or contribute to visibility impairment in a Class I Area.

1.2 Location of Source vs. Relevant Class I Areas

Figure 1-1 shows a plot of the Burns Harbor facility relative to nearby Class I areas. There are no PSD Class I areas within 300 km of the facility, which is the outer extent of the reliability range for predicting impacts with CALPUFF air dispersion modeling. Nonetheless, the four closest Class I areas were included in the modeling to capture possible impacts from the Burns Harbor facility. These Class I areas are listed below:

- Isle Royale National Park (674 km)
- Mammoth Cave National Park (485 km)
- Mingo Wilderness (580 km)
- Seney Wilderness (539 km)

IDEM’s CALPUFF modeling screened for potential contributions to visibility impairment from the Burns Harbor facility at these four Class I areas. The refined modeling summarized in this Report offers a more accurate assessment of the potential contribution of Burns Harbor to visibility impairments at any of these far-off Class I areas. This Report describes in detail the procedures used for this refined CALPUFF modeling.

CALPUFF is the only EPA-approved model for predicting impacts for long-range emission transport beyond 50 km. The Guideline on Air Quality Models (GAQM) (Appendix W to 40 CFR Part 51) suggests that CALPUFF “had performed in a reasonable manner, and had no apparent bias toward over or under prediction, so long as


the transport distance was limited to less than 300 km". Beyond 300 km, CALPUFF's modeled impacts are less reliable with a tendency toward over predicting impacts.

The closest Class I area is Mammoth Cave NP, located approximately 485 km to the south-southeast well beyond the suggested use of CALPUFF. The modeling analysis in this Report uses CALPUFF as directed by the Midwest Regional Planning Organization (MWRPO) and IDEM with the stipulation that the model's performance has tended toward over prediction of modeled impacts beyond 300 km and the fact that the federal Guidance suggests that its use beyond 300 km may not be reliable or appropriate.

1.3 Organization of Report

Section 2 of this report describes the method for determining the peak 24-hour source emissions that were used as input to the BART modeling. Section 3 describes refinements to the meteorological database and the CALMET processing that provide essential data for predicting the transport of emissions. Section 4 discusses CALPUFF technical options and modeling procedures. Section 5 presents the modeling results. References are provided in Section 6. Appendix A lists meteorological stations that were used for CALMET processing and Appendix B provides documentation of the implementation of the new IMPROVE equation. Appendix C provides a detailed description of the method used to derive the oxides of nitrogen and sulfur dioxide inputs to the model.

Figure 1-1 Location of Class I Areas in Relation the Burns Harbor Facility



2.0 Emissions and Source Parameters

The Lake Michigan Air Directors Consortium (LADCO) developed a protocol to be used in the BART CALPUFF modeling for Indiana. The LADCO protocol specifies that “States will use the 24-hour maximum emissions rate between 2002 and 2004. If this data is not available, then a short term “allowable” or “potential emission rate of emissions between the years 2002-2004 will be used. If neither of these types of emission rates is available, then the highest actual annual emissions divided by hours of operation will be applied in CALPUFF.” For this Report, we calculate the 24-hour maximum emission rate for the years 2002-2004.

Emission units included in the modeling are of two main types, combustion units and process units. Combustion unit emissions are calculated using actual daily fuel use records from Burns Harbor’s computerized database for 2002, 2003, and 2004 and relevant emission factors. The emission factors for combustions units are based on fuel sampling, stack testing, or U.S. EPA’s AP-42 (see Table 2-4). The 24-hour emission rate was determined by multiplying the daily fuel use day for each fuel used that day by the appropriate emission factor for each combustion unit for 2002, 2003 and 2004. Emission for each fuel used was summed to determine the total emissions for each unit by day. The 24-hour maximum emission rate was determined by selecting the highest total emissions day for each unit and were used as the maximum 24-hour emissions inputs to the CALPUFF model.

Burns Harbor’s Power Station contains multi-fuel Boiler Nos. 7 through 12. The Power Station is operated as one unit with switching between boilers as necessary to provide the needed steam and to maintain backup capabilities. Consequently, fuel use and emissions calculations were determined for the entire Power Station rather than for individual boilers to more accurately reflect 24-hour maximum emissions.

Process unit emissions are calculated using the maximum 24-hour production rate for each process unit during 2002, 2003 and 2004 and appropriate emission factors per unit of production. The process emission factors were derived from stack tests on the same or similar units and from AP-42 emission factors (see Table 2-5). For smaller incidental units (e.g., FM Boiler, Hot Metal Desulfurization, etc.) where only monthly production data were available, the average daily production was calculated by dividing the monthly production by the number of days in the period. The day with the highest calculated sulfur dioxide emission rate and the day with the highest oxides of nitrogen emissions rate from 2002, 2003 or 2004 were selected for each process unit as the maximum 24-hour emission inputs to the CALPUFF model.

Emissions from slag pits and steelmaking fugitives that do not vent through stacks are “volume” sources (see Table 2-1). Without stacks, volume sources have limited velocity at the point of emission and are, thus, not expected to be transported very far away from the emission source. As such, we do not expect these volume sources to contribute to visibility impacts that require the transport of emissions to Class I areas over 480 km away. Nonetheless, we conservatively included the emissions from volume sources in the modeling by adding their emissions to the combustion emissions from the Power Station.

This method combines the highest daily emission rates for each of 26 emission units (+3 volume sources) into a fictitious worst case day. A complex steel manufacturer cannot simultaneously achieve the 24-hour maximum emission rate at all 26+ emission units listed in Table 2-1. While the modeling demonstrates that Burns Harbor’s visibility impact is acceptable even using this highly conservative approach (see Table 5-1), This scenario conservatively overestimates the impact on Class I areas. In order to estimate plant emissions on a more realistic basis, we calculated the maximum individual day of plant-wide sulfur dioxide and oxides of nitrogen emissions during the period of 2002 through 2004. Daily sulfur dioxide and oxides of nitrogen emissions from all emission units were summed for each day to obtain the total plant daily emissions. The plant-wide daily sulfur dioxide and oxides of nitrogen emissions for 2002, 2003 and 2004 were scanned to determine the highest daily plant-wide emissions for each of the two pollutants. These maximum 24-hour plant-wide emission rates for sulfur dioxide emissions and for oxides of nitrogen were used as inputs in a

separate modeling run summarized in Table 5-2. The modeling results confirm that Burns Harbor is comfortably below the threshold that triggers BART regulation when using this more realistic assessment of the 24-hour maximum emission rate as input to the CALPUFF model.

Table 2-1 provides a summary of the baseline emissions used in the BART CALPUFF model to model the maximum day on an emission unit basis. Table 2-2 provides the modeling parameters that were used in the BART CALPUFF modeling. Table 2-3 provides a summary of the baseline emissions used in the plant-wide maximum emission day modeling. The same modeling parameters in Table 2-2 were used for the plant-wide maximum modeling. Table 2-4 contains the emission factors used to calculate emissions for combustion units. Table 2-5 provides the emission factors used to calculate emissions from process units.

Table 2-1 Burns Harbor Facility Baseline Emission Rates - Maximum by Emission Unit

Stack Description	Peak 24-Hour Emissions (g/s)		Fuel & Production Data Record Frequency
	SO ₂	NO _x	
POWER STATION Boiler Nos 7-12	218.31	162.49	Daily
#1 COKE BATTERY PUSHING	1.38	0.27	Monthly
#1 COKE BATTERY UNDERFIRE	64.13	94.53	Daily
#2 COKE BATTERY PUSHING	1.39	0.27	Monthly
#2 COKE BATTERY UNDERFIRE	69.29	5.45	Daily
SINTER WINDBOX STACK	25.20	43.59	Daily
BLAST FCE D CASTHOUSE/FUG	0.00	1.02	Monthly
BLAST FURNACE C STOVES	42.03	4.27	Daily
BLAST FURNACE D STOVES	41.88	4.33	Daily
BLAST FCE C CASTHOUSE/FUG	0.00	0.99	Monthly
STEELMAKING HMD STATION #1	0.30	0.02	Monthly
STEELMAKING HMD STATION #2	0.30	0.02	Monthly
STEELMAKING VESSELS #1 & #2	0.09	2.76	Monthly
STEELMAKING VESSEL #3	0.09	1.53	Monthly
STEELMAKING FM BOILER	0.002	0.47	Monthly
HOT STRIP FURNACE #1	7.74	7.36	Daily
HOT STRIP FURNACE #3	7.93	8.16	Daily
HOT STRIP FURNACE #2	7.95	7.17	Daily
160" PLATE MILL FURNACE #1	18.17	4.09	Daily
160" PLATE MILL FURNACE #2	25.28	4.39	Daily
160" PLATE MILL FURNACE #5	0.00	0.00	Daily
160" PLATE MILL FURNACES 6 & 7	0.01	1.27	Daily
160" PLATE MILL FURNACE #8	0.00	0.00	Daily
110 PLATE MILL FURNACES 1 & 2	0.00	0.00	Daily
STEELMAKING HMD STATION #3	0.26	0.02	Monthly
110" Plate Mill Normalizing Fce	0.00	0.00	Daily

Volume Source Description ⁽¹⁾	Model Inputs (g/s)	
	SO ₂	NO _x
Blast Furnace C Slag Pit	4.04	0.00
Blast Furnace D Slag Pit	3.36	0.00
Steelmaking Fugitives	0.37	0.99

(1) Total emission from the volume sources were added to the Power Station Source when modeled. Production data frequency is monthly for all volume sources

Table 2-2 Burns Harbor Facility Modeling Stack Parameters

Stack Description	Base Elevation(m)	Stack Height (m)	Diameter (m)	Flow (m ³ /s)	Temperature (K)	Exit velocity (m/sec)	UTM Easting (m)	UTM Northing (m)
POWER STATION Boiler Nos 7-12	187.14	67.06	3.43	123.2	505	13.34	488375	4609318
#1 COKE BATTERY PUSHING	187.54	20.12	0.76	4.3	323	9.44	488045	4608362
#1 COKE BATTERY UNDERFIRE	187.15	76.81	3.78	80.2	547	7.15	487968	4608346
#2 COKE BATTERY PUSHING	187.15	26.82	2.44	94.4	335	20.20	488059	4608115
#2 COKE BATTERY UNDERFIRE	187.14	75.90	4.18	63.4	505	4.48	487959	4608191
SINTER WINDBOX STACK*	187.15	24.08	2.39	247.2	319	55.12	488038	4609329
BLAST FCE D CASTHOUSE/FUG	187.14	18.90	1.56	47.2	533	24.70	488203	4609371
BLAST FURNACE C STOVES	187.15	61.26	3.48	151.1	519	15.89	488244	4609339
BLAST FURNACE D STOVES	187.14	61.26	3.59	151.1	519	14.93	488229	4609496
BLAST FCE C CASTHOUSE/FUG	187.14	18.90	1.56	47.2	533	24.70	488203	4609371
STEELMAKING HMD STATION #1	187.14	25.91	2.05	42.7	305	12.95	488512	4609936
STEELMAKING HMD STATION #2	187.14	25.91	3.04	42.7	305	5.89	488542	4609936
STEELMAKING VESSELS #1 & #2	187.15	24.99	6.02	160.7	325	5.65	488544	4609957
STEELMAKING VESSEL #3	187.15	11.58	6.71	93.4	332	2.64	488555	4610037
STEELMAKING FM BOILER	187.15	67.66	1.99	5.6	478	1.79	488690	4609918
HOT STRIP FURNACE #1	187.14	41.45	4.30	402.5	811	7.06	489030	4609212
HOT STRIP FURNACE #3	187.14	41.45	3.97	109.0	811	8.81	489063	4609212
HOT STRIP FURNACE #2	187.14	41.45	4.30	102.0	811	7.02	489046	4609212
160" PLATE MILL FURNACE #1	187.14	54.25	3.10	33.0	673	4.37	489014	4609043
160" PLATE MILL FURNACE #2	187.14	54.25	3.10	33.0	693	4.09	489035	4609043
160" PLATE MILL FURNACE #5	187.14	39.92	1.95	37.3	783	12.48	489054	4609039
160" PLATE MILL FURNACES 6 & 7	187.14	32.92	2.24	39.3	783	9.99	489042	4608914
160" PLATE MILL FURNACE #8	187.14	50.90	1.74	7.1	673	2.99	489042	4608894
110 PLATE MILL FURNACES 1 & 2	187.14	54.56	4.44	33.0	838	2.13	489030	4608811
STEELMAKING HMD STATION #3	187.14	25.91	2.05	42.7	305	12.95	488601	4609962
110" Plate Mill Normalizing Fce	187.14	45.72	1.92	12.4	505	4.27	489801	4608431

Table 2-3 Burns Harbor Facility Baseline Emission Rates - Plant-wide Maximum Emission Day

Stack Description ⁽²⁾	Peak 24-Hour Emissions (g/s)	
	SO ₂	NO _x
POWER STATION Boiler Nos 7-12	218.31	162.49
#1 COKE BATTERY PUSHING	1.38	0.25
#1 COKE BATTERY UNDERFIRE	61.34	81.30
#2 COKE BATTERY PUSHING	1.39	0.25
#2 COKE BATTERY UNDERFIRE	64.26	4.65
SINTER WINDBOX STACK*	25.20	37.31
BLAST FCE D CASTHOUSE/FUG	0.00	1.02
BLAST FURNACE C STOVES	29.20	3.44
BLAST FURNACE D STOVES	32.28	3.28
BLAST FCE C CASTHOUSE/FUG	0.00	0.99
STEELMAKING HMD STATION #1	0.30	0.02
STEELMAKING HMD STATION #2	0.30	0.02
STEELMAKING VESSELS #1 & #2	0.15	2.54
STEELMAKING VESSEL #3	0.08	1.53
STEELMAKING FM BOILER	0.00	0.43
HOT STRIP FURNACE #1	4.23	5.97
HOT STRIP FURNACE #3	0.00	6.09
HOT STRIP FURNACE #2	4.29	6.14
160" PLATE MILL FURNACE #1	3.23	1.89
160" PLATE MILL FURNACE #2	3.31	1.83
160" PLATE MILL FURNACE #5	0.00	0.00
160" PLATE MILL FURNACES 6 & 7	0.00	0.00
160" PLATE MILL FURNACE #8	0.00	0.00
110 PLATE MILL FURNACES 1 & 2	0.00	0.00
STEELMAKING HMD STATION #3	0.26	0.02
110" Plate Mill Normalizing Fce	0.00	0.00

Volume Source Description ⁽¹⁾	Model Inputs (g/s)	
	SO ₂	NO _x
Blast Furnace C Slag Pit	3.28	0.00
Blast Furnace D Slag Pit	2.85	0.00
Steelmaking Fugitives	0.37	0.99

(1) Total emission from the volume sources were added to the Power Station Source when modeled. Production data frequency is monthly for all volume sources

(2) Fuel use and production data record frequency is same as that shown in Table 2-1.

Table 2-4 Combustion Unit Emission Factors Used In Emissions Calculations

Sulfur Dioxide

Fuel	Emission Units	SO ₂ Emission Factor (lb/MMBTU)	Source of Emission Factor
Blast Furnace Gas	All Units	0.13	Based on stack test used as basis for annual emission fees reporting
Coke Oven Gas		Varies from 1.088 to 1.395	Semi-annual testing of No. 2 Coke Battery Underfiring Stack when combusting coke oven gas
Natural Gas		0.0006	AP-42, External Combustion

Oxides of Nitrogen

Fuel	Emission Units	NO _x Emission Factor (lb/MMBTU)	Source of Emission Factor
Blast Furnace Gas	All Units Except Coke Battery Underfiring and Hot Strip Mill Reheat Furnaces	0.0100	ISG Indiana Harbor test of No. 7 Boiler Stack on 5/11/04
Coke Oven Gas		0.1367	FIRE database [SCC 10200707]
Natural Gas		0.1373	AP-42, External Combustion, Table 1.4-1, Low-NO _x Burners. Converted from lb/MMscf using 1020 BTU/scf.
Fuel	Emission Units	NO _x Emission Factor (lb/MMcf)	Source of Emission Factor
Blast Furnace Gas	No. 1 Coke Battery Underfiring	168.50	Average of 1995 & 2000 Burns Harbor Stack Tests
Coke Oven Gas		987	Average of 1995 & 2000 Burns Harbor Stack Tests
Natural Gas		NA	NA
Blast Furnace Gas	No. 2 Coke Battery Underfiring	NA	NA
Coke Oven Gas		60.57	2000 Burns Harbor Stack Test
Natural Gas		NA	NA
Coke Oven Gas	Hot Strip Mill Reheat Fce. Nos. 1, 2 & 3	82.07	2/14/06 Burns Harbor Stack Test
Natural Gas		143.14	

Table 2-5 Process Unit Emission Factors Used In Emissions Calculations

Source	Pollutant	Emission Factor Uncontrolled	Units	Capture Efficiency (Control Device)	Control Efficiency (Control Device)	Controlled Emission Factor (lb/unit)	Source of Emission Factor
HMD Station Nos. 1, 2 & 3 Baghouse Stack Emissions	NOx	0.00100	lbs/ton HM	98.00%	0.00%	0.00098	BH Test Data (HMD/transfer/skimming) 8/13/02 Stack Test @ #2 HMD
	SO2	0.01400	lbs/ton HM	98.00%	0.00%	0.01372	BH Test Data (HMD/transfer/skimming) 8/13/02 Stack Test @ #2 HMD
BOF Nos. 1 & 2 (refining/blow) Stack Primary Emissions	NOx	0.05400	lbs/ton steel	99.80%	0.00%	0.05389	BH Test 9/29/93-10/14/93
	SO2	0.00604	lbs/ton steel	99.80%	50.00%	0.00302	BH 4/7/05 Test
BOF No. 3 (refining/blow) Stack Primary Emissions	NOx	0.05400	lbs/ton steel	99.99%	0.00%	0.05399	BH Test 9/29/93-10/14/93
	SO2	0.00604	lbs/ton steel	99.99%	50.00%	0.00302	BH 4/7/05 Test
Ladle Treatment Station (LTS) Nos. 4 & 5 BH Stack Emissions	NOx	0.00300	lbs/ton steel	99.99%	0.00%	0.00300	ArcelorMittal Indiana Harbor f/k/a Inland 2001 Emission Inv 2BOF Ladle Metallurgy
	SO2	0.02500	lbs/ton steel	99.99%	0.00%	0.02500	ArcelorMittal Indiana Harbor f/k/a Inland 2001 Emission Inv 2BOF Ladle Metallurgy
Steel Ladle Desulf Station Nos. 2 & 3 BH Stack Emissions	SO2	0.00245	lbs/ton steel	90.00%	0.00%	0.00221	Same SO2 emitted/steel sulfur conc. as HMD
Vacuum Degasser Process Flare Stack Emissions	NOx	0.00015	lbs/ton steel	100.00%	0.00%	0.00015	USS Gary Works 1998 Application for RH Vacuum Degasser
Coke Battery No. 1 Pushing	NOx	N/A	lbs/ton coal	N/A	N/A	0.01900	AP-42 Table 12.2-9
	SO2	N/A	lbs/ton coal	N/A	N/A	0.09800	AP-42 Table 12.2-9
Coke Battery No. 2 Pushing	NOx	N/A	lbs/ton coal	N/A	N/A	0.01900	AP-42 Table 12.2-9
	SO2	N/A	lbs/ton coal	N/A	N/A	0.09800	AP-42 Table 12.2-9
BF C Slag Pit	SO2	0.08500	lbs/ton HM	100.00%	0.00%	0.08500	USS Gary Works and Mittal Indiana Harbor West SIP Model
BF D Slag Pit	SO2	0.08500	lbs/ton HM	100.00%	0.00%	0.08500	USS Gary Works and Mittal Indiana Harbor West SIP Model
Sinter Plant Windbox	NOx	N/A	lbs/ton sinter	N/A	N/A	0.66700	BH 1/8/97 Test
	SO2	N/A	lbs/hr	N/A	N/A	200	Engineering Estimate based on stack sampling in 2008*

* Engineering evaluation in 2008 confirmed that Sinter Plant Windbox Scrubber properly operated sustained SO2 emissions below 200 lb./ ton.

3.0 Meteorological Data

This section discusses refinements to Lake Michigan Air Directors Consortium (LADCO) and Midwest Regional Planning Organization (MWRPO) meteorological database that were used for the Burns Harbor facility BART modeling.

3.1 Elements of the Refined Analysis

ENSR refined the CALMET meteorological data produced by LADCO/MWRPO for BART CALPUFF analyses for Midwestern States. The CALMET database derived by LADCO/MWRPO has a domain that covers approximately a 3,492 km (east-west) by 3,240 km (north-south) area with a 36-km grid resolution. This area covers the entire continental United States east of the Rocky Mountains, but its large size limits the horizontal resolution of each grid element to 36 km. This coarse grid resolution can be deemed appropriate for a screening-level analysis, but it would not be considered appropriate for a more refined analysis.

ENSR developed a refined meteorological database that would include a modeling domain encompassing the four Class I areas (Seney, Mingo, Mammoth, and Isle Royale), the Burns Harbor facility, and the appropriate buffers around the source and Class I areas for puffs recirculation. This domain covers approximately a 1,002 km (east-west) by 1,374 km (north-south) area, has a grid resolution of 6 km (6 times more resolved than the LADCO/MWRPO database in both east-west and north-south directions), and contains 10 vertical levels. The refined database utilizes the same MM5 databases that were used to develop the LADCO/MWRPO 36-km CALMET database.

In addition to the use of consistent MM5 databases with the LADCO-developed meteorological data, ENSR utilized similar model switches/settings, when appropriate, that were used to develop the LADCO/MWRPO CALMET database. To improve the database even further, ENSR introduced actual surface, precipitation, and twice-daily upper air sounding observations into the refined meteorological database. These improvements in the CALMET database provide more accurate plume trajectories from the Burns Harbor facility to the distant Class I areas.

In addition, ENSR used the latest EPA-approved versions of CALMET (Version 5.8) and CALPUFF (Version 5.8), rather than the "old" EPA-approved versions suggested in the MWRPO BART common protocol (available at http://www.state.in.us/idem/programs/air/workgroups/regionalhaze/docs/BART_protocol.pdf).

3.2 CALMET Processing

ENSR used refined 6-km grid spacing for the CALMET and CALPUFF models. The modeling domain was based on a 100 km buffer around the source and a 50 km buffer around each of the four Class I areas plus an additional buffer to the east and to the west to account for puffs recirculation. The modeling domain is shown in Figure 3-1. This design allows for a 1,002 km (east-west) x 1,374 km (north-south) domain extent and, at a 6-km resolution, there are 167 x 229 horizontal grid cells.

Due to the size of the modeling domain, a Lambert Conformal Conic (LCC) coordinate system was used to account for the curvature of the Earth's surface. The LCC projection for this analysis was based on the NAS-C datum and standard parallels of 33 and 45 degrees North, with an origin of 40 degrees North and 97 degrees West.

ENSR used the latest EPA-approved version of CALMET (Version 5.8, Level 070623) to produce three-dimensional wind fields for three years (2002-2004). Advanced meteorological data in the form of prognostic mesoscale meteorological data, such as the Fifth Generation Mesoscale Model (MM5), were used to provide a superior estimate of the initial wind fields. This application considered 3 years (2002-2004) of prognostic MM5 meteorological data at a 36-km resolution.

- 2002 MM5 data set at 36 km resolution provided by CENRAP;
- 2003 MM5 data set at 36 km resolution provided by Midwest RPO;
- 2004 MM5 data set at 36 km resolution provided by Midwest RPO.

These databases are consistent with those used by LADCO/MWRPO for their BART assessments.

These prognostic meteorological data sets were combined with the 6-km grid resolution terrain and land use data to more accurately characterize the wind flow throughout the modeling domain. The gridded terrain data was derived using several data sources because the modeling domain extends into Canadian territory. The U.S. Geological Survey (USGS) 90-meter grid spacing Digital Elevation Model (DEM) files were combined with the 100-meter grid spacing Canadian DEM files and the 90-meter spacing Shuttle RADAR Topo Mission files. These files were processed in the TERREL pre-processor program. The gridded land use data was derived from USGS 1:250,000 Composite Theme Grid land use files.

The Step 2 wind fields were produced using the input of all available National Weather Service (NWS) hourly surface and twice-daily upper air balloon sounding data within and just outside the modeling domain. Hourly surface data from both first-order and second-order stations also were considered in this analysis. Other sources of meteorological data such as CASTNET data and buoy stations were used to supplement areas lacking NWS or second-order data. Hourly precipitation data from stations within and just outside of the modeling domain were taken from a National Climatic Data Center data set. Figure 3-2 shows the meteorological stations that were used in the CALMET modeling and Appendix A provides their names and locations.

The non-default user-defined settings proposed for the CALMET processing are provided in Table 3-1.


Table 3-1 CALMET User-Defined Fields Not Specified in IWAQM Appendix A

Variable	Description	Value
NX	Number of east-west grid cells	167
NY	Number of north-south grid cells	229
DGRIDKM	Meteorology grid spacing (km)	6.0
NZ	Number of Vertical layers of input meteorology	10
ZFACE	Vertical cell face heights (m)	0.,20.,40.,80.,160.,300.,600.,1000.,1500.,2000.,3500.
RMAX1	Max surface over-land extrapolation radius (km)	40
RMAX2	Max aloft over-land extrapolation radius (km)	40
RMAX3	Maximum over-water extrapolation radius (km)	100
TERRAD	Radius of influence of terrain features (km)	15
R1	Relative weight at surface of Step 1 field and obs	5
R2	Relative weight aloft of Step 1 field and obs	5
IUPT	Station for lapse rates	International Falls, MN
IPROG	Gridded initial prognostic wind field – MM4/MM5 data	14

Figure 3-1 Burns Harbor CALMET and CALPUFF Modeling Domain



Figure 3-2 Location of Meteorological Stations used in CALMET Processing



4.0 CALPUFF Modeling

This section provides a summary of the modeling procedures that were used for the refined CALPUFF analysis conducted for the Burns Harbor facility.

4.1 CALPUFF Modeling Domain and Receptors

ENSR used the latest EPA-approved version of CALPUFF (Version 5.8, Level 070623) that has been posted at http://www.src.com/calpuff/download/download.htm#EPA_VERSION.

The extent of the CALMET/CALPUFF modeling domain are shown in Figure 3-1. The modeling domain included a 100 km buffer around the source and a 50 km buffer around each of the four Class I areas plus an additional buffer to the east and to the west to account for puffs recirculation. This design allows the modeling domain to extend 1,002 km east-west and 1,374 km north-south and have a 6-km grid element size.

The receptors for each of the Class I areas were based on the National Park Service database of Class I receptors.

4.2 Technical Options Used in the Modeling

For CALPUFF model technical options, inputs and processing steps, Burns Harbor followed the MWRPO common BART protocol.

For CALPUFF modeling, ENSR used seasonal ozone and ammonia ambient background concentrations that are consistent with the MWRPO common BART modeling protocol. For convenience, there values are listed in Table 4-1.

Table 4-1 MWRPO Ozone and Ammonia Seasonal Concentrations

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
O ₃ (ppb)	31	31	31	37	37	37	33	33	33	27	27	27
NH ₃ (ppb)	.3	.3	.3	.5	.5	.5	.5	.5	.5	.5	.5	.5

Due to the large distance to the nearest Class I area, building downwash effects were not included in the CALPUFF modeling.

4.3 Natural Conditions and Monthly f(RH) at Class I Areas

There are four Class I areas to be modeled for the Burns Harbor facility. For these Class I areas, natural background conditions must be established in order to determine a change in natural conditions related to a source's emissions.

For BART analyses, EPA has chosen to accept either the annual average or 20% best day's natural background for BART exemption and determination modeling analyses. Regional Planning Organization(s) (RPOs) have provided guidance to states within their RPOs on what values to accept, which typically has varied based on the degree of the meteorological database refinement. Since MWRPO uses the 36-km database with no observations, as a measure of conservatism, MWRPO/LADCO recommended to states that the 20% best day's background be incorporated into the analysis as opposed to the annual average. This conservative approach compensated for the inaccuracy of the 36-km meteorological data in no-obs mode.

Model refinements to improve accuracy reduce the need for conservative background assumptions. For instance, Wisconsin, a MWRPO state, has stated that they would allow sources to use the annual average background with the 98th percentile day as opposed to the 20% best days if a site-specific meteorological database is developed.

In addition, states within the VISTAS RPO* have uniformly decided to allow sources to use the annual average background coupled with the 98th percentile day when refined meteorological data (that incorporates observations) is used as input to the BART CALPUFF runs. This procedure was approved by EPA Region 4. To conduct the BART modeling, VISTAS, like the MWRPO, developed its own coarse no-obs 12-km resolution CALMET meteorological database covering all VISTAS states and Class I areas within 300 km. The 12-km CALMET meteorological data was used in the modeling analyses as a screening step to exempt BART eligible sources that, based on modeling, did not cause or contribute to visibility impairment (i.e. according to the BART rule did not have impacts greater than 0.5 dv). VISTAS also developed a more refined 4-km resolution CALMET databases that covered a sub-set of the large 12-km grid. These databases were able to be used in refined BART modeling analyses along with the annual average background. To ENSR's knowledge, all VISTAS states have accepted the use of the annual average background.

Burns Harbor used refined meteorological database with a finer grid resolution (6-km) and introduced surface observations. In addition, ENSR used the annual average background while evaluating BART exemption based on the source's impacts at the 98th percentile day. This procedure is consistent with the modeling approach taken by other eastern states and consistent with Wisconsin's approach within the MWRPO.

For the modeling described in this document, ENSR used the annual average natural background concentrations shown in Table 4-2, modified as noted below with site-specific considerations (as shown in Table 4-3), and corresponding to the annual average natural background concentrations (EPA 2003, Appendix B).

To determine the input to CALPOST, it is first necessary to convert the deciviews to extinction using the equation:

$$\text{Extinction (Mm}^{-1}\text{)} = 10 \exp(\text{deciviews}/10).$$

For example, for Mingo, 7.43 deciviews is equivalent to an extinction of 21.02 inverse megameters (Mm^{-1}); this extinction includes the default 10 Mm^{-1} for Rayleigh scattering. This remaining extinction is due to naturally occurring particles, and is held constant for the entire year's simulation. Therefore, the data provided to CALPOST for Mingo would be the total natural background extinction minus 10 (expressed in Mm^{-1}), or 11.02. This is most easily input as a fine soil concentration of 11.02 $\mu\text{g}/\text{m}^3$ in CALPOST, since the extinction efficiency of soil (PM-fine) is 1.0 and there is no f(RH) component. The concentration entries for all other particle constituents would be set to zero, and the fine soil concentration would be kept the same for each month of the year. The monthly values for f(RH) that CALPOST needs were taken from "Guidance for Tracking Progress Under the Regional Haze Rule" (EPA, 2003) Appendix A, Table A-3.

* The VISTAS states include: Alabama, Florida, Georgia, Kentucky, Mississippi, North Carolina, South Carolina, Tennessee, Virginia, and West Virginia.

Table 4-2 Annual Average Natural Background Concentrations

Component Represented	Isle Royale	Mammoth Cave	Mingo	Seney
Soil (PM fine) (deciview)	7.38	7.69	7.43	7.53
Soil (PM fine) (Mm^{-1} or $\mu\text{g}/\text{m}^3$)	20.92	21.58	21.02	21.23

* Extinction values include Rayleigh scattering.

Table 4-3 New IMPROVE Equation Background Sea Salt Concentration and Site-specific Rayleigh Scattering Coefficient

Parameter	Isle Royale	Mammoth Cave	Mingo	Seney
Sea Salt Concentration ($\mu\text{g}/\text{m}^3$)	0.03	0.02	0.01	0.02
Rayleigh Scattering Coefficient (Mm^{-1})	12	11	12	12

Note: Data taken from VIEWS website (<http://vista.cira.colostate.edu/views/>)

4.4 Light Extinction and Haze Impact Calculations

The CALPOST postprocessor was used for the calculation of the impact from the modeled source's primary and secondary particulate matter concentrations on light extinction. The formula that is used is the existing IMPROVE/EPA formula, which is applied to determine a change in light extinction due to increases in the particulate matter component concentrations. Using the notation of CALPOST, the formula is the following:

$$b_{\text{ext}} = 3 f(\text{RH}) [(\text{NH}_4)_2\text{SO}_4] + 3 f(\text{RH}) [\text{NH}_4\text{NO}_3] + 4[\text{OC}] + 1[\text{Soil}] + 0.6[\text{Coarse Mass}] + 10[\text{EC}] + b_{\text{Ray}}$$

The concentrations, in square brackets, are in $\mu\text{g}/\text{m}^3$ and b_{ext} is in units of Mm^{-1} . The Rayleigh scattering term (b_{Ray}) has a default value of 10 Mm^{-1} , as recommended in EPA guidance for tracking reasonable progress (EPA, 2003a).

Dr. Ivar Tombach, consultant to VISTAS, has provided a spreadsheet calculation system (see Appendix B) that incorporates the revised IMPROVE equation (also documented in Appendix B) for determining light extinction from particulate concentration estimates. We used this approach instead of the old/current IMPROVE equation in the presentation of the BART modeling. The Fish & Wildlife Service, who administer the Seney and Mingo Wilderness Areas, have previously communicated to ENSR (2006) that they approve of Dr. Tombach's procedure for implementing the new IMPROVE equation, and that this equation may be used for regional haze assessments with this approach. Notably, the Federal Land Managers associated with the US Fish and Wildlife Service recently approved the use of the new IMPROVE equation at Seney Wilderness (as implemented here using Dr. Tombach's procedures) for a PSD permit application in Michigan.

The new IMPROVE equation is fundamentally different in 3 major areas (taken from Ivar Tombach's "Instructions: A Postprocessor for Recalculating CALPOST Visibility Outputs with the New IMPROVE Algorithm"):

- (1) The extinction efficiencies of sulfates, nitrates, and organics have been changed and are now functions of their concentrations. The extinction efficiencies of sulfate and nitrate are no longer identical, although the new hygroscopic scattering enhancement factors applied to them are the same.
- (2) The contribution of fine sea salt to light extinction has been added, and is accompanied by its own hygroscopic scattering enhancement factor, $f_{ss}(RH)$.
- (3) The light scattering by air itself (Rayleigh scattering) now varies with site elevation and mean temperature. It is to be rounded off to the nearest one Mm^{-1} when used with the new algorithm.

States and other RPOs have allowed sources to use the new IMPROVE equation as opposed to the IMPROVE equation algorithms that are currently coded into CALPOST because these differences (noted above) represent a real improvement over how the old/current IMPROVE equation calculates light extinction. ENSR used the new IMPROVE equation for the light extinction calculations in this refined BART analysis using the guidance provided by Dr. Ivar Tombach. Table 4-3 lists sea salt concentrations and Rayleigh coefficients that were used as input to the new IMPROVE equation.

In addition to using the new IMPROVE equation, the assessment of visibility impacts at the Class I areas used CALPOST Method 6 (as standard with all BART applications). Each hour's source-caused extinction is calculated by first using the hygroscopic components of the source-caused concentrations, due to ammonium sulfate and nitrate, and monthly Class I area-specific $f(RH)$ values. The contribution to the total source-caused extinction from ammonium sulfate and nitrate is then added to the other, non-hygroscopic components of the particulate concentration (from coarse and fine soil, secondary organic aerosols, and from elemental carbon) to yield the total hourly source-caused extinction.

5.0 Modeling Results

The BART exemption modeling results at the four Class I areas using the maximum emissions by emission unit are provided in Table 5-1. Table 5-2 provides the results of the more realistic modeling using the maximum plant-wide emission days. Both tables indicate that the 8th highest day's impacts for each year are below the 0.5 delta-deciviews threshold. These results demonstrate that the ArcelorMittal Burns Harbor emissions do not cause or contribute to regional haze in any of these four Class I area. Therefore, Burns Harbor facility is not subject to BART and no further BART analysis is required.

Table 5-1 BART Exemption Modeling Results - Maximum by Emission Unit

Class I Area	2002				2003				2004			
	Days > than		MAX Δ dv	8 th Highest Δ dv _t	Days > than		MAX Δ dv	8 th Highest Δ dv	Days > than		MAX Δ dv	8 th Highest Δ dv _t
	0.5 Δ dv	1.0 Δ dv			0.5 D dv	1.0 D dv			0.5 D dv	1.0 D dv		
MVISBK=6, Annual Average Background, 6-km CALMET, New IMPROVE Equation												
Isle Royale National Park	0	0	0.220	0.083	2	0	0.601	0.117	2	0	0.615	0.163
Mammoth Cave National Park	2	0	0.898	0.351	3	0	0.674	0.333	1	0	0.658	0.218
Mingo Wilderness	3	0	0.705	0.199	1	0	0.559	0.224	0	0	0.414	0.181
Seney Wilderness	4	0	0.750	0.346	4	1	1.165	0.375	7	1	1.030	0.464

Table 5-2 BART Exemption Modeling Results - Plant-wide Maximum Emission Day

Class I Area	2002				2003				2004			
	Days > than		MAX Δ dv	8 th Highest Δ dv _t	Days > than		MAX Δ dv	8 th Highest Δ dv	Days > than		MAX Δ dv	8 th Highest Δ dv _t
	0.5 Δ dv	1.0 Δ dv			0.5 D dv	1.0 D dv			0.5 D dv	1.0 D dv		
MVISBK=6, Annual Average Background, 6-km CALMET, New IMPROVE Equation												
Isle Royale National Park	0	0	0.188	0.069	2	0	0.533	0.099	2	0	0.542	0.143
Mammoth Cave National Park	2	0	0.789	0.300	2	0	0.574	0.287	1	0	0.563	0.185
Mingo Wilderness	2	0	0.629	0.170	0	0	0.474	0.189	0	0	0.352	0.155
Seney Wilderness	2	0	0.675	0.297	2	0	1.027	0.332	6	0	0.914	0.405

6.0 References

ENSR, Personal communication to Mr. Robert Paine from Mr. Tim Allen of the U.S Fish and Wildlife Service

Environmental Protection Agency (EPA), AP 42, Fifth Edition, Compilation of Air Pollutant Emission Factors, Volume 1: Stationary Point and Area Sources, January, 1995

Environmental Protection Agency (EPA), Guidance for Tracking Progress Under the Regional Haze Rule, EPA-454/B-03-003, Appendix A, Table A-3, September, 2003a

Environmental Protection Agency (EPA), Guidance for Estimating Natural Visibility Conditions Under the Regional Haze Program, EPA 454/B-03-005, September 2003b

Environmental Protection Agency (EPA), Interagency Workgroup on Air Quality Modeling (IWAQM) Phase 2 Summary Report and Recommendations for Modeling Long Range Transport Impacts, EPA-454/R-98-019, December, 1998

Regional Haze Regulations and Guidelines for Best Available Retrofit Technology (BART) Determinations; Final Rule (FR Vol. 70, No. 128 published July 6, 2005)

Regional Haze Regulations; Revisions to Provisions Governing Alternative to Source-Specific Best Available Retrofit Technology (BART) Determinations; Final Rule (FR Vol. 71, NO. 198 published October 13, 2006)

Single Source Modeling to Support Regional Haze BART Modeling Protocol November 17, 2005, Lake Michigan Air Directors Consortium, Des Plaines, IL

Appendix A

Meteorological Stations used in CALMET Processing

Table A-1 Surface Stations used in CALMET Processing

Country/State	WBAN ID	Source ⁽¹⁾	Name	Latitude	Longitude	Elevation (m)	2002	2003	2004
Canada	712600	NNDC	SAULT STE MARIE	46.48	-84.51	192	x	x	x
Canada	712610	NNDC	GODERICH (AUTO8)	43.76	-81.71	214	x	x	x
Canada	712700	NNDC	COLLINGWOOD (AUT8)	44.50	-80.21	180	x	x	x
Canada	712730	NNDC	BELLE RIVER	42.30	-82.70	184	x	x	x
Canada	713680	NNDC	WATERLOO WELL	43.46	-80.38	317	x	x	x
Canada	714330	NCDC	CARIBOU ISL (MAPS)	47.33	-85.83	187	x	x	x
Canada	714350	NCDC	UPSALA (MARS)	49.03	-90.46	489	x	x	x
Canada	714390	NCDC	COVE ISLAND (MAPS)	45.33	-81.73	181	x	x	x
Canada	714600	NCDC	KILLARNEY (MAPS)	45.96	-81.48	196	x	x	x
Canada	714620	NCDC	GREAT DUCK ISLAND	45.63	-82.96	183	x	x	x
Canada	714650	NCDC	ERIEAU (MAPS)	42.25	-81.90	178	x	x	x
Canada	714660	NCDC	S.E. SHOAL (MAPS)	41.83	-82.46	195	x	x	x
Canada	715380	NCDC	WINDSOR AIRPORT	42.26	-82.96	190	x	x	x
Canada	715730	NCDC	DELHI CS	42.83	-80.55	232	x	x	x
Canada	716230	NCDC	LONDON AIRPORT	43.03	-81.15	278	x	x	x
Canada	716310	NCDC	MOUNT FOREST(MARS)	43.98	-80.75	415	x	x	x
Canada	716330	NCDC	WIARTON AIRPORT	44.75	-81.10	222	x	x	x
Canada	716340	NCDC	SARNIA AIRPORT	43.00	-82.31	181	x	x	x
Canada	716420	NCDC	CHAPLEAU A	47.81	-83.35	447	x	x	x
Canada	717300	NCDC	SUDBURY AIRPORT	46.61	-80.80	348	x	x	x
Canada	717320	NCDC	BRITT (MARS)	45.80	-80.53	192	x	x	x
Canada	717330	NCDC	GORE BAY AIRPORT	45.88	-82.56	193	x	x	x
Canada	717334	NCDC	ELLIOT LAKE (SAWR)	46.35	-82.56	329	x	x	x
Canada	717340	NCDC	ROUYN	48.25	-79.03	318	x	x	x
Canada	717350	NCDC	EARLTON AIRPORT	47.70	-79.85	243	x	x	x
Canada	717380	NCDC	WAWA AIRPORT	47.96	-84.78	287	x	x	x
Canada	717390	NCDC	TIMMINS AIRPORT	48.56	-81.36	295	x	x	x
Canada	717470	NCDC	ATIKOKAN	48.76	-91.63	389	x	x	x
Canada	717490	NCDC	THUNDER BAY AIRPORT	48.36	-89.31	199	x	x	x
Canada	717493	NCDC	TERRACE BAY (SAWR)	48.81	-87.10	287	x	x	x
Canada	717500	NCDC	PUKASKWA	48.60	-86.30	206	x	x	x
Canada	717510	NCDC	WELCOME ISLAND	48.36	-89.11	209	x	x	x
Canada	718200	NCDC	BARRAGE ANGLIERS	47.55	-79.23	266	x	x	x
AR	723406	NCDC	WALNUT RIDGE (AWOS)	36.13	-90.91	83	x	x	x
AR	723439	NCDC	BAXTER CO RGNL APT	36.36	-92.46	283	x	x	x
AR	723446	NCDC	HARRISON FAA AP	36.26	-93.15	418	x	x	x
AR	723447	NCDC	FLIPPIN (AWOS)	36.30	-92.46	350	x	x	x
IA	725349	NCDC	DAVENPORT NEXRAD	41.61	-90.58	259	x	x	x
IA	725450	NCDC	CEDAR RAPIDS MUNICI	41.88	-91.71	256	x	x	x
IA	725454	NCDC	WASHINGTON	41.28	-91.66	230	x	x	x
IA	725455	NCDC	BURLINGTON MUNICIPA	40.78	-91.11	210	x	x	x
IA	725456	NCDC	KEOKUK MUNI	40.46	-91.43	205	x	x	x
IA	725461	NCDC	MARSHALL TOWN MUNI	42.10	-92.91	296	x	x	x
IA	725462	NCDC	IOWA CITY MUNI	41.63	-91.55	198	x	x	x
IA	725463	NCDC	CHARLES CITY	43.06	-92.61	343	x	x	x
IA	725464	NCDC	NEWTON MUNI	41.68	-93.01	290	x	x	x
IA	725465	NCDC	OTTUMWA INDUSTRIAL	41.10	-92.45	256	x	x	x
IA	725469	NCDC	CHARITON	41.03	-93.36	320	x	x	x
IA	725470	NCDC	DUBUQUE REGIONAL AP	42.40	-90.70	321	x	x	x
IA	725473	NCDC	CLINTON MUNI (AWOS)	41.83	-90.33	216	x	x	x
IA	725475	NCDC	MONTICELLO MUNI	42.23	-91.16	259	x	x	x
IA	725476	NCDC	DECORAH	43.28	-91.73	353	x	x	x
IA	725480	NCDC	WATERLOO MUNICIPAL	42.55	-92.40	263	x	x	x
IA	725483	NCDC	FORT MADISON	40.66	-91.33	221	x	x	x
IA	725485	NCDC	MASON CITY MUNICIPA	43.15	-93.33	363	x	x	x
IA	725487	NCDC	MUSCATINE	41.36	-91.15	167	x	x	x
IA	725488	NCDC	OELWEN	42.68	-91.96	328	x	x	x
IA	725493	NCDC	KNOXVILLE	41.30	-93.11	283	x	x	x
IA	726498	NCDC	FAIR FIELD	41.05	-91.98	244	x	x	x
IL	724330	NCDC	SALEM-LECKRONE	38.65	-88.96	174	x	x	x
IL	724335	NCDC	MOUNT VERNON (AWOS)	38.31	-88.86	146	x	x	x
IL	724336	NCDC	CARBONDALE/MURPHYSB	37.78	-89.25	125	x	x	x
IL	724338	NCDC	BELLEVILLE SCOTT AF	38.55	-89.85	135	x	x	x
IL	724339	NCDC	MARION REGIONAL	37.75	-89.01	144	x	x	x
IL	724390	NCDC	SPRINGFIELD CAPITAL	39.85	-89.68	178	x	x	x
IL	724395	NCDC	ALTON/ST LOUIS RGNL	38.90	-90.05	166	x	x	x
IL	724396	NCDC	QUINCY MUNI BALDWIN	39.93	-91.20	232	x	x	x
IL	724397	NCDC	BLOOMINGTON/NORMAL	40.48	-88.91	267	x	x	x
IL	725300	NCDC	CHICAGO OHARE INTL	41.98	-87.91	200	x	x	x
IL	725305	NCDC	W. CHICAGO/DU PAGE	41.91	-88.25	231	x	x	x
IL	725314	NCDC	CAHOKIA/ST. LOUIS	38.56	-90.15	126	x	x	x
IL	725315	NCDC	CHAMPAIGN/URBANA	40.03	-88.28	230	x	x	x
IL	725316	NCDC	DECATUR AIRPORT	39.83	-88.86	208	x	x	x
IL	725317	NCDC	MATTOON/CHARLESTON	39.48	-88.28	220	x	x	x
IL	725320	NCDC	PEORIA GREATER PEOR	40.66	-89.68	198	x	x	x
IL	725326	NCDC	STERLING ROCKFALLS	41.75	-89.66	197	x	x	x

Table A-1 Surface Stations used in CALMET Processing

Country/State	WBAN ID	Source ⁽¹⁾	Name	Latitude	Longitude	Elevation (m)	2002	2003	2004
IL	724397	NCDC	BLOOMINGTON/NORMAL	40.48	-88.91	267	x	x	x
IL	725300	NCDC	CHICAGO OHARE INTL	41.98	-87.91	200	x	x	x
IL	725305	NCDC	W. CHICAGO/DU PAGE	41.91	-88.25	231	x	x	x
IL	725314	NCDC	CAHOKIA/ST. LOUIS	38.56	-90.15	126	x	x	x
IL	725315	NCDC	CHAMPAIGN/URBANA	40.03	-88.28	230	x	x	x
IL	725316	NCDC	DECATUR AIRPORT	39.83	-88.86	208	x	x	x
IL	725317	NCDC	MATTOON/CHARLESTON	39.48	-88.28	220	x	x	x
IL	725320	NCDC	PEORIA GREATER PEOR	40.66	-89.68	198	x	x	x
IL	725326	NCDC	STERLING ROCKFALLS	41.75	-89.66	197	x	x	x
IL	725340	NCDC	CHICAGO MIDWAY AP	41.78	-87.75	186	x	x	x
IL	725342	NCDC	LAWRENCEVILLE/IN.	38.76	-87.60	131	x	x	x
IL	725345	NCDC	JOLIET PARK DISTRIC	41.51	-88.18	177	x	x	x
IL	725346	NCDC	CHICAGO MEIGS FIELD	41.86	-87.61	180	x	x	x
IL	725347	NCDC	CHICAGO/WAUKEGAN	42.41	-87.86	222	x	x	x
IL	725348	NCDC	CHICAGO NEXRAD	41.60	-88.08	231	x	x	x
IL	725430	NCDC	ROCKFORD GREATER RO	42.20	-89.10	223	x	x	x
IL	725440	NCDC	MOLINE QUAD CITY IN	41.46	-90.51	180	x	x	x
IL	744655	NCDC	AURORA MUNICIPAL	41.76	-88.46	215	x	x	x
IL	744665	NCDC	CHICAGO/PALWAUKEE	42.11	-87.90	197		x	x
IL	ALH157	CASTNET	Alhambra	38.87	-89.62	164	x	x	x
IL	STK138	CASTNET	Stockton	42.29	-90.00	274	x	x	x
IN	724320	NCDC	EVANSVILLE REGIONAL	38.05	-87.53	116	x	x	x
IN	724356	NCDC	SHELBYVILLE MUNI	39.58	-85.80	245	x	x	x
IN	724363	NCDC	COLUMBUS BAKALAR	39.26	-85.90	199	x	x	x
IN	724365	NCDC	HUNTINGBURG	38.25	-86.95	161		x	x
IN	724373	NCDC	TERRE HAUTE HULMAN	39.45	-87.30	175	x	x	x
IN	724375	NCDC	BLOOMINGTON/MONROE	39.15	-86.61	258	x	x	x
IN	724380	NCDC	INDIANAPOLIS INTL A	39.71	-86.26	241	x	x	x
IN	724384	NCDC	EAGLE CREEK	39.83	-86.30	250	x	x	x
IN	724385	NCDC	ANDERSON MUNICIPAL	40.11	-85.61	280	x	x	x
IN	724386	NCDC	LAFAYETTE PURDUE UN	40.41	-86.93	182	x	x	x
IN	724387	NCDC	KOKOMO(AWOS)	40.53	-86.06	253		x	x
IN	724388	NCDC	GOSHEN	41.53	-85.78	252	x	x	x
IN	725327	NCDC	VALPARAISO	41.45	-87.00	234	x	x	x
IN	725330	NCDC	FORT WAYNE INTL AP	41.00	-85.20	241	x	x	x
IN	725335	NCDC	GRISSOM AFB/PERU	40.65	-86.15	247	x	x	x
IN	725336	NCDC	MUNCIE/JOHNSON FLD	40.25	-85.40	286	x	x	x
IN	725337	NCDC	GARY REGIONAL	41.61	-87.41	180	x	x	x
IN	725350	NCDC	SOUTH BEND MICHIANA	41.70	-86.33	235	x	x	x
IN	725354	NCDC	ELKHART MUNICIPAL	41.71	-86.00	237	x	x	x
IN	SAL133	CASTNET	Salamonie Reservoir	40.82	-85.66	250	x	x	x
KY	724210	NCDC	CINCINNATI NORTHERN	39.05	-84.66	264	x	x	x
KY	724220	NCDC	LEXINGTON BLUEGRASS	38.03	-84.60	294	x	x	x
KY	724230	NCDC	LOUISVILLE STANDIFO	38.18	-85.73	146	x	x	x
KY	724233	NCDC	CAPITAL CITY ARPT	38.18	-84.90	245	x	x	x
KY	724235	NCDC	LOUISVILLE BOWMAN F	38.23	-85.66	164	x	x	x
KY	724236	NCDC	JACKSON JULIAN CARR	37.58	-83.31	416	x	x	x
KY	724237	NCDC	OWENSBORO/DAVIESS	37.73	-87.16	124	x	x	x
KY	724238	NCDC	HENDERSON CITY	37.81	-87.68	117	x	x	x
KY	724240	NCDC	FORT KNOX GODMAN AA	37.90	-85.96	239	x	x	x
KY	724243	NCDC	LONDON-CORBIN AP	37.08	-84.08	362	x	x	x
KY	724360	NCDC	PADUCAH BARKLEY REG	37.05	-88.76	124	x	x	x
KY	724364	NCDC	SOMERSET(AWOS)	38.00	-84.60	283	x	x	x
KY	746710	NCDC	FORT CAMPBELL (AAF)	36.66	-87.50	173	x	x	x
KY	746716	NCDC	BOWLING GREEN WARRE	36.98	-86.43	160	x	x	x
KY	CDZ171	CASTNET	Cadiz	36.78	-87.85	189	x	x	x
KY	CKT136	CASTNET	Crockett	37.92	-83.07	455	x	x	x
KY	MCK131	CASTNET	Mackville	37.70	-85.05	353	x	x	x
KY	MAC426	CASTNET	Mammoth Cave	37.28	-86.26	236	x	x	x
MI	725370	NCDC	DETROIT METROPOLITA	42.21	-83.35	194	x	x	x
MI	725373	NCDC	GROSSE ISLE ARPT	42.10	-83.15	176	x	x	x
MI	725374	NCDC	ANN ARBOR MUNICIPAL	42.21	-83.75	256	x	x	x
MI	725375	NCDC	DETROIT CITY AIRPOR	42.40	-83.00	190	x	x	x
MI	725376	NCDC	DETROIT WILLOW RUN	42.23	-83.53	218	x	x	x
MI	725377	NCDC	MOUNT CLEMENS SELFR	42.61	-82.83	176	x	x	x
MI	725378	NCDC	HOWELL	42.63	-83.98	293	x	x	x
MI	725383	NCDC	STURGIS/KIRSH MUNI	41.81	-85.43	0	x	x	x
MI	725384	NCDC	ST. CLAIR COUNTY INT	42.91	-82.53	198	x	x	x
MI	725386	NCDC	HARBOR BEACH(RAMOS)	44.01	-82.80	183	x	x	x
MI	725387	NCDC	COPPER HARBOR RAMOS	47.45	-87.90	186	x	x	x
MI	725390	NCDC	LANSING CAPITAL CIT	42.78	-84.58	256	x	x	x
MI	725394	NCDC	HOLLAND/TULIP CITY	42.75	-86.10	210	x	x	x
MI	725395	NCDC	JACKSON REYNOLDS FI	42.26	-84.46	304	x	x	x

Table A-1 Surface Stations used in CALMET Processing

Country/State	WBAN ID	Source ⁽¹⁾	Name	Latitude	Longitude	Elevation (m)	2002	2003	2004
MI	725396	NCDC	BATTLE CREEK	42.30	-85.25	282	x	x	x
MI	725404	NCDC	ADRIAN	41.66	-84.08	244	x	x	x
MI	725405	NCDC	ALMA	43.31	-84.68	230	x	x	x
MI	725406	NCDC	BAD AXE	43.78	-82.98	234	x	x	x
MI	725407	NCDC	GAYLORD	45.01	-84.68	404	x	x	x
MI	725408	NCDC	MANISTIQUE	45.96	-86.18	209	x	x	x
MI	725409	NCDC	HILLSDALE	41.91	-84.58	360	x	x	x
MI	725414	NCDC	COLDWATER	41.93	-85.05	292	x	x	x
MI	725415	NCDC	MARSHALL BROOKS	42.25	-84.95	287	x	x	x
MI	725416	NCDC	BIG RAPIDS	43.71	-85.50	302	x	x	x
MI	725417	NCDC	MASON	42.56	-84.41	280	x	x	x
MI	725418	NCDC	MONROE	41.93	-83.43	188	x	x	x
MI	725424	NCDC	MT PLEASANT MUNI	43.61	-84.73	230	x	x	x
MI	726284	NCDC	GWINN SAWYER AIRPO	46.35	-87.38	372	x	x	x
MI	726350	NCDC	GRAND RAPIDS KENT C	42.88	-85.51	241	x	x	x
MI	726355	NCDC	BENTON HARBOR/ROSS	42.13	-86.43	196	x	x	x
MI	726357	NCDC	KALAMAZOO INTL ARPT	42.23	-85.55	266	x	x	x
MI	726360	NCDC	MUSKEGON COUNTY ARP	43.16	-86.23	190	x	x	x
MI	726364	NCDC	LUDINGTON/MASON	43.96	-86.40	197	x	x	x
MI	726370	NCDC	FLINT BISHOP INTL A	42.96	-83.75	233	x	x	x
MI	726375	NCDC	PONTIAC-OAKLAND	42.66	-83.41	299	x	x	x
MI	726379	NCDC	SAGINAW TRI CITY IN	43.53	-84.08	201	x	x	x
MI	726380	NCDC	HOUGHTON LAKE ROSCO	44.36	-84.68	350	x	x	x
MI	726384	NCDC	CADILLAC WEXFORD CO	44.28	-85.41	396	x	x	x
MI	726385	NCDC	MANISTEE (AWOS)	44.26	-86.25	189	x	x	x
MI	726387	NCDC	TRAVERSE CITY CHERR	44.73	-85.58	188	x	x	x
MI	726390	NCDC	ALPENA COUNTY REGIO	45.06	-83.58	210	x	x	x
MI	726394	NCDC	NEWBERRY LUCE CO.	46.31	-85.46	198	x	x	x
MI	726395	NCDC	OSCODA WURTSMITH AF	44.45	-83.40	188	x	x	x
MI	726399	NCDC	SEUL CHOIX PT(AMOS)	45.91	-85.91	180	x	x	x
MI	726480	NCDC	ESCANABA (AWOS)	45.75	-87.03	187	x	x	x
MI	726487	NCDC	MENOMINEE (AWOS)	45.13	-87.63	191	x	x	x
MI	727340	NCDC	SAULT STE MARIE SAN	46.46	-84.35	218	x	x	x
MI	727344	NCDC	CHIPPEWA INTL(AWOS)	46.25	-84.46	244	x	x	x
MI	727347	NCDC	PELLSTON EMMET COUN	45.56	-84.78	217	x	x	x
MI	727435	NCDC	MACKINACK ISLAND	46.35	-87.40	372	x	x	x
MI	727436	NCDC	ANTRIM CO ARPT	44.98	-85.20	190	x	x	x
MI	727437	NCDC	IRON MOUNTAIN/FORD	45.81	-88.11	360	x	x	x
MI	727440	NCDC	HANCOCK HOUGHTON CO	47.16	-88.50	327	x	x	x
MI	727445	NCDC	IRONWOOD (AWOS)	46.53	-90.13	375	x	x	x
MI	727449	NCDC	MOOSE LAKE CO ARPT	46.41	-92.80	184	x	x	x
MI	ANA115	CASTNET	Ann Arbor	42.42	-83.90	267	x	x	x
MI	H0X148	CASTNET	Hoxlyville	44.18	-85.74	305	x	x	x
MI	UVL124	CASTNET	Unionville	43.61	-83.36	201	x	x	x
MN	726440	NCDC	ROCHESTER INTERNATI	43.90	-92.50	397	x	x	x
MN	726544	NCDC	ORR	48.01	-92.86	397	x	x	x
MN	726549	NCDC	COOK MUNI ARPT	47.81	-92.70	402	x	x	x
MN	726558	NCDC	CLOQUET (AWOS)	46.70	-92.50	390	x	x	x
MN	726563	NCDC	FARIBAULT MUNI AWOS	44.33	-93.31	322	x	x	x
MN	726564	NCDC	RED WING	44.58	-92.48	239	x	x	x
MN	726568	NCDC	OWATONNA (AWOS)	44.11	-93.25	350	x	x	x
MN	726575	NCDC	MINNEAPOLIS/CRYSTAL	45.06	-93.35	265	x	x	x
MN	726577	NCDC	MINNEAPOLIS/BLAINE	45.15	-93.21	278	x	x	x
MN	726580	NCDC	MINNEAPOLIS-ST PAUL	44.88	-93.23	254	x	x	x
MN	726584	NCDC	SAINT PAUL DOWNTOWN	44.95	-93.06	219	x	x	x
MN	726588	NCDC	WINONA MUNI (AWOS)	44.08	-91.70	200	x	x	x
MN	726589	NCDC	ALBERT LEA (AWOS)	43.68	-93.36	383	x	x	x
MN	726596	NCDC	DODGE CENTER AIRPOR	44.01	-92.81	398	x	x	x
MN	726603	NCDC	SOUTH ST PAUL MUNI	44.85	-93.15	250	x	x	x
MN	726679	NCDC	RUSH CITY RGNL ARPT	45.68	-92.95	281	x	x	x
MN	727444	NCDC	TWO HARBORS	47.05	-91.75	328	x	x	x
MN	727450	NCDC	DULUTH INTERNATIONAL	46.83	-92.21	433	x	x	x
MN	727454	NCDC	GRAND MARAIS MUNI	47.83	-90.38	505	x	x	x
MN	727455	NCDC	HIBBING CHISHOLM-HI	47.38	-92.85	410	x	x	x
MN	727456	NCDC	DULUTH HARBOR (CGS)	46.76	-92.08	186	x	x	x
MN	727459	NCDC	ELY MUNI (AWOS)	47.81	-91.83	443	x	x	x
MN	727469	NCDC	GRAND MARIAS	47.83	-90.38	186	x	x	x
MN	727473	NCDC	CRANE LAKE (AWOS)	46.26	-92.56	350	x	x	x
MN	727474	NCDC	EVELETH MUNI (AWOS)	47.40	-92.50	421	x	x	x
MN	727475	NCDC	MORA MUNI (AWOS)	45.88	-93.26	309	x	x	x
MN	727503	NCDC	CAMBRIDGE MUNI	45.56	-93.26	287	x	x	x
MN	727556	NCDC	SILVER BAY	47.20	-91.40	331	x	x	x
MN	727566	NCDC	AUSTIN MUNI	43.66	-92.93	375	x	x	x

Table A-1 Surface Stations used in CALMET Processing

Country/State	WBAN ID	Source ⁽¹⁾	Name	Latitude	Longitude	Elevation (m)	2002	2003	2004
MO	723300	NCDC	POPLAR BLUFF(AMOS)	36.76	-90.46	146	x	x	x
MO	723484	NCDC	WEST PLAINS - ASOS	36.88	-91.90	374	x	x	x
MO	723489	NCDC	CAPE GIRARDEAU MUNI	37.23	-89.56	102	x	x	x
MO	724340	NCDC	ST LOUIS LAMBERT IN	38.75	-90.36	173	x	x	x
MO	724345	NCDC	ST LOUIS SPIRIT OF	38.65	-90.65	140	x	x	x
MO	724347	NCDC	ST CHARLES COUNTY A	38.91	-90.41	133	x	x	x
MO	724400	NCDC	SPRINGFIELD REGIONA	37.23	-93.38	383	x	x	x
MO	724450	NCDC	COLUMBIA REGIONAL A	38.81	-92.21	272	x	x	x
MO	724453	NCDC	SEDALIA MEMORIAL	38.70	-93.18	277	x	x	x
MO	724454	NCDC	FARMINGTON	37.76	-90.40	274	x	x	x
MO	724455	NCDC	KIRKSVILLE REGIONAL	40.10	-92.55	294	x	x	x
MO	724456	NCDC	VICHY ROLLA NATL AR	38.13	-91.76	335	x	x	x
MO	724457	NCDC	FORT LEONARD WOOD	37.73	-92.13	351	x	x	x
MO	724458	NCDC	JEFFERSON CITY MEM	38.58	-92.15	167	x	x	x
MO	724459	NCDC	KAISER MEM (AWOS)	38.10	-92.55	265	x	x	x
MO	724464	NCDC	CHILLICOTHE	39.81	-93.58	234	x	x	x
MO	724467	NCDC	WHITEMAN AFB	38.71	-93.55	255	x	x	x
NC	723150	NCDC	ASHEVILLE REGIONAL	35.43	-82.53	652	x	x	x
OH	724276	NCDC	DAYTON GENERL ARPT	39.60	-84.23	293	x	x	x
OH	724280	NCDC	COLUMBUS PORT COLUM	39.98	-82.88	246	x	x	x
OH	724284	NCDC	COLUMBUS/BOLTON FLD	39.90	-83.13	280	x	x	x
OH	724285	NCDC	COLUMBUS RICKENBACK	39.81	-82.93	230	x	x	x
OH	724286	NCDC	ZANESVILLE MUNICIPA	39.95	-81.90	268	x	x	x
OH	724287	NCDC	METCALF FIELD	41.55	-83.46	189	x	x	x
OH	724288	NCDC	OHIO ST U/COLUMBUS	40.08	-83.06	276	x	x	x
OH	724290	NCDC	DAYTON INTERNATIONAL	39.90	-84.21	304	x	x	x
OH	724294	NCDC	LANCASTER/FAIRFIEL	39.75	-82.65	264	x	x	x
OH	724296	NCDC	WILMINGTON AIRBORNE	39.41	-83.81	328	x	x	x
OH	724297	NCDC	CINCINNATI MUNICIPA	39.10	-84.41	149	x	x	x
OH	724298	NCDC	LIMA ALLEN CO ARPT	40.40	-84.01	296	x	x	x
OH	724303	NCDC	AKRON FULTON ASOS	41.03	-81.46	326	x	x	x
OH	725208	NCDC	MARION MUNI ARPT	40.61	-83.06	303	x	x	x
OH	725210	NCDC	AKRON AKRON-CANTON	40.91	-81.43	368	x	x	x
OH	725214	NCDC	ELYRIA/LORAIN CO.	41.35	-82.18	242	x	x	x
OH	725216	NCDC	WOOSTER	40.86	-81.88	346	x	x	x
OH	725217	NCDC	HAMILTON	39.36	-84.51	193	x	x	x
OH	725224	NCDC	NEW PHILADELPHIA	40.46	-81.41	272	x	x	x
OH	725229	NCDC	NEWARK/HEATH AIRPRT	40.01	-82.45	269	x	x	x
OH	725240	NCDC	CLEVELAND HOPKINS I	41.40	-81.85	234	x	x	x
OH	725245	NCDC	CLEVELAND/BURKELAKE	41.51	-81.68	178	x	x	x
OH	725246	NCDC	MANSFIELD LAHM MUNI	40.81	-82.51	394	x	x	x
OH	725247	NCDC	CLEVELAND/CUYAHOGA	41.56	-81.48	268	x	x	x
OH	725254	NCDC	DEFIANCE MEMORIAL	41.33	-84.41	219	x	x	x
OH	725360	NCDC	TOLEDO EXPRESS AIRP	41.58	-83.80	203	x	x	x
OH	725366	NCDC	FINDLAY AIRPORT	41.01	-83.66	243	x	x	x
OH	745700	NCDC	DAYTON WRIGHT PATTE	39.83	-84.05	249	x	x	x
OH	DCP114	CASTNET	Deer Creek	39.64	-83.26	267	x	x	x
OH	LYK123	CASTNET	Lykens	40.92	-83.00	303	x	x	x
OH	OXF122	CASTNET	Oxford	39.53	-84.73	284	x	x	x
SD	726626	NCDC	ANTIGO/LANG(AWOS)	45.15	-87.15	464	x	x	x

Table A-1 Surface Stations used in CALMET Processing

Country/State	WBAN ID	Source ⁽¹⁾	Name	Latitude	Longitude	Elevation (m)	2002	2003	2004
TN	723183	NCDC	BRISTOL TRI CITY AI	36.46	-82.40	457	x	x	x
TN	723246	NCDC	OAK RIDGE	36.01	-84.23	277	x	x	x
TN	723260	NCDC	KNOXVILLE MCGHEE TY	35.81	-83.98	293	x	x	x
TN	723265	NCDC	CROSSVILLE MEMORIAL	35.95	-85.08	569	x	x	x
TN	723270	NCDC	NASHVILLE INTERNATI	36.11	-86.68	176	x	x	x
TN	723347	NCDC	DYERSBURG MUNICIPAL	36.01	-89.40	102	x	x	x
TN	SPD111	CASTNET	Speedwell	36.47	-83.83	361	x	x	x
VA	724058	NCDC	ABINGTON	36.68	-82.03	631	x	x	x
VA	724117	NCDC	WISE/LONESOME PINE	36.98	-82.53	817	x	x	x
WI	726400	NCDC	MILWAUKEE MITCHELL	42.95	-87.90	204	x	x	x
WI	726404	NCDC	MINOCQUA/WOODRUFF	45.93	-89.73	496	x	x	x
WI	726405	NCDC	MILWAUKEE TIMMERMAN	43.11	-88.05	224	x	x	x
WI	726409	NCDC	WAUKESHA	43.03	-88.23	284	x	x	x
WI	726410	NCDC	MADISON DANE CO REG	43.13	-89.35	261	x	x	x
WI	726413	NCDC	WEST BEND MUNI	43.41	-88.11	270	x	x	x
WI	726414	NCDC	MONROE MUNICIPAL AI	42.60	-89.58	331	x	x	x
WI	726415	NCDC	JANESVILLE/ROCK CO.	42.61	-89.03	246	x	x	x
WI	726416	NCDC	LONE ROCK FAA AP	43.20	-90.18	219	x	x	x
WI	726417	NCDC	MEDFORD	45.10	-90.30	448	x	x	x
WI	726418	NCDC	OSCEOLA	45.31	-92.68	275	x	x	x
WI	726419	NCDC	ASHLAND KENNEDY ME	46.55	-90.91	251	x	x	x
WI	726424	NCDC	RACINE	42.76	-87.81	205	x	x	x
WI	726425	NCDC	SHEBOYGAN	43.78	-87.85	228	x	x	x
WI	726426	NCDC	STEVENS POINT	44.55	-89.53	338	x	x	x
WI	726427	NCDC	SUPERIOR	46.68	-92.10	206	x	x	x
WI	726430	NCDC	LA CROSSE MUNICIPAL	43.86	-91.25	198	x	x	x
WI	726435	NCDC	EAU CLAIRE COUNTY A	44.86	-91.48	271	x	x	x
WI	726436	NCDC	VOLK FIELD ANG	43.93	-90.26	280	x	x	x
WI	726437	NCDC	MCCOY (USA-AF)	43.96	-90.73	256	x	x	x
WI	726438	NCDC	BOSCOBEL AIRPORT	43.15	-90.42	205	x	x	x
WI	726444	NCDC	PRAIRIE DU CHIEN	43.01	-91.11	201	x	x	x
WI	726449	NCDC	MERRILL MUNI ARPT	45.18	-89.70	401	x	x	x
WI	726450	NCDC	GREEN BAY AUSTIN ST	44.48	-88.13	209	x	x	x
WI	726452	NCDC	WISCONSIN RAPIDS	44.35	-89.83	308	x	x	x
WI	726455	NCDC	MANITOWAC MUNI AWOS	44.13	-87.68	198	x	x	x
WI	726456	NCDC	OSHKOSH/WITTMAN FLD	43.96	-88.55	246	x	x	x
WI	726457	NCDC	APPLETON/OUTAGAMIE	44.25	-88.51	280	x	x	x
WI	726458	NCDC	STURGEON BAY	44.85	-87.41	221	x	x	x
WI	726463	NCDC	WAUSAU MUNICIPAL AR	44.91	-89.63	365	x	x	x
WI	726464	NCDC	WATERTOWN	43.16	-88.71	254	x	x	x
WI	726465	NCDC	MOSINEE/CENTRAL WI	44.78	-89.66	389	x	x	x
WI	726466	NCDC	APPLETON MUNI ARPT	44.55	-89.53	338	x	x	x
WI	726467	NCDC	RICE LAKE MUNICIPAL	45.48	-91.71	347	x	x	x
WI	726468	NCDC	PHILLIPS/PRICE CO.	45.70	-90.40	449	x	x	x
WI	726502	NCDC	CLINTONVILLE MUNI	44.61	-88.73	0	x	x	x
WI	726503	NCDC	WISCONSIN DELLS	43.51	-89.76	0	x	x	x
WI	726504	NCDC	EAGLE RIVER UNION	45.93	-89.26	500	x	x	x
WI	726505	NCDC	KENOSHA REGIONAL	42.60	-87.93	226	x	x	x
WI	726506	NCDC	FOND DU LAC CO.	43.76	-88.48	246		x	x
WI	726507	NCDC	MINERAL POINT	42.88	-90.23	0	x	x	x
WI	726508	NCDC	HAYWARD MUNI ARPT	46.03	-91.45	370	x	x	x
WI	726509	NCDC	JUNEAU/DODGE CO	43.43	-88.70	285	x	x	x
WI	726574	NCDC	MARSHFIELD MUNI	44.63	-90.18	389	x	x	x
WI	727415	NCDC	RHINELANDER/ONEIDA	45.63	-89.46	495	x	x	x
WI	PRK134	CASTNET	Perkinstown	45.21	-90.60	472	x	x	x
WV	724140	NCDC	CHARLESTON YEAGER A	38.38	-81.58	309	x	x	x
WV	724250	NCDC	HUNTINGTON TRI-STAT	38.38	-82.55	253	x	x	x
WV	724273	NCDC	PARKERSBURG WOOD CO	39.35	-81.43	253	x	x	x
x - Data is used in CALMET									
(1) The Clean Air Status and Trends Network (CASTNET): http://www.epa.gov/castnet/site.html									
National Climatic Data Center (NCDC): http://www.ncdc.noaa.gov/oa/ncdc.html									
NOAA National Data Centers (NNDC): http://ols.nndc.noaa.gov/plolstore/plsql/olstore.main?look=1									

Table A-2 Upper Air Stations used in CALMET Processing

State	Station Name	Station ID	Latitude	Longitude	Base Elevation (m)	2002	2003	2004
IA	DAVENPORT MUNICIPAL AP	94982	41.60	-90.57	229	x	x	x
IL	LINCOLN-LOGAN COUNTY AP	04833	40.15	-89.33	178	x	x	x
MI	GAYLORD / ALPENA	04837	44.55	-84.43	448	x	x	x
MI	DETROIT/PONTIAC	04830	42.70	-83.47	329	x	x	x
MN	INTERNATIONAL FALLS	14918	48.57	-93.38	359	x	x	x
MN	MINNEAPOLIS	94983	44.83	-93.55	287	x	x	x
MO	SPRINGFIELD REGIONAL AP	13995	37.23	-93.40	394	x	x	x
OH	WILMINGTON	13841	39.42	-83.82	317	x	x	x
PA	PITTSBURGH/MOON TOWNSHIP	94823	40.53	-80.23	360	x	x	x
TN	NASHVILLE	13897	36.25	-86.57	180	x	x	x
WI	GREEN BAY	14898	44.48	-88.13	210	x	x	x
x - Data is used in CALMET								

Table A-3 Buoy Stations used in CALMET Processing

Buoy Name	Station ID	Latitude	Longitude	Anemometer Height (m)	2002	2003	2004
N Michigan	45002	45.33	-86.42	5	x	x	x
N Huron	45003	45.35	-82.84	5	x	x	x
E Superior	45004	47.57	-86.55	5	x	x	x
S Huron	45008	44.29	-82.42	5	x	x	x
x - Data is used in CALMET							

Table A-4 Precipitation Stations used in CALMET Processing

State	ID	Station Name	Latitude	Longitude	Elevation (m)	2002	2003	2004
AR	030616	BERRYVILLE 5 NW	36.4294	-93.6256	1180	x	x	x
AR	031020	BULL SHOALS DAM	36.3647	-92.5781	480	x	x	x
AR	031632	CORNING	36.4197	-90.5858	300	x	x	x
AR	032356	EUREKA SPRINGS 3 WNW	36.4164	-93.7917	1420	x	x	x
AR	033132	HARDY	36.2747	-91.5056	400	x	x	x
AR	033165	HARRISON BOONE CNTY AP	36.2667	-93.1567	1374	x	x	x
IL	110082	ALEXIS 1 SW	41.0639	-90.5639	680	x	x	x
IL	110281	ASHLEY	38.3306	-89.1814	555	x	x	x
IL	110330	AUGUSTA	40.2378	-90.9456	680	x	x	x
IL	110510	BELLEVILLE SIU RESEARCH	38.5200	-89.8467	450	x	x	x
IL	110583	BELVIDERE	42.2550	-88.8644	738	x	x	x
IL	111166	CAIRO 3 N	37.0425	-89.1856	310	x	x	x
IL	111284	CARLINVILLE 2	39.2881	-89.8700	621	x	x	x
IL	111290	CARLYLE RESERVOIR	38.6308	-89.3658	501	x	x	x
IL	111302	CARMI 3	38.0781	-88.1831	335	x	x	x
IL	111549	CHICAGO OHARE AP	41.9950	-87.9336	658	x	x	x
IL	111577	CHICAGO MIDWAY AP 3SW	41.7372	-87.7775	620	x	x	x
IL	111664	CISNE 2 S	38.5047	-88.4094	454	x	x	x
IL	112011	CRETE	41.4492	-87.6222	664	x	x	x
IL	112140	DANVILLE	40.1389	-87.6483	558	x	x	x
IL	112193	DECATUR	39.8275	-88.9525	620	x	x	x
IL	112353	DIXON SPRINGS AGRIC CNT	37.4367	-88.6672	540	x	x	x
IL	112687	EFFINGHAM	39.1189	-88.6242	625	x	x	x
IL	112923	FAIRBURY WWTP	40.7511	-88.4983	690	x	x	x
IL	113262	FREEDPORT WASTE WTR PL	42.2972	-89.6039	750	x	x	x
IL	113666	GREENFIELD	39.3425	-90.2058	548	x	x	x
IL	113683	GREENUP 3SE	39.2283	-88.1261	545	x	x	x
IL	113879	HARRISBURG	37.7408	-88.5244	365	x	x	x
IL	114198	HOOPESTON 1 NE	40.4744	-87.6558	710	x	x	x
IL	114317	HUTSONVILLE POWER PLANT	39.1333	-87.6578	455	x	x	x
IL	114355	ILLINOIS CITY DAM 16	41.4253	-91.0094	550	x	x	x
IL	114442	JACKSONVILLE 2E	39.7353	-90.2153	610	x	x	x
IL	114603	KANKAKEE METRO WASTWTR	41.1381	-87.8856	640	x	x	x
IL	114629	KASKASKIA RIV NAV LOCK	37.9842	-89.9492	380	x	x	x
IL	114710	KEWANEE 1 E	41.2483	-89.8992	780	x	x	x
IL	114805	LACON 1 N	41.0414	-89.4061	460	x	x	x
IL	114879	LANARK	42.0925	-89.8422	830	x	x	x
IL	114957	LAWRENCEVILLE	38.7267	-87.6903	442	x	x	x
IL	115272	MACKINAW 1N	40.5525	-89.3336	710	x	x	x
IL	115334	MARIETTA	40.5019	-90.3892	640	x	x	x
IL	115413	MASON CITY 1 E	40.2003	-89.6775	575	x	x	x
IL	115493	MCHENRY WG STRATTON L&D	42.3103	-88.2525	742	x	x	x
IL	115751	MOBILE WSO AP	41.4653	-90.5233	592	x	x	x
IL	115768	MONMOUTH	40.9247	-90.6392	745	x	x	x
IL	115825	MORRIS 1 NW	41.3708	-88.4336	524	x	x	x
IL	115841	MORRISONVILLE	39.4158	-89.4614	630	x	x	x
IL	115888	MT CARMEL	38.4106	-87.7578	430	x	x	x
IL	115983	MURPHYSBORO 2 SW	37.7608	-89.3656	550	x	x	x
IL	116185	NOKOMIS	39.3053	-89.2828	680	x	x	x
IL	116610	PARIS WATERWORKS	39.6356	-87.6933	680	x	x	x
IL	116711	PEORIA GTR PEORIA RGNL	40.6675	-89.6839	650	x	x	x
IL	116819	PIPER CITY	40.7569	-88.1828	670	x	x	x
IL	116837	PITTSFIELD NO 2	39.6222	-90.8058	670	x	x	x
IL	117014	PROPHETSTOWN	41.6808	-89.9403	605	x	x	x
IL	117072	QUINCY REGIONAL AP	39.9369	-91.1919	769	x	x	x
IL	117077	QUINCY DAM 21	39.9058	-91.4281	483	x	x	x
IL	117150	RANTOUL	40.3131	-88.1594	740	x	x	x
IL	117187	REND LAKE DAM	38.0406	-88.9883	455	x	x	x
IL	117382	ROCKFORD AIRPORT	42.1928	-89.0931	730	x	x	x
IL	117391	ROCK ISLAND L&D 15	41.5194	-90.5644	568	x	x	x
IL	117833	SHABONA 3S	41.7322	-88.8653	850	x	x	x
IL	117876	SHELBYVILLE DAM	39.4106	-88.7800	655	x	x	x
IL	118020	SMITHLAND LOCK & DAM	37.1644	-88.4311	357	x	x	x
IL	118147	SPARTA 1 W	38.1167	-89.7167	535	x	x	x
IL	118179	SPRINGFIELD CAPITAL AP	39.8447	-89.6839	594	x	x	x
IL	118389	SULLIVAN 3 S	39.5608	-88.6067	659	x	x	x
IL	118740	URBANA	40.0842	-88.2406	721	x	x	x
IL	118781	VANDALIA	38.9703	-89.0922	540	x	x	x
IL	119193	WEST SALEM	38.5306	-88.0219	445	x	x	x
IL	119816	YATES CITY	40.7764	-90.0203	675	x	x	x

Table A-4 Precipitation Stations used in CALMET Processing

State	ID	Station Name	Latitude	Longitude	Elevation (m)	2002	2003	2004
IN	120132	ALPINE 2 NE	39.5736	-85.1583	850	x	x	x
IN	120177	ANDERSON SEWAGE PLANT	40.1122	-85.7175	845	x	x	x
IN	120200	ANGOLA	41.6397	-84.9900	1010	x	x	x
IN	120331	ATTICA 2E	40.2839	-87.1964	727	x	x	x
IN	120482	BATESVILLE WATERWORKS	39.2969	-85.2186	970	x	x	x
IN	120830	BLUFFTON 1 N	40.7478	-85.1733	825	x	x	x
IN	120922	BRAZIL	39.5108	-87.1242	680	x	x	x
IN	121147	BURLINGTON 1 NW	40.4875	-86.4089	724	x	x	x
IN	121256	CANNELTON	37.8994	-86.7072	402	x	x	x
IN	121415	CHALMERS	40.6628	-86.8814	700	x	x	x
IN	121628	CLINTON 2 W	39.6592	-87.4392	605	x	x	x
IN	121739	COLUMBIA CITY	41.1450	-85.4897	850	x	x	x
IN	121752	COLUMBUS UTILITIES	39.2106	-85.8883	632	x	x	x
IN	121814	CORYDON	38.2181	-86.1178	590	x	x	x
IN	121873	CRAWFORDSVILLE 6 SE	39.9664	-86.9289	840	x	x	x
IN	121929	CROTHERSVILLE	38.7908	-85.8483	560	x	x	x
IN	122309	DUBOIS SRN IN FORAGE FA	38.4558	-86.7000	690	x	x	x
IN	122738	EVANSVILLE REGIONAL AP	38.0431	-87.5203	400	x	x	x
IN	122825	FARMLAND 5 NNW	40.2539	-85.1483	965	x	x	x
IN	123037	FORT WAYNE WSO AP	41.0061	-85.2056	791	x	x	x
IN	123082	FRANKFORT DISPOSAL PLT	40.2986	-86.5067	824	x	x	x
IN	123091	FRANKLIN WWTP	39.4689	-86.0408	719	x	x	x
IN	123104	FREELANDVILLE	38.8672	-87.3083	550	x	x	x
IN	123206	GARRETT	41.3411	-85.1292	880	x	x	x
IN	123418	GOSHEN 3W	41.5575	-85.8825	875	x	x	x
IN	123714	HARRISON CRAWFORD S F	38.1975	-86.2686	850	x	x	x
IN	123777	HARTFORD CITY 4 ESE	40.4356	-85.2892	942	x	x	x
IN	124181	HUNTINGTON	40.8556	-85.4981	725	x	x	x
IN	124259	INDIANAPOLIS INTL AP	39.7317	-86.2789	790	x	x	x
IN	124286	INDIANAPOLIS ZOO	39.7681	-86.1806	710	x	x	x
IN	124372	JASPER	38.3861	-86.9408	460	x	x	x
IN	124527	KENTLAND	40.7592	-87.4353	695	x	x	x
IN	124730	LAGRANGE 1 N	41.6739	-85.4250	915	x	x	x
IN	124782	LAKEVILLE	41.5269	-86.2692	841	x	x	x
IN	124837	LA PORTE	41.6117	-86.7297	845	x	x	x
IN	124908	LEBANON WATER WORKS	40.0517	-86.4750	950	x	x	x
IN	124973	LEWISVILLE	39.8061	-85.3483	1065	x	x	x
IN	125337	MARION 2 N	40.5800	-85.6586	790	x	x	x
IN	125407	MARTINSVILLE 2 SW	39.4042	-86.4517	610	x	x	x
IN	125535	MEDARYVILLE 5 N	41.1589	-86.9014	695	x	x	x
IN	126151	NEWBURGH LOCK & DAM	37.9325	-87.3744	380	x	x	x
IN	126580	OOLITIC PURDUE EXP FRM	38.8894	-86.5519	650	x	x	x
IN	126697	PALMYRA	38.4075	-86.1106	770	x	x	x
IN	126864	PERU WASTE WATER PLANT	40.7453	-86.0717	645	x	x	x
IN	127069	PORTLAND 1 SW	40.4356	-85.2889	910	x	x	x
IN	127125	PRINCETON 1 W	38.3567	-87.5906	480	x	x	x
IN	127298	RENSSELAER	40.9356	-87.1564	650	x	x	x
IN	127370	RICHMOND WTR WKS	39.8833	-84.8833	1015	x	x	x
IN	127482	ROCHESTER	41.0658	-86.2094	770	x	x	x
IN	127930	SEYMOUR HIGHWAY GARAGE	38.9617	-85.8608	595	x	x	x
IN	127959	SHAKAMAK STATE PARK	39.1614	-87.2436	530	x	x	x
IN	127999	SHELBYVILLE SEWAGE PL	39.5283	-85.7917	750	x	x	x
IN	128036	SHOALS 8 S	38.5897	-86.7989	506	x	x	x
IN	128187	SOUTH BEND WSO AP	41.7072	-86.3331	773	x	x	x
IN	128442	STENDAL	38.2692	-87.1631	635	x	x	x
IN	128784	TIPTON 5 SW	40.2233	-86.1086	895	x	x	x
IN	128967	J T MYERS LOCKS & DAM	37.7953	-87.9931	340	x	x	x
IN	128999	VALPARAISO WATERWORKS	41.5114	-87.0378	800	x	x	x
IN	129069	VERSAILLES WATERWORKS	39.0717	-85.2453	939	x	x	x
IN	129174	WALDRON 2 W	39.4539	-85.6964	825	x	x	x
IN	129430	WEST LAFAYETTE 6 NW	40.4750	-86.9919	715	x	x	x
IA	130149	ALLERTON	40.7039	-93.3639	1090	x	x	x
IA	130608	BELLEVUE L AND D 12	42.2614	-90.4233	603	x	x	x
IA	131060	BURLINGTON RADIO KBUR	40.8167	-91.1667	703	x	x	x
IA	131257	CASCADE	42.2975	-91.0133	850	x	x	x
IA	131354	CENTERVILLE	40.7364	-92.8692	980	x	x	x
IA	131363	CENTRAL CITY	42.2011	-91.5286	870	x	x	x
IA	131724	COLUMBIA	41.1756	-93.1522	950	x	x	x
IA	132195	DERBY	40.9308	-93.4581	1190	x	x	x
IA	132203	DES MOINES AP	41.5339	-93.6531	957	x	x	x

Table A-4 Precipitation Stations used in CALMET Processing

State	ID	Station Name	Latitude	Longitude	Elevation (m)	2002	2003	2004
IA	132367	DUBUQUE WSO AP	42.3978	-90.7036	1056	x	x	x
IA	132977	FOREST CITY 2 NNE	43.2844	-93.6306	1300	x	x	x
IA	133473	GRINNELL 3 SW	41.7203	-92.7489	905	x	x	x
IA	134101	IOWA CITY	41.6092	-91.5050	640	x	x	x
IA	134142	IOWA FALLS	42.5189	-93.2536	1130	x	x	x
IA	134381	KEOKUK LOCK DAM 19	40.3969	-91.3767	527	x	x	x
IA	134502	KNOXVILLE	41.3336	-93.1117	920	x	x	x
IA	134963	LOWDEN	41.8564	-90.9300	715	x	x	x
IA	135198	MARSHALLTOWN	42.0647	-92.9244	870	x	x	x
IA	135235	MASON CITY MUNI AP	43.1544	-93.3269	1225	x	x	x
IA	135295	MAXWELL	41.8875	-93.3919	875	x	x	x
IA	135315	MCGREGOR	43.0239	-91.1747	627	x	x	x
IA	135796	MOUNT PLEASANT 1 SSW	40.9486	-91.5647	730	x	x	x
IA	136076	NORTH ENGLISH	41.5119	-92.0725	797	x	x	x
IA	136389	OTTUMWA INDUSTRIAL AP	41.1078	-92.4467	842	x	x	x
IA	137326	ST ANSGAR	43.3817	-92.9156	1170	x	x	x
IA	137572	SHEFFIELD 3 NW	42.9217	-93.2828	1045	x	x	x
IA	137602	SHELL ROCK 2W	42.7081	-92.6153	912	x	x	x
IA	137855	SPILLVILLE	43.2053	-91.9536	1080	x	x	x
IA	137985	STORY CITY	42.1792	-93.5817	975	x	x	x
IA	138009	STRAWBERRY POINT	42.6842	-91.5353	1200	x	x	x
IA	138315	TRAER	42.1869	-92.4728	950	x	x	x
IA	138688	WASHINGTON	41.2828	-91.7069	690	x	x	x
IA	138706	WATERLOO MUNICIPAL AP	42.5544	-92.4011	868	x	x	x
KY	150381	BARBOURVILLE	36.8825	-83.8819	990	x	x	x
KY	150450	BAXTER	36.8583	-83.3303	1164	x	x	x
KY	150611	BENTON	36.8581	-88.3364	365	x	x	x
KY	150619	BEREA COLLEGE	37.5733	-84.2908	1070	x	x	x
KY	151080	BUCKHORN LAKE	37.3500	-83.3833	936	x	x	x
KY	151227	CALHOUN LOCK 2	37.5317	-87.2667	402	x	x	x
KY	151631	CLINTON 4 S	36.6267	-88.9608	350	x	x	x
KY	151855	COVINGTON WSO	39.0431	-84.6717	869	x	x	x
KY	152358	DUNDEE 2NE	37.5806	-86.7769	450	x	x	x
KY	152979	FORDSVILLE	37.6372	-86.7206	480	x	x	x
KY	153741	HEIDELBERG	37.5500	-83.7667	665	x	x	x
KY	153798	HERNDON 5 S	36.6703	-87.5589	560	x	x	x
KY	153929	HODGENVILLE-LINCOLN NP	37.5317	-85.7350	788	x	x	x
KY	154202	JACKSON WSO	37.5914	-83.3144	1365	x	x	x
KY	154650	LEBANON 5 S	37.5050	-85.3086	660	x	x	x
KY	154746	LEXINGTON BLUEGRASS AP	38.0408	-84.6058	980	x	x	x
KY	154948	LOUISA 5 W	38.1250	-82.6947	753	x	x	x
KY	154954	LOUISVILLE INTL AP	38.1811	-85.7392	488	x	x	x
KY	154955	LOUISVILLE UPPER GAGE	38.2833	-85.8000	440	x	x	x
KY	155067	MADISONVILLE	37.3467	-87.5244	440	x	x	x
KY	155243	MAYSVILLE SEWAGE PLANT	38.6869	-83.7872	515	x	x	x
KY	155555	MOREHEAD 3 NW	38.2167	-83.4833	830	x	x	x
KY	155684	MUNFORDVILLE 5 NW	37.3347	-85.9503	680	x	x	x
KY	156012	OLIVE HILL 5 NE	38.3422	-83.1036	891	x	x	x
KY	156110	PADUCAH BARKLEY AP	37.0564	-88.7742	413	x	x	x
KY	156170	PARIS	38.2047	-84.2392	810	x	x	x
KY	156580	PRINCETON 1 SE	37.1244	-87.8672	497	x	x	x
KY	157074	SADIEVILLE	38.4078	-84.6836	945	x	x	x
KY	157473	SMITHFIELD 4 S	38.3333	-85.2861	850	x	x	x
KY	157508	SOMERSET 2 NE	37.1167	-84.6000	955	x	x	x
KY	157622	STAFFORDSVILLE 2 NW	37.8500	-82.8667	760	x	x	x
KY	157677	STEARNS 2 S	36.6667	-84.4833	1220	x	x	x
KY	158070	TOMPKINSVILLE 9 NW	36.8136	-85.7081	1060	x	x	x
KY	158719	WILLISBURG	37.8014	-85.1131	870	x	x	x
KY	158824	WOODBURY	37.1842	-86.6353	465	x	x	x
MI	200128	ALLEGAN 5 NE	42.5797	-85.7894	750	x	x	x
MI	200164	ALPENA COUNTY RGNL AP	45.0717	-83.5644	684	x	x	x
MI	200230	ANN ARBOR U OF MICH	42.2947	-83.7108	900	x	x	x
MI	200373	AVOCA 4 N	43.1256	-82.6886	770	x	x	x
MI	200662	BELLAIRE	44.9758	-85.1978	625	x	x	x
MI	200766	BIG BAY 8 NW	46.8867	-87.8642	612	x	x	x
MI	201088	BRUCE CROSSING	46.5333	-89.1833	1135	x	x	x
MI	201361	CASS CITY 1 SSW	43.5861	-83.1806	698	x	x	x
MI	201486	CHATHAM EXP FARM 2	46.3467	-86.9289	870	x	x	x
MI	201680	COLDWTR WASTEWTR PLT	41.9397	-85.0183	950	x	x	x
MI	201780	COPPER HARBOR FT WILKIN	47.4675	-87.8669	625	x	x	x

Table A-4 Precipitation Stations used in CALMET Processing

State	ID	Station Name	Latitude	Longitude	Elevation (m)	2002	2003	2004
MI	202094	DETOUR VILLAGE	45.9983	-83.9014	595	x	x	x
MI	202103	DETROIT METRO AP	42.2314	-83.3308	631	x	x	x
MI	202395	EAST LANSING 4 S	42.6742	-84.4850	880	x	x	x
MI	202626	ESCANABA	45.7500	-87.0333	591	x	x	x
MI	202788	FIFE LAKE 3WSW	44.5650	-85.4133	1112	x	x	x
MI	202846	FLINT BISHOP INTL AP	42.9667	-83.7494	770	x	x	x
MI	203170	GLADWIN	43.9758	-84.4908	775	x	x	x
MI	203199	GLENNIE ALCONA DAM	44.5617	-83.8031	805	x	x	x
MI	203295	GRAND HAVEN WASTEWTR PL	43.0608	-86.2047	605	x	x	x
MI	203333	GRAND RAPIDS INTL AP	42.8825	-85.5239	803	x	x	x
MI	203391	GRAYLING	44.6542	-84.6994	1136	x	x	x
MI	203516	GWINN 1 W	46.2864	-87.4511	1162	x	x	x
MI	203585	HARBOR BEACH 1 SSE	43.8322	-82.6428	595	x	x	x
MI	203936	HOUGHTON LAKE ROSCOMMON	44.3592	-84.6739	1151	x	x	x
MI	203947	HOWELL WWTP	42.5936	-83.9322	917	x	x	x
MI	204090	IRON MTN-KINGSFORD WWTP	45.7858	-88.0842	1071	x	x	x
MI	204155	JACKSON 3 N	42.2833	-84.4167	950	x	x	x
MI	204320	KENT CITY 2 SW	43.1994	-85.7717	840	x	x	x
MI	204641	LANSING CAPITAL CITY A	42.7803	-84.5789	841	x	x	x
MI	205073	MANISTIQUE WWTP	45.9511	-86.2511	620	x	x	x
MI	205567	MONTAGUE 4 NW	43.4614	-86.4175	650	x	x	x
MI	205712	MUSKEGON COUNTY AP	43.1711	-86.2367	625	x	x	x
MI	205816	NEWBERRY 3 S	46.3133	-85.5106	850	x	x	x
MI	206215	ONTONAGON	46.8561	-89.3119	673	x	x	x
MI	206300	OWOSSO WWTP	43.0161	-84.1800	730	x	x	x
MI	206438	PELLSTON REGIONAL AP	45.5644	-84.7928	705	x	x	x
MI	207366	SAULT STE MARIE SNDRSN	46.4794	-84.3572	722	x	x	x
MI	207812	STAMBAUGH 2 SSE	46.0556	-88.6278	1450	x	x	x
MI	207828	STANTON	43.2908	-85.0922	930	x	x	x
MI	208246	TRAVERSE CITY	44.7683	-85.5761	604	x	x	x
MI	208293	TROUT LAKE 2WNW	46.1989	-85.0728	871	x	x	x
MI	208417	VANDERBILT 11ENE	45.1703	-84.4397	905	x	x	x
MI	208443	VASSAR	43.3656	-83.5828	630	x	x	x
MI	208559	WAKEFIELD	46.4792	-89.9322	1600	x	x	x
MI	209218	YPSILANTI E MICH U	42.2475	-83.6253	780	x	x	x
MN	210075	ALBERT LEA 3 SE	43.6064	-93.3019	1230	x	x	x
MN	211227	CAMBRIDGE 5ESE	45.5506	-93.1264	960	x	x	x
MN	212166	DODGE CENTER	44.0419	-92.8814	1250	x	x	x
MN	212248	DULUTH INTL AP	46.8369	-92.1833	1433	x	x	x
MN	212543	ELY	47.9239	-91.8586	1382	x	x	x
MN	212645	EVELETH WASTE WATER PLA	47.4581	-92.5303	1445	x	x	x
MN	212842	FLOODWOOD 3 NE	46.9728	-92.8700	1260	x	x	x
MN	213202	GOLDEN VALLEY	44.9944	-93.4075	910	x	x	x
MN	213417	GUNFLINT LAKE 10 NW	48.1603	-90.8842	1455	x	x	x
MN	213793	HINCKLEY	45.9919	-92.9928	1035	x	x	x
MN	213863	HOLYOKE	46.4675	-92.3903	1034	x	x	x
MN	214418	LA CRESCENT DAM 7	43.8658	-91.3100	647	x	x	x
MN	215435	MINNEAPOLIS/ST PAUL AP	44.8831	-93.2289	872	x	x	x
MN	215987	NORTHFIELD 2 NNE	44.4761	-93.1486	890	x	x	x
MN	216213	ORR	48.0553	-92.8425	1390	x	x	x
MN	216822	RED WING DAM 3	44.6103	-92.6100	677	x	x	x
MN	217004	ROCHESTER INTERNATIONAL	43.9042	-92.4917	1304	x	x	x
MN	217184	RUSHFORD	43.8053	-91.7500	770	x	x	x
MN	217460	SANDY LAKE DAM LIBBY	46.7953	-93.3211	1234	x	x	x
MN	217941	SPRING VALLEY	43.6933	-92.3925	1280	x	x	x
MN	218280	TOFTE RANGER STATION	47.5681	-90.8500	680	x	x	x
MN	218613	WALES 2E	47.2561	-91.7017	1675	x	x	x
MO	230022	ADVANCE 1 S	37.0956	-89.9058	360	x	x	x
MO	230088	ALLEY SPRING RGR STA	37.1528	-91.4439	700	x	x	x
MO	230789	BOLIVAR 1 NE	37.6167	-93.3911	1034	x	x	x
MO	231283	CAP AU GRIS LOCK & DAM	39.0031	-90.6886	450	x	x	x
MO	231600	CLARENCE CANNON DAM	39.5253	-91.6450	702	x	x	x
MO	231640	CLARKSVILLE L&D 24	39.3731	-90.9053	460	x	x	x
MO	231674	CLEARWATER DAM	37.1319	-90.7756	660	x	x	x
MO	231711	CLINTON	38.3950	-93.7711	770	x	x	x
MO	231791	COLUMBIA REGIONAL AP	38.8169	-92.2183	893	x	x	x
MO	232302	DORA	36.7797	-92.2328	990	x	x	x
MO	232318	DOWNING	40.4822	-92.3636	870	x	x	x
MO	232809	FARMINGTON	37.7922	-90.4103	928	x	x	x
MO	233079	FULTON	38.8581	-91.9300	870	x	x	x

Table A-4 Precipitation Stations used in CALMET Processing

State	ID	Station Name	Latitude	Longitude	Elevation (m)	2002	2003	2004
MO	233601	HANNIBAL WATER WORKS	39.7233	-91.3719	712	x	x	x
MO	234271	JEFFERSON CITY WTR PL	38.5850	-92.1825	670	x	x	x
MO	234273	JEFFERSON BARRACKS	38.5039	-90.2800	490	x	x	x
MO	234544	KIRKSVILLE	40.2058	-92.5747	970	x	x	x
MO	234825	LEBANON 2W	37.6850	-92.6936	1279	x	x	x
MO	234919	LICKING 4N	37.5544	-91.8831	1180	x	x	x
MO	235050	LONG BRANCH RESERVOIR	39.7506	-92.5064	820	x	x	x
MO	235130	LURAY 2 N	40.4892	-91.8781	740	x	x	x
MO	235207	MALDEN MUNICIPAL AP	36.5994	-89.9894	290	x	x	x
MO	235298	MARSHALL	39.1342	-93.2225	790	x	x	x
MO	235307	MARSHFIELD	37.3381	-92.9097	1490	x	x	x
MO	235415	MC CREDIE EXPERIMENT ST	38.9500	-91.9000	850	x	x	x
MO	235562	MIDDLETOWN	39.1244	-91.4142	680	x	x	x
MO	235594	MILLER 1 E	37.2147	-93.8228	1296	x	x	x
MO	235671	MOBERLY	39.4194	-92.4369	860	x	x	x
MO	235834	MOUNTAIN GROVE 2 N	37.1528	-92.2636	1450	x	x	x
MO	236012	NEW FRANKLIN 1 W	39.0172	-92.7558	641	x	x	x
MO	236460	OZARK BEACH	36.6597	-93.1261	700	x	x	x
MO	236777	POMME DE TERRE DAM	37.9050	-93.3169	900	x	x	x
MO	236826	POTOSI 5 SW	37.8908	-90.8600	1030	x	x	x
MO	237263	ROLLA UNI OF MISSOURI	37.9572	-91.7758	1167	x	x	x
MO	237300	ROSEBUD	38.4506	-91.3756	960	x	x	x
MO	237452	ST LOUIS SCIENCE CENTER	38.6292	-90.2706	545	x	x	x
MO	237455	ST LOUIS LAMBERT INTL	38.7525	-90.3736	531	x	x	x
MO	237506	SALEM	37.6331	-91.5364	1200	x	x	x
MO	237976	SPRINGFIELD REG AP	37.2397	-93.3897	1259	x	x	x
MO	238043	STEELVILLE 2 N	38.0053	-91.3706	700	x	x	x
MO	238051	STEFFENVILLE	39.9714	-91.8872	690	x	x	x
MO	238082	STOCKTON DAM	37.6967	-93.7722	873	x	x	x
MO	238223	SWEET SPRINGS	38.9631	-93.4000	670	x	x	x
MO	238252	TABLE ROCK DAM	36.5972	-93.3075	820	x	x	x
MO	238466	TRUMAN DAM & RESERVOIR	38.2581	-93.3989	632	x	x	x
MO	238609	VIBURNUM	37.7119	-91.1328	1276	x	x	x
MO	238620	VIENNA 2 WNW	38.2017	-91.9811	770	x	x	x
MO	238700	WAPPAPELLO DAM	36.9231	-90.2836	410	x	x	x
MO	238712	WARRENSBURG 4 NW	38.7842	-93.8008	796	x	x	x
MO	238746	WASHINGTON	38.5425	-90.9719	490	x	x	x
MO	238827	WENTZVILLE	38.8128	-90.8561	580	x	x	x
MO	238880	WEST PLAINS	36.7425	-91.8347	1010	x	x	x
OH	330058	AKRON CANTON WSO AP	40.9167	-81.4333	1208	x	x	x
OH	330059	AKRON WPCS	41.1500	-81.5667	750	x	x	x
OH	330107	ALLIANCE 3 NNW	40.9550	-81.1169	1055	x	x	x
OH	330256	ASHLAND 2 SW	40.8333	-82.3500	1265	x	x	x
OH	330493	BEACH CITY LAKE	40.6333	-81.5667	985	x	x	x
OH	330639	BERLIN LAKE	41.0333	-81.0167	1040	x	x	x
OH	330862	BOWLING GREEN WWTP	41.3831	-83.6111	675	x	x	x
OH	331042	BRYAN 2 SE	41.4619	-84.5272	730	x	x	x
OH	331197	CAMBRIDGE	40.0167	-81.5833	800	x	x	x
OH	331404	CENTERBURG 2 SE	40.3000	-82.6500	1205	x	x	x
OH	331466	CHARLES MILL LAKE	40.7400	-82.3569	1025	x	x	x
OH	331528	CHILICOTHE MOUND CITY	39.3744	-83.0036	650	x	x	x
OH	331536	CHILLO MELDAHL L&D	38.7983	-84.1731	500	x	x	x
OH	331541	CHIPPEWA LAKE	41.0517	-81.9361	1180	x	x	x
OH	331592	CIRCLEVILLE	39.6106	-82.9547	673	x	x	x
OH	331651	CLEVELAND EASTERLY	41.5667	-81.5833	550	x	x	x
OH	331657	CLEVELAND WSFO AP	41.4050	-81.8528	770	x	x	x
OH	331786	COLUMBUS WSO AIRPORT	39.9914	-82.8808	810	x	x	x
OH	331905	COSHOCOTON AGRI RS STA	40.3708	-81.7908	1140	x	x	x
OH	332075	DAYTON WSO AIRPORT	39.9061	-84.2186	1000	x	x	x
OH	332090	DEER CREEK LAKE	39.6253	-83.2128	860	x	x	x
OH	332098	DEFIANCE	41.2778	-84.3853	700	x	x	x
OH	332124	DELAWARE LAKE	40.3667	-83.0667	930	x	x	x
OH	332272	DOVER DAM	40.5667	-81.4167	930	x	x	x
OH	332485	EATON	39.7347	-84.6336	1002	x	x	x
OH	332651	FAIRFIELD	39.3500	-84.5833	575	x	x	x
OH	332791	FINDLAY WPCC	41.0461	-83.6622	768	x	x	x
OH	332956	FREDERICKTOWN 4 S	40.4167	-82.5333	1050	x	x	x
OH	332974	FREMONT	41.3333	-83.1167	600	x	x	x
OH	333021	GALION WATER WORKS	40.7167	-82.8000	1170	x	x	x

Table A-4 Precipitation Stations used in CALMET Processing

State	ID	Station Name	Latitude	Longitude	Elevation (m)	2002	2003	2004
OH	333120	GERMANTOWN DAM	39.6358	-84.4003	740	x	x	x
OH	333356	GREENFIELD 1 WNW	39.3542	-83.4056	970	x	x	x
OH	333375	GREENVILLE WATER PLANT	40.1000	-84.6500	1024	x	x	x
OH	333758	HILLSBORO	39.2000	-83.6167	1100	x	x	x
OH	334004	JACKSON 3 NW	39.0775	-82.7053	800	x	x	x
OH	334189	KENTON	40.6489	-83.6061	995	x	x	x
OH	334403	LANCASTER	39.7156	-82.6072	840	x	x	x
OH	334459	LEBANON 4 SE	39.3689	-84.2394	680	x	x	x
OH	334473	LEESVILLE LAKE	40.4667	-81.2000	980	x	x	x
OH	334551	LIMA WWTP	40.7247	-84.1294	850	x	x	x
OH	334672	LOGAN	39.5292	-82.3850	722	x	x	x
OH	334681	LONDON	39.8833	-83.4500	1020	x	x	x
OH	334865	MANSFIELD WSO AP	40.8203	-82.5178	1295	x	x	x
OH	334942	MARION 2 N	40.6167	-83.1333	965	x	x	x
OH	334979	MARYSVILLE	40.2411	-83.3669	1000	x	x	x
OH	334992	MASSILLON	40.7667	-81.5333	930	x	x	x
OH	335029	MC ARTHUR	39.2503	-82.4822	785	x	x	x
OH	335041	MC CONNELSVILLE LOCK 7	39.6539	-81.8569	760	x	x	x
OH	335297	MILLERSBURG	40.5500	-81.9167	819	x	x	x
OH	335398	MOHAWK DAM	40.3486	-82.0908	865	x	x	x
OH	335585	MOUNT VERNON	40.3833	-82.4667	980	x	x	x
OH	335747	NEWARK WATER WORKS	40.0875	-82.4131	835	x	x	x
OH	336123	NORWALK 5 SE	41.1833	-82.5667	925	x	x	x
OH	336196	OBERLIN	41.2667	-82.2167	816	x	x	x
OH	336375	OXFORD	39.5167	-84.7333	860	x	x	x
OH	336616	PIEDMONT LAKE	40.1833	-81.2167	940	x	x	x
OH	336650	PIQUA WWTP	40.1311	-84.2342	800	x	x	x
OH	336702	PLEASANT HILL LAKE	40.6167	-82.3333	1125	x	x	x
OH	336781	PORTSMOUTH SCIOTOVILLE	38.7569	-82.8872	540	x	x	x
OH	336949	RAVENNA 2 S	41.1333	-81.2833	1107	x	x	x
OH	337383	ST MARYS 3 W	40.5447	-84.4375	875	x	x	x
OH	337559	SENECAVILLE LAKE	39.9222	-81.4347	875	x	x	x
OH	337698	SIDNEY HIGHWAY DEPT	40.2983	-84.1633	1030	x	x	x
OH	337935	SPRINGFIELD NEW WTR WKS	39.9667	-83.8167	930	x	x	x
OH	338240	TAPPAN DAM	40.3561	-81.2281	950	x	x	x
OH	338313	TIFFIN	41.1167	-83.1667	740	x	x	x
OH	338357	TOLEDO EXPRESS WSO AP	41.5886	-83.8014	669	x	x	x
OH	338378	TOM JENKINS DAM-BURR OA	39.5444	-82.0589	760	x	x	x
OH	338539	UPPER SANDUSKY WATER WK	40.8167	-83.2833	820	x	x	x
OH	338552	URBANA WWTP	40.1000	-83.7833	1000	x	x	x
OH	338810	WATERLOO	38.7003	-82.4736	625	x	x	x
OH	339211	WILLS CREEK LAKE	40.1500	-81.8500	780	x	x	x
OH	339224	WILMINGTON	39.4333	-83.8500	975	x	x	x
OH	339312	WOOSTER EXP STN	40.7833	-81.9167	1020	x	x	x
OH	339357	XENIA TREATMENT PLANT	39.7167	-83.9667	820	x	x	x
OH	339422	ZANESVILLE WWTP	39.9125	-82.0042	700	x	x	x
TN	401094	BRISTOL AP	36.4731	-82.4044	1500	x	x	x
TN	401561	CELINA	36.5408	-85.4594	540	x	x	x
TN	401663	CHEATHAM LOCK & DAM	36.3244	-87.2244	392	x	x	x
TN	405332	LIVINGSTON RADIO WLIV	36.3772	-85.3394	975	x	x	x
TN	407359	PORTLAND SEWAGE PLANT	36.5875	-86.5258	794	x	x	x
TN	407884	ROGERSVILLE 1 NE	36.4161	-82.9839	1355	x	x	x
TN	408065	SAMBURG W. L. REFUGE	36.4528	-89.3028	310	x	x	x
TN	408562	SPRINGFIELD EXPERIMENT	36.4739	-86.8472	745	x	x	x
TN	409219	UNION CITY	36.3925	-89.0317	350	x	x	x
VA	444180	HURLEY 4 S	37.3653	-82.0561	1088	x	x	x
VA	449215	WISE 3E	36.9986	-82.5389	2549	x	x	x
WV	461570	CHARLESTON YEAGER AP	38.3794	-81.5914	910	x	x	x
WV	461579	CHARLESTON WSFO	38.3139	-81.7186	918	x	x	x
WV	463749	GRIFFITHSVILLE	38.2381	-81.9853	780	x	x	x
WV	464393	HUNTINGTON TRI/STATE	38.3650	-82.5550	824	x	x	x
WV	465323	LIVERPOOL	38.8956	-81.5311	665	x	x	x
WV	465353	LOGAN	37.8611	-81.9961	640	x	x	x
WV	468351	SOUTHSIDE 3 NNW	38.7506	-81.9808	576	x	x	x
WI	470045	AFTON	42.6475	-89.0644	742	x	x	x
WI	470124	ALMA DAM 4	44.3272	-91.9194	670	x	x	x

Table A-4 Precipitation Stations used in CALMET Processing

State	ID	Station Name	Latitude	Longitude	Elevation (m)	2002	2003	2004
WI	470308	ARLINGTON UNIV FARM	43.3008	-89.3269	1080	x	x	x
WI	470349	ASHLAND EXP FARM	46.5728	-90.9714	650	x	x	x
WI	470456	BABCOCK 1 WNW	44.2994	-90.1306	980	x	x	x
WI	470855	BLACK RVR FALLS SWG	44.2903	-90.8536	810	x	x	x
WI	470890	BLANCHARDVILLE	42.8169	-89.8628	830	x	x	x
WI	471416	CHARMANY FARM	43.0603	-89.4781	910	x	x	x
WI	471568	CHILTON	44.0328	-88.1469	840	x	x	x
WI	471578	CHIPPEWA FALLS	44.9278	-91.4081	850	x	x	x
WI	471667	CLINTON	42.5492	-88.8753	960	x	x	x
WI	471676	CLINTONVILLE	44.6225	-88.7483	800	x	x	x
WI	471897	CRIVITZ HIGH FALLS	45.3581	-88.1925	1050	x	x	x
WI	471913	CUBA CITY 2NW	42.6253	-90.4592	900	x	x	x
WI	472447	EAU PLEINE RESERVOIR	44.7247	-89.7567	1138	x	x	x
WI	472973	FRIENDSHIP	43.9750	-89.8308	945	x	x	x
WI	473038	GENOA DAM 8	43.5706	-91.2294	639	x	x	x
WI	473269	GREEN BAY A S INTL AP	44.4794	-88.1378	687	x	x	x
WI	473453	HARTFORD 2 W	43.3311	-88.4114	980	x	x	x
WI	473511	HAYWARD RANGER STA	46.0003	-91.5075	1200	x	x	x
WI	473636	HILES	45.6811	-88.9603	1633	x	x	x
WI	473756	HORICON	43.4406	-88.6325	880	x	x	x
WI	474370	LA CROSSE MUNICIPAL AIR	43.8789	-91.2528	652	x	x	x
WI	474396	LADYSMITH WTP	45.4431	-91.0894	1160	x	x	x
WI	474404	LA FARGE	43.5753	-90.6417	810	x	x	x
WI	474546	LANCASTER 4 WSW	42.8278	-90.7889	1040	x	x	x
WI	474894	LUCK	45.5733	-92.4850	1220	x	x	x
WI	474937	LYNXVILLE DAM 9	43.2117	-91.0986	633	x	x	x
WI	474961	MADISON DANE COUNTY AP	43.1406	-89.3453	866	x	x	x
WI	475120	MARSHFIELD EXP FARM	44.6322	-90.1314	1250	x	x	x
WI	475255	MEDFORD	45.1308	-90.3439	1470	x	x	x
WI	475335	MENOMONIE	44.8742	-91.9364	780	x	x	x
WI	475352	MERCER RANGER STN	46.1683	-90.0722	1600	x	x	x
WI	475364	MERRILL	45.1706	-89.6614	1253	x	x	x
WI	475479	MILWAUKEE MITCHELL AP	42.9550	-87.9044	670	x	x	x
WI	475524	MINONG RANGER STN	46.1006	-91.8178	1080	x	x	x
WI	475948	NEW RICHMOND	45.1167	-92.5639	1000	x	x	x
WI	476398	PARK FALLS DNR HQ	45.9336	-90.4506	1525	x	x	x
WI	476510	PESHTIGO	45.0203	-87.7342	600	x	x	x
WI	476518	HELPS	46.0658	-89.0756	1776	x	x	x
WI	476718	PORTAGE	43.5278	-89.4342	775	x	x	x
WI	476854	PRENTICE	45.5478	-90.2883	1540	x	x	x
WI	476939	RAINBOW RSVR-LK TOMAHAWK	45.8342	-89.5494	1600	x	x	x
WI	477132	RICE LAKE	45.4164	-91.7719	1103	x	x	x
WI	477140	RICE RESERVOIR TOMAHAWK	45.5406	-89.7481	1465	x	x	x
WI	478027	SPOONER EXPERMNT FARM	45.8236	-91.8761	1100	x	x	x
WI	478259	STRUM 4 S	44.4964	-91.3964	976	x	x	x
WI	478267	STURGEON BAY EXP FARM	44.8722	-87.3353	656	x	x	x
WI	478316	SULLIVAN 3SE	42.9675	-88.5497	933	x	x	x
WI	478515	TOMAH RANGER STATION	43.9908	-90.5053	960	x	x	x
WI	478589	TREMPEALEAU DAM 6	43.9994	-91.4378	660	x	x	x
WI	479176	WHITE LAKE 3 NE	45.1817	-88.7344	1285	x	x	x
WI	479218	WILLARD	44.7314	-90.7217	1490	x	x	x
WI	479304	WINTER	45.8231	-91.0139	1397	x	x	x
x - Data is used in CALMET								