

IBCD CUSTOMER TANK PUMPING LIST

HOLDING TANK PROPERTY ASSIGNMENTS AND CLEANOUT SCHEDULE

11/2/2025

LEGENDS

1/11/2010

Other Up dates/corrections to information

Note: Tanks are pumped and inspected every five years.

Date 2021 Fall Clean Out Schedule Completed By D&M

Date 2022 Fall Clean Out Schedule Completed By D&M

Date 2023 Fall Clean Out Schedule Completed By D&M

Date 2024 Fall Clean Out Schedule Completed By D&M

Date 2025 Fall Clean Out Schedule Completed 7/10/25By D&M

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results
246	Arbor	07/06/22	D	248		Baffles intact; Clean cast. & Lid needs new gasket
247	Arbor	07/06/22	S			Baffles intact; Clean cast. & Lid
248	Arbor	07/06/22	D	246		Baffles intact; Clean cast. & Lid needs new gasket
249	Arbor	07/06/22	S			Baffles intact; Clean cast. & Lid needs new gasket
251	Arbor	07/06/22	D	253		Baffles intact; Clean cast. & Lid needs new gasket
252	Arbor	07/13/22	S			Baffles intact; Clean cast. & Lid
253	Arbor	07/06/22	D	251	On Brummitt Park	Baffles intact; Clean cast. & Lid needs new gasket
254	Arbor	07/13/22	S			Baffles intact; Clean cast. & Lid
255	Arbor	08/23/23	D	257		Baffles intact; Clean cast. & Lid
256	Arbor	10/12/22	D>		W/ 750 Br Pk On Br Pk	Baffles intact; Clean cast & Lid
257	Arbor	08/23/23	D	255		Baffles intact; Clean cast. & Lid
258	Arbor	07/13/22	D	260		Baffles intact; Clean cast. & Lid
259	Arbor	07/13/22	D	261		Baffles intact; Clean cast. & Lid
260	Arbor	07/13/22	D	258		Baffles intact; Clean cast. & Lid
261	Arbor	07/13/22	D	259		Baffles intact; Clean cast. & Lid
262	Arbor	07/13/22	S			Baffles intact; Clean cast. & Lid
263	Arbor	08/23/23	D	265		Baffles intact; Clean cast. & Lid, replace seal
264	Arbor	08/29/23	D	266		Baffles intact; Clean cast. & Lid, replace seal
265	Arbor	08/23/23	D	263		Baffles intact; Clean cast. & Lid, replace seal
266	Arbor	08/29/23	D	264		Baffles intact; Clean cast. & Lid, replace seal
267	Arbor	10/4/23	S			Baffles intact; Clean cast. & Lid
268	Arbor	09/15/25	S			Baffles intact. Concrete Lid.
269	Arbor	07/13/22	S			Baffles intact; Clean cast. & Lid
270	Arbor	09/15/25	S			Baffles intact; Clean cast. & Lid
271	Arbor	07/13/22	D	273		Baffles intact; Clean cast. & Lid
272	Arbor	10/12/22	S			New Tank
273	Arbor	07/13/22	D	271		Baffles intact; Clean cast. & Lid
274	Arbor	10/12/22	S			Baffles intact; Clean cast. & Lid
276	Arbor	08/29/23	D>		W/ 1302 Brummitt Rd	Baffles intact; Clean cast. & Lid
1262	Arbutus	09/09/21	D	1266		Baffles intact; Clean cast. & Lid
1263	Arbutus	09/09/21	D	1267		Baffles intact; Clean cast. & Lid
1266	Arbutus	09/09/21	D	1262		Baffles intact; Clean cast. & Lid
1267	Arbutus	09/09/21	D	1263		Baffles intact; Clean cast. & Lid
1270	Arbutus	10/12/22	D>		W/ Vac Lot Ind Bndry	Baffles intact; Clean cast. & Lid
1271	Arbutus	09/15/25	S		Was 216 Ind Bndry	Baffles intact; Clean cast. & Lid

IBCD CUSTOMER TANK PUMPING LIST

HOLDING TANK PROPERTY ASSIGNMENTS AND CLEANOUT SCHEDULE

11/2/2025

LEGENDS

1/11/2010

Other Up dates/corrections to information

Note: Tanks are pumped and inspected every five years.

Date 2021 Fall Clean Out Schedule Completed By D&M

Date 2022 Fall Clean Out Schedule Completed By D&M

Date 2023 Fall Clean Out Schedule Completed By D&M

Date 2024 Fall Clean Out Schedule Completed By D&M

Date 2025 Fall Clean Out Schedule Completed 7/10/25By D&M

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results
2335	Architect	10/11/23	S		On Park Rd	Baffles intact; Clean cast. & Lid
2350	Architect	10/04/23	S			Baffles intact; Clean cast. & Lid
2390	Architect	08/17/22	D	2402		Baffles intact; Clean cast. & Lid
2402	Architect	08/17/22	D	2390		Baffles intact; Clean cast. & Lid
2501	Architect	10/07/21	S			Baffles intact; Clean cast. & Lid
2502	Architect	10/07/21	D	2602		Baffles intact; Clean cast. & Lid
2602	Architect	10/07/21	D	2502		Baffles intact; Clean cast. & Lid
510	Brummitt Pk Dr	09/27/23	D	530		Baffles intact; clean cast. & lid, replace seal
530	Brummitt Pk Dr	09/27/23	D	510		Baffles intact; clean cast. & lid, replace seal
531	Brummitt Pk Dr	09/27/23	D	551		Baffles intact; Clean cast. & Lid
550	Brummitt Pk Dr	09/27/23	D	570	Set Back	Baffles intact; Clean cast. & Lid
551	Brummitt Pk Dr	09/27/23	D	531		Baffles intact; Clean cast. & Lid
561	Brummitt Pk	10/12/22	D>		W/ 2502 Riverview	Baffles intact; Clean cast. & Lid
570	Brummitt Pk Dr	09/27/23	D	550		Baffles intact; Clean cast. & Lid
595	Brummitt Pk	09/20/21	S		On Riverview	Baffles intact; Clean cast. & Lid
750	Brummitt Pk	10/12/22	D>		W/ 256 Arbor	Baffles intact; Clean cast. & Lid
1268	Brummitt Rd	09/15/25	S			Baffles intact; cast. Lid & seal good shape
1276	N. Brummitt Rd	08/19/21	S			Baffles intact; Clean cast. & Lid
1277	Brummitt Rd	08/29/23	S			Baffles intact; Clean cast. & Lid
1278	N. Brummitt Rd	08/19/21	S			Baffles intact; Clean cast. & Lid
1282	N. Brummitt Rd	09/02/21	S			Baffles intact; Clean cast. & Lid
1284	Brummitt Rd	08/29/23	S		STEP (Lift Sta - Special Tk w/ effluent pump)	Baffles intact; Clean cast. & Lid
1285	N. Brummitt Rd	08/26/21	S			Baffles intact; Clean cast. & Lid
1286	N. Brummitt Rd	10/07/21	S		On Mar Mar Loop	Baffles intact; Clean cast. & Lid
1288	N. Brummitt Rd	08/26/21	D	1292		Baffles intact; Clean cast. & Lid
1292	N. Brummitt Rd	08/26/21	D	1288		Baffles intact; Clean cast. & Lid
1294	N. Brummitt Rd	08/07/24	S			Baffles intact; Clean cast. & Lid
1298	N. Brummitt Rd	08/07/24	S			Baffles intact; Clean cast. & Lid
1302	N. Brummitt Rd	08/29/23	D>		W/ 276 Arbor	Baffles intact; Clean cast. & Lid
1303	N. Brummitt Rd	07/31/24	D	1305		Baffles intact; Clean cast. & Lid
1305	N. Brummitt Rd	07/31/24	D	1303		Baffles intact; Clean cast. & Lid

IBCD CUSTOMER TANK PUMPING LIST

HOLDING TANK PROPERTY ASSIGNMENTS AND CLEANOUT SCHEDULE

11/2/2025

LEGENDS

1/11/2010

Other Up dates/corrections to information

Note: Tanks are pumped and inspected every five years.

Date 2021 Fall Clean Out Schedule Completed By D&M

Date 2022 Fall Clean Out Schedule Completed By D&M

Date 2023 Fall Clean Out Schedule Completed By D&M

Date 2024 Fall Clean Out Schedule Completed By D&M

Date 2025 Fall Clean Out Schedule Completed 7/10/25By D&M

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results
1306	N. Brummitt Rd	08/29/23	S		New 4/96	Baffles intact; Plastic riser and cap
205	Dogwood	08/12/21	D>		W/ 392 Wake Robin	Baffles intact; Clean cast. & Lid
209	Dogwood	09/15/25	S			Baffles intact; Clean cast. & Lid
211	Dogwood	09/15/25	S			Baffles intact; cast. Lid & seal good shape
215	Dogwood	09/15/25	S		On Arbutus	Baffles intact; Clean cast. & Lid
217	Dogwood	09/15/25	S			Baffles intact; Clean cast. & Lid
218	Dogwood	09/15/25	D	1690	On Arbutus	Baffles intact; Clean cast. & Lid Needs new seal
219	Dogwood	09/15/25	D	221		Baffles intact; Clean cast. & Lid Needs new seal
221	Dogwood	09/15/25	D	219	On Violet	Baffles intact; Clean cast. & Lid Needs new seal
222	Dogwood	09/17/25	S			Baffles intact; cast. Lid & seal OK
223	Dogwood	09/17/25	S			Baffles intact; Clean cast. & Lid
224	Dogwood	09/15/25	D	226		Baffles intact; Clean cast. & Lid
225	Dogwood	09/15/25	D>		W/ 1264 Redbud	Baffles intact; Clean cast. & Lid
226	Dogwood	09/15/25	D	224		Baffles intact; Clean cast. & Lid
1217	Dogwood	09/15/25	D	1219		Baffles intact; Clean cast. & Lid
1218	Dogwood	09/17/25	S			Baffles intact; Clean cast. & Lid
1219	Dogwood	09/15/25	D	1217		Baffles intact; Clean cast. & Lid
1220	Dogwood	09/17/25	S			Baffles intact; Clean cast. & Lid
1221	Dogwood	09/20/21	D	1223		Baffles intact; Clean cast. & Lid
1222	Dogwood	08/18/21	D	1224		Baffles intact; Clean cast. & Lid
1223	Dogwood	09/20/21	D	1221		Baffles intact; Clean cast. & Lid
1224	Dogwood	08/18/21	D	1222		Baffles intact; Clean cast. & Lid
1225	Dogwood	09/14/21	D	1227		Baffles intact; Clean cast. & Lid
1226	Dogwood	09/02/21	D	1228		Baffles intact; Clean cast. & Lid
1227	Dogwood	09/14/21	D	1225		Baffles intact; Clean cast. & Lid
1228	Dogwood	09/02/21	D	1226		Baffles intact; Clean cast. & Lid
1229	Dogwood	09/17/25	S			Baffles intact; Clean cast. & Lid
1230	Dogwood	10/07/21	D	1232		Baffles intact; Clean cast. & Lid
1231	Dogwood	09/17/25	S			Baffles intact; Clean cast. & Lid
1232	Dogwood	10/07/21	D	1230		Baffles intact; Clean cast. & Lid
1233	Dogwood	07/31/24	S			Baffles intact; Clean cast. & Lid
1234	Dogwood	09/14/21	D	1236		Baffles intact; Clean cast. & Lid
1235	Dogwood	10/07/21	D	1237	Disconnected	Baffles intact; Clean cast. & Lid
1236	Dogwood	09/14/21	D	1234		Baffles intact; Clean cast. & Lid
1237	Dogwood	10/07/21	D	1235		Baffles intact; Clean cast. & Lid

IBCD CUSTOMER TANK PUMPING LIST

HOLDING TANK PROPERTY ASSIGNMENTS AND CLEANOUT SCHEDULE

11/2/2025

LEGENDS

1/11/2010

Other Up dates/corrections to information

Note: Tanks are pumped and inspected every five years.

Date 2021 Fall Clean Out Schedule Completed By D&M

Date 2022 Fall Clean Out Schedule Completed By D&M

Date 2023 Fall Clean Out Schedule Completed By D&M

Date 2024 Fall Clean Out Schedule Completed By D&M

Date 2025 Fall Clean Out Schedule Completed 7/10/25By D&M

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results
1238	Dogwood	08/19/21	D	1242		Baffles intact; Clean cast. & Lid
1239	Dogwood	09/17/25	D	1241		Baffles intact; Clean cast. & Lid
1241	Dogwood	09/17/25	D	1239		Baffles intact; Clean cast. & Lid
1242	Dogwood	08/19/21	D	1238		Baffles intact; Clean cast. & Lid
1243	Dogwood	09/17/25	S			Baffles intact; Clean cast. & Lid
1245	Dogwood	09/17/25	D	1247		Baffles intact; Clean cast. & Lid
1246	Dogwood	09/17/25	D	1248		Baffles intact; Clean cast. & Lid
1247	Dogwood	09/17/25	D	1245		Baffles intact; Clean cast. & Lid
1248	Dogwood	09/17/25	D	1246		Baffles intact; Clean cast. & Lid
1249	Dogwood	09/17/25	D	1251		Baffles intact; Clean cast. & Lid
1250	Dogwood	09/17/25	D	1252		Baffles intact; Clean cast. & Lid
1251	Dogwood	09/17/25	D	1249		Baffles intact; Clean cast. & Lid
1252	Dogwood	09/17/25	D	1250		Baffles intact; Clean cast. & Lid
1253	Dogwood	09/17/25	D	1255	w/ 1255 Dogwood	Baffles intact; Clean cast. & Lid
1254	Dogwood	08/05/21	D>		W/ 1255 Redbud	Baffles intact; Clean cast. & Lid
1255	Dogwood	09/17/25	D	1253	New 1/96 Miller	Baffles intact; Clean cast. & Lid
1257	Dogwood	09/17/25	S			Baffles intact; Clean cast. & Lid
1660	Dogwood	08/05/21	S			Baffles intact; Clean cast. & Lid
1690	Dogwood	09/17/25	D	218		Baffles intact; Clean cast. & Lid Needs new seal
501	Graham				No Tank	
502	Graham				No Tank	
530	Graham	07/10/24	D	560		Baffles intact; Clean cast & Lid
531	Graham	08/07/24	S			Baffles intact; Clean cast & Lid
551	Graham	07/10/24	D	561		Baffles intact; Clean cast & Lid
560	Graham	07/10/24	D	530		Baffles intact; Clean cast & Lid
561	Graham	07/10/24	D	551		Baffles intact; Clean cast & Lid
590	Graham	07/10/24	D	598		Baffles intact; Clean cast & Lid
591	Graham	08/26/20	D	601		Baffles intact; Clean cast & Lid
598	Graham	07/10/24	D	590		Baffles intact; Clean cast & Lid
601	Graham	08/26/20	D	591		Baffles intact; Clean cast & Lid
611	Graham	07/10/24	D	617		Baffles intact; Clean cast & Lid
617	Graham	07/10/24	D	611		Baffles intact; Clean cast & Lid
621	Graham	07/31/24	S			Baffles intact; Clean cast & Lid
631	Graham	07/10/24	D	661		Baffles intact; Clean cast & Lid
650	Graham	07/31/24	S			Baffles intact; clean cast. & Lid

IBCD CUSTOMER TANK PUMPING LIST

HOLDING TANK PROPERTY ASSIGNMENTS AND CLEANOUT SCHEDULE

11/2/2025

LEGENDS

1/11/2010

Other Up dates/corrections to information

Note: Tanks are pumped and inspected every five years.

Date 2021 Fall Clean Out Schedule Completed By D&M

Date 2022 Fall Clean Out Schedule Completed By D&M

Date 2023 Fall Clean Out Schedule Completed By D&M

Date 2024 Fall Clean Out Schedule Completed By D&M

Date 2025 Fall Clean Out Schedule Completed 7/10/25By D&M

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results
661	Graham	07/10/24	D	631		Baffles intact; Clean cast & Lid
691	Graham	07/10/24	D	701		Baffles intact; Clean cast & Lid
700	Graham	07/10/24	D	750		Baffles intact; Clean cast & Lid
701	Graham	07/10/24	D	691		Baffles intact; Clean cast & Lid
731	Graham	09/09/21	S			Baffles intact; Clean cast. & Lid
750	Graham	07/10/24	D	700		Baffles intact; Clean cast & Lid
761	Graham	08/07/24	S			Baffles intact; clean cast. & Lid
790	Graham	08/07/24	S		On Park Dr	Baffles intact; clean cast. & Lid
791	Graham	04/12/13	Dual Pump Well		Gr Dr Lift Station	Pumped and Powerwashed
795	Graham	09/10/25	D	1820		Baffles intact; Casting cleaned, Seal OK
1605	Graham	09/09/21	S			Baffles intact; Clean cast & Lid
1624	Graham	08/07/24	S		W/ Vacant Lot	Baffles intact; Clean cast & Lid
1625	Graham	07/10/24	D	1635		Baffles intact; Clean cast & Lid
1635	Graham	07/10/24	D	1625		Baffles intact; Clean cast & Lid
1660	Graham	08/07/24	S			Baffles intact; Clean cast & Lid
1665	Graham	08/07/24	S			Baffles intact; Clean cast & Lid
1690	Graham	09/10/25	D	1730		Baffles intact; Casting cleaned, Seal OK
1695	Graham	08/07/24	S			Baffles intact; Clean cast & Lid
1725	Graham	07/10/24	D	1765		Baffles intact; Clean cast & Lid
1730	Graham	09/10/25	D	1690		Baffles intact; Casting cleaned, Seal OK
1760	Graham	08/07/24	S			Baffles intact; Clean cast & Lid
1765	Graham	07/10/24	D	1725		Baffles intact; Clean cast & Lid
1790	Graham	07/10/24	D	1810		Baffles intact; Clean cast & Lid
1795	Graham	08/10/22	D	1805		Baffles intact; Clean cast & Lid
1805	Graham	08/10/22	D	1795		Baffles intact; Clean cast & Lid
1810	Graham	07/10/24	D	1790		Baffles intact; Clean cast & Lid
1820	Graham	09/10/25	D	795		Baffles intact; Casting cleaned, Seal OK
1825	Graham	08/07/24	S		On Lake Drive	Baffles intact; clean cast. & Lid
1835	Graham	08/07/24	S		On Lake Drive	Baffles intact; clean cast. & Lid
501	Honeyshade	09/27/23	D>		W/1875 InBdry on InBdry	Baffles intact; Clean cast & Lid
502	Honeyshade	08/07/24	S		On In Bdry	Baffles intact; clean cast. & Lid
520	Honeyshade	07/31/24	D	540		Baffles intact; Clean cast & Lid

IBCD CUSTOMER TANK PUMPING LIST

HOLDING TANK PROPERTY ASSIGNMENTS AND CLEANOUT SCHEDULE

11/2/2025

LEGENDS

1/11/2010

Other Up dates/corrections to information

Note: Tanks are pumped and inspected every five years.

Date 2021 Fall Clean Out Schedule Completed By D&M

Date 2022 Fall Clean Out Schedule Completed By D&M

Date 2023 Fall Clean Out Schedule Completed By D&M

Date 2024 Fall Clean Out Schedule Completed By D&M

Date 2025 Fall Clean Out Schedule Completed 7/10/25By D&M

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results
521	Honeyshade	07/31/24	D	541		Baffles intact; Clean cast & Lid
540	Honeyshade	07/31/24	D	520		Baffles intact; Clean cast & Lid
541	Honeyshade	07/31/24	D	521		Baffles intact; Clean cast & Lid
561	Honeyshade	08/07/24	S			Baffles intact; clean cast. & Lid
1475	In Bdry	10/04/23	S			Pump station
1498	In Bdry	10/04/23	S			Baffles intact; clean cast. & lid
1501	In Bdry	10/04/23	S		STEP (Lift Sta - Special Tk w/ effluent pump)	Pump Station
1505	In Bdry	10/04/23	S		STEP (Lift Sta - Special Tk w/ effluent pump)	Pump Station
1530	In Bdry	08/07/24	S			Baffles intact; clean cast. & lid
1550	In Bdry	08/07/24	S			Baffles intact; clean cast. & lid
1551	In Bdry	10/04/23	S			Baffles intact; clean cast. & lid
1569	In Bdry	09/27/23	D>		W/ 501 Honeyshade	Baffles intact; Clean cast & Lid
1570	In Bdry	08/12/21	D>		W/ 1270 Wake Robin	Baffles intact; Casting cleaned, Seal OK
1650	In Bdry	10/12/22	D>		W/ 1271 Wake Robin	Baffles intact; Clean cast & Lid
1660	In Bdry	07/31/24	D	1680		Baffles intact; Clean cast & Lid
1665	In Bdry	07/31/24	D	1695		Baffles intact; Clean cast & Lid
1680	In Bdry	07/31/24	D	1660		Baffles intact; Clean cast & Lid
1695	In Bdry	07/31/24	D	1665		Baffles intact; Clean cast & Lid
1735	In Bdry	10/11/23	S			Baffles intact; clean cast. & lid
1765	In Bdry	08/17/22	D>		W/ 501 Starwood	Baffles intact; Clean cast & Lid
1776	In Bdry	10/11/23	S			Baffles intact; clean cast. & lid
1780	In Bdry	08/07/24	S		STEP (Lift Sta - Special Tk w/ effluent pump)	STEP Pump Replaced 3/05/12 Sta Inspected- Replaced Bad Alarm Float 08/08/12 Added Viper Cellular Monitoring Unit to Controls- 10/10/12 Replaced Holding Tank 07/10/13

IBCD CUSTOMER TANK PUMPING LIST

HOLDING TANK PROPERTY ASSIGNMENTS AND CLEANOUT SCHEDULE

11/2/2025

LEGENDS

1/11/2010

Other Up dates/corrections to information

Note: Tanks are pumped and inspected every five years.

Date 2021 Fall Clean Out Schedule Completed By D&M

Date 2022 Fall Clean Out Schedule Completed By D&M

Date 2023 Fall Clean Out Schedule Completed By D&M

Date 2024 Fall Clean Out Schedule Completed By D&M

Date 2025 Fall Clean Out Schedule Completed 7/10/25By D&M

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results
1800	In Bdry	10/11/23	S		STEP (Lift Sta - Special Tk w/ effluent pump)	Pump Station
1835	In Bdry	10/11/23	S			Baffles intact; clean cast. & lid
1845	In Bdry	2009	Dual Pump Well		IBR Main Lift Station	Pumped when well rails and pump bases repaired.
1960	In Bdry	08/12/11	S		No Tank	
2355	In Bdry				No Tank	
2375	In Bdry				No Tank	
2500	In Bdry		None		Brummitt Elem School	NO Tank Found-Local Manhole w/ direct feed to Main Sewer System on Ind Bndry Rd
2601	In Bdry	09/17/25	S		Plan Incomplete	Baffles intact; Casting OK, needs new Lid/Seal
1202	Lake	09/17/25	S			Baffles intact; Casting cleaned, Seal OK
1206	Lake	09/17/25	S			Baffles intact; Casting cleaned, Seal OK
1301	Lake	07/31/24	D	1305		Baffles intact; Clean cast & Lid
1305	Lake	07/31/24	D	1301		Baffles intact; Clean cast & Lid
730	Mar Mar	09/14/21	S			Baffles intact; Clean cast & Lid
751	Mar Mar	09/17/25	D	801		Baffles intact; Casting cleaned, Seal OK
780	Mar Mar	09/14/21	S			Baffles intact; Clean cast & Lid
801	Mar Mar	09/11/25	D	751		
802	Mar Mar	08/31/22	D	822		Baffles intact; clean cast & lid
822	Mar Mar	08/31/22	D	802		Baffles intact; clean cast & lid
852	Mar Mar	08/31/22	D	904		Baffles intact; clean cast & lid
901	Mar Mar	09/17/25	S		New Mullin 1/98	
904	Mar Mar	08/31/22	D	852		Baffles intact; clean cast & lid
950	Mar Mar	08/07/24	S		New 4/91	Baffles intact; clean cast & lid
951	Mar Mar	10/04/23	S			Baffles intact; clean cast & lid
226	Michael	08/28/25	D	228		Baffles intact; Casting cleaned, Seal OK
228	Michael	08/28/25	D	226		Baffles intact; Casting cleaned, Seal OK
229	Michael	08/12/21	D>		W/ 1219 Redbud	Baffles intact; Cast. & Seal Good shape
230	Michael	09/11/25	S			Baffles intact; Cast. & Seal Good shape
232	Michael	09/11/25	D	234		Baffles intact; Casting cleaned, Seal OK

IBCD CUSTOMER TANK PUMPING LIST

HOLDING TANK PROPERTY ASSIGNMENTS AND CLEANOUT SCHEDULE

11/2/2025

LEGENDS

1/11/2010

Other Up dates/corrections to information

Note: Tanks are pumped and inspected every five years.

Date 2021 Fall Clean Out Schedule Completed By D&M

Date 2022 Fall Clean Out Schedule Completed By D&M

Date 2023 Fall Clean Out Schedule Completed By D&M

Date 2024 Fall Clean Out Schedule Completed By D&M

Date 2025 Fall Clean Out Schedule Completed 7/10/25By D&M

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results
234	Michael	09/11/25	D	232		Baffles intact; Casting cleaned, Seal OK
1520	Orchard Lane	10/12/22	D	1560		Baffles intact; Clean cast & Lid
1525	Orchard Lane	08/17/22	D	1555		Baffles intact; Clean cast & Lid
1555	Orchard Lane	08/17/22	D	1525	New 12/97	Baffles intact; Clean cast & Lid
1560	Orchard Lane	10/12/22	D	1520		Baffles intact; Clean cast & Lid
1590	Orchard Lane	08/26/21	S			Baffles intact; Clean cast & Lid
1201	Park Drive	08/16/23	S			Baffles intact; clean cast. & lid
1301	Park Drive	08/16/23	S			Baffles intact; clean cast. & lid
1218	Redbud	08/05/21	S			
1219	Redbud	08/12/21	D>		W/ 229 Michael	
1220	Redbud	08/24/22	D	1222		Baffles intact; Clean cast & Lid
1221	Redbud	08/24/22	D	1223		Baffles intact; Clean cast & Lid
1222	Redbud	08/24/22	D	1220		Baffles intact; Clean cast & Lid
1223	Redbud	08/24/22	D	1221		Baffles intact; Clean cast & Lid
1224	Redbud	07/26/23	D	1226		Baffles intact; Clean cast & Lid
1225	Redbud	07/26/23	D	1227		Baffles intact; Clean cast & Lid
1226	Redbud	07/26/23	D	1224		Baffles intact; Clean cast & Lid
1227	Redbud	07/26/23	D	1225		Baffles intact; Clean cast & Lid
1228	Redbud	07/26/23	D	1230		Baffles intact; Clean cast & Lid
1229	Redbud	07/31/24	D	1231		Baffles intact; Clean cast & Lid
1230	Redbud	07/26/23	D	1228		Baffles intact; Clean cast & Lid
1231	Redbud	07/31/24	D	1229		Baffles intact; Clean cast & Lid
1232	Redbud	07/26/23	D	1234		Baffles intact; Clean cast & Lid
1233	Redbud	07/26/23	D	1235		Baffles intact; Clean cast & Lid
1234	Redbud	07/26/23	D	1232		Baffles intact; Clean cast & Lid
1235	Redbud	07/26/23	D	1233		Baffles intact; Clean cast & Lid
1236	Redbud	08/01/23	D	1238		Baffles intact; Clean cast & Lid
1237	Redbud	08/01/23	D	1239		Baffles intact; Clean cast & Lid
1238	Redbud	08/01/23	D	1236		Baffles intact; Clean cast & Lid
1239	Redbud	08/01/23	D	1237		Baffles intact; Clean cast & Lid
1241	Redbud	08/18/16	S		House Removed	Baffles intact; Clean cast & Lid
1242	Redbud	08/12/21	S			Baffles intact; Clean cast & Lid
1245	Redbud	08/01/23	D	1247		Baffles intact; Clean cast & Lid

IBCD CUSTOMER TANK PUMPING LIST

HOLDING TANK PROPERTY ASSIGNMENTS AND CLEANOUT SCHEDULE

11/2/2025

LEGENDS

1/11/2010

Other Up dates/corrections to information

Note: Tanks are pumped and inspected every five years.

Date 2021 Fall Clean Out Schedule Completed By D&M

Date 2022 Fall Clean Out Schedule Completed By D&M

Date 2023 Fall Clean Out Schedule Completed By D&M

Date 2024 Fall Clean Out Schedule Completed By D&M

Date 2025 Fall Clean Out Schedule Completed 7/10/25By D&M

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results
1246	Redbud	08/01/23	D	1248	Disconnecting	Baffles intact; Clean cast & Lid
1247	Redbud	08/01/23	D	1245		Baffles intact; Clean cast & Lid
1248	Redbud	08/01/23	D	1246		Baffles intact; Clean cast & Lid
1249	Redbud	08/09/23	D	1251		Baffles intact; Clean cast & Lid
1250	Redbud	07/31/24	D	1252		Baffles intact; Clean cast & Lid
1251	Redbud	08/09/23	D	1249		Baffles intact; Clean cast & Lid
1252	Redbud	07/31/24	D	1250		Baffles intact; Clean cast & Lid
1253	Redbud	08/09/23	S			Baffles intact; Clean cast & Lid
1254	Redbud	08/28/25	D	1256		
1255	Redbud	08/05/21	D>		W/ 1254 Dogwood	
1256	Redbud	08/28/25	D	1254		
1259	Redbud	08/09/23	S		New 3/94	Baffles intact; Clean cast & Lid. Riser needs replaced
1261	Redbud	08/16/23	S			Baffles intact; Clean cast & Lid
1263	Redbud	08/28/25	S			Baffles intact; Clean cast & Lid
1264	Redbud	08/05/21	D>		W/ 225 Dogwood	
1265	Redbud	08/16/23	S			Baffles intact; Clean cast & Lid
1266	Redbud	08/09/23	D	1269		Baffles intact; Clean cast & Lid
1269	Redbud	08/09/23	D	1266		Baffles intact; Clean cast & Lid
1805	Riverline	09/04/25	D	1825		
1825	Riverline	09/04/25	D	1805		
1830	Riverline	08/24/22	S			Baffles intact; Clean cast & Lid
1835	Riverline	08/24/22	S			Baffles intact; Clean cast & Lid
2401	Riverview	08/24/22	S		On Graham	Baffles intact; Clean cast & Lid
2402	Riverview	10/07/21	S		On Graham	
2501	Riverview	08/24/22	S			Baffles intact; Clean cast & Lid
2502	Riverview	10/12/22	D>		W/ 561 Brummitt Rd	Baffles intact; Clean cast & Lid
2601	Riverview	08/24/22	S			Baffles intact; Clean cast & Lid
501	Starwood	08/17/22	S		Shown as Dbl Tk on original	Baffles intact; Cast. & Seal Good shape
502	Starwood	08/17/22	S			Baffles intact; Clean cast & Lid
520	Starwood	08/03/22	S			Baffles intact; Clean cast & Lid

IBCD CUSTOMER TANK PUMPING LIST

HOLDING TANK PROPERTY ASSIGNMENTS AND CLEANOUT SCHEDULE

11/2/2025

LEGENDS

1/11/2010

Other Up dates/corrections to information

Note: Tanks are pumped and inspected every five years.

Date 2021 Fall Clean Out Schedule Completed By D&M

Date 2022 Fall Clean Out Schedule Completed By D&M

Date 2023 Fall Clean Out Schedule Completed By D&M

Date 2024 Fall Clean Out Schedule Completed By D&M

Date 2025 Fall Clean Out Schedule Completed 7/10/25By D&M

House No.	Street Name	Date Pumped See Color Code Above	Tank S single D double	Shared Address	Comments	Tank Cover Seal and Video Inspection Results
521	Starwood	08/17/16	D>		W/ 1765 In Bdry Shown as Sgl Tk on Original	Baffles intact; Seal OK
1601	Starwood	10/07/21	S		On In Bdry	Baffles intact; Casting cleaned, Seal OK
1635	Starwood	08/03/22	D	1665	On Riverline	Baffles intact; Clean cast & Lid
1660	Starwood	08/03/22	D	1690		Baffles intact; Clean cast & Lid
1665	Starwood	08/03/22	D	1635		Baffles intact; Clean cast & Lid
1690	Starwood	08/03/22	D	1660		Baffles intact; Clean cast & Lid
1695	Starwood	08/03/22	S			Baffles intact; Clean cast & Lid
1730	Starwood	08/03/22	D	1760		Baffles intact; Clean cast & Lid
1735	Starwood	08/03/22	S			Baffles intact; Clean cast & Lid
1760	Starwood	08/03/22	D	1730		Baffles intact; Clean cast & Lid
1765	Starwood	08/16/22	S			Baffles intact; Clean cast & Lid
1795	Starwood	08/03/22	S			Baffles intact; Clean cast & Lid
1250	Trillium	07/29/21	S			Baffles intact; Casting cleaned, Seal OK
1251	Trillium	08/26/21	S			Baffles intact; Casting cleaned, Seal OK
1252	Trillium	08/12/21	S			Baffles intact; Casting cleaned, Seal OK
1254	Trillium	07/29/21	S			Baffles intact; Casting cleaned, Seal OK
1251	Violet	08/31/22	S			Baffles intact; Clean cast & Lid **Broken Punch out causing sinkhole & sand in tank
1252	Violet	08/31/22	S			Baffles intact; Clean cast & Lid
332	Wake Robin	08/12/21	S			Baffles intact; Casting cleaned, Seal OK
392	Wake Robin	08/12/21	D>		w/ 205 Dogwood	Baffles intact; Casting cleaned, Seal OK
1260	Wake Robin	07/29/21	D	1266		Baffles intact; Casting cleaned, Seal OK
1261	Wake Robin	07/29/21	D	1265		Baffles intact; Casting cleaned, Seal OK
1265	Wake Robin	07/29/21	D	1261	New 1/98	Baffles intact; Casting cleaned, Seal OK
1266	Wake Robin	07/29/21	D	1260		Baffles intact; Casting cleaned, Seal OK
1270	Wake Robin	08/12/21	D>		W/ 1570 In Bdry	Baffles intact; Casting cleaned, Seal OK
1271	Wake Robin	10/12/22	D>		W/ 1650 In Bdry	Baffles intact; Clean cast & Lid