Indiana State Department of Health
An Equal Opportunity Employer

Michael R. Pence
Governor

Jerome M. Adams, MD, MPH
State Health Commissioner

STATE OF INDIANA)
) SS:
COUNTY OF MARION)

ADMINISTRATIVE ORDER OF THE INDIANA STATE DEPARTMENT OF HEALTH
Cause no. Gasoline Sample – Water Test
Registration Number: B5-92404

IN THE MATTER OF THE OPERATION OF)
Circle K (Shell #15))
211 S. VanBuren)
Nashville, IN 47448)

TO: Circle K (Shell #15)
211 S. VanBuren
Nashville, IN 47448

EMERGENCY STOP – SALE ORDER

You are **NOTIFIED** that the Division of Weights and Measures, Indiana State Department of Health, pursuant to Indiana Code 16-44-3-7 (2) and Indiana code 4-21.5-4 et seq. hereby **ORDERS YOU TO IMMEDIATELY STOP THE SALE** of motor fuel from the fuel pumps dispensing grades (89) & (93) octane motor fuel, at the facility known as **Circle K (shell#15)** located at **211 South VanBuren Nashville Indiana 47448**

This order is based upon the following: **Circle K (shell#15)** is a motor fuel outlet facility engaged in the sale of retail motor fuel to the public.

On **August 4, 2015** a Representative of the Division of Weights and Measures, Indiana State Department of Health conducted an inspection of **Circle K (shell#15)** facilities of the unleaded (89) & (93) octane grades of gasoline. The results of Gasoila and Sar-Gel paste test conducted on said motor fuel storage tanks reveals **6 inches** of water / phase separation in the (93) unleaded storage tank which are blender pumps at this location.

ASTM Standard for unleaded fuels is no more than ¼ of inch of water in fuel storage tank.

This is a violation of the Indiana Code 16-44-3-1 et seq., and 410 IAC 12.1-2-2(a), "Standard Specification for Automotive Spark-Ignition Engine Fuel".

YOU ARE HEREBY ORDERED TO IMMEDIATELY STOP THE SALE of (89) & (93) octane Unleaded fuels from the fuel pumps dispensing at the facility known as:**Circle K (shell#15) 211 S. VanBuren Nashville, Indiana 47448**