PRINTED: 11/06/2020 FORM APPROVED

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION A. BUILDING:		(X3) DATE SURVEY COMPLETED	
		005051			07/28/2020	
	ROVIDER OR SUPPLIER	1701 N S	ADDRESS, CITY, STATE SENATE BLVD	ZIP CODE		
			APOLIS, IN 46202			
(X4) ID PREFIX TAG	(EACH DEFICIEN	STATEMENT OF DEFICIENCIES ICY MUST BE PRECEDED BY FULL R LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORREC (EACH CORRECTIVE ACTION SHO CROSS-REFERENCED TO THE APPI DEFICIENCY)	OULD BE COM	X5) IPLETI ATE
S 000	INITIAL COMMENT	S	S 000			
	Facility Number: 005051					
	Survey Date: 7/28/2020					
		t rooms were successfully pressure: E1234, and				
	The following patien successfully verified	nt rooms failed to be I as negative pressure: None				
	QA: 7/29/20					
no Stato [Department of Health					