

Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 004683	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 04/16/2020
--	---	---	---

NAME OF PROVIDER OR SUPPLIER INDIANA UNIVERSITY HEALTH BEDFORD HOSPITAL	STREET ADDRESS, CITY, STATE, ZIP CODE 2900 W 16TH ST BEDFORD, IN 47421
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
S 000	<p>INITIAL COMMENTS</p> <p>This visit was for a licensure review of negative pressure rooms per ISDH CSHCR: Program Advisory Letter Number: AC-2020-01-HOSP.</p> <p>Facility Number: 004683</p> <p>Survey Date: 4/16/2020</p> <p>The following rooms were successfully verified as negative pressure: #419, 418, 417, 416, 133, 134, ED area #1 and 2.</p> <p>The following rooms failed to be successfully verified as negative pressure: None.</p> <p>QA: 4/23/2020</p>	S 000		

Indiana State Department of Health LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
---	-------	-----------