

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G814	X2) MULTIPLE CONSTRUCTION A. BUILDING -- _____ B. WING _____	X3) DATE SURVEY COMPLETED 01/23/2018
--	---	--	---

NAME OF PROVIDER OR SUPPLIER VOCA CORPORATION OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 8307 CASTLETON BLVD INDIANAPOLIS, IN 46256
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

E 0000 Bldg. --	<p>An Emergency Preparedness Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.475.</p> <p>Survey Date: 01/23/18</p> <p>Facility Number: 010453 Provider Number: 15G814 AIM Number: 201408320</p> <p>At this Emergency Preparedness survey, Voca Corporation of Indiana Inc was found not in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.475</p> <p>The facility has 8 certified beds. All 8 beds are certified for Medicaid. At the time of the survey, the census was 7.</p> <p>Quality Review completed on 01/24/18 - DA</p> <p>The requirement at 42 CFR, Subpart 483.475 is NOT MET as evidenced by:</p>	E 0000		
------------------------	--	--------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined other safeguards provide sufficient protection to the patients. (see instructions.) Except for nursing homes, the findings stated above are disclosable following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosed days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G814	X2) MULTIPLE CONSTRUCTION A. BUILDING -- _____ B. WING _____		X3) DATE SURVEY COMPLETED 01/23/2018
NAME OF PROVIDER OR SUPPLIER VOCA CORPORATION OF INDIANA			STREET ADDRESS, CITY, STATE, ZIP CODE 8307 CASTLETON BLVD INDIANAPOLIS, IN 46256		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 0004 Bldg. --	<p>Based on record review and interview, the facility failed to develop and maintain an emergency preparedness plan that was reviewed and updated at least annually in accordance with 42 CFR 483.475(a). This deficient practice could affect all occupants.</p> <p>Findings include:</p> <p>Based on record review with the Maintenance Aide from 10:30 a.m. to 11:10 a.m. on 01/23/18, the facility failed to develop and maintain an emergency preparedness plan that was reviewed and updated at least annually. Based on interview at the time of record review, the Maintenance Aide stated the facility has a target date of 02/01/18 for completion of a plan and agreed an emergency preparedness plan for the facility was not available for review at the time of the survey.</p>	E 0004	<p>CORRECTION:</p> <p><i>The facility must develop establish and maintain a comprehensive emergency preparedness program. Specifically, with the assistance of the agency's Safety Committee, the facility will update its emergency Preparedness plan to include the following elements: an Emergency Plan, Policies and Procedures, a Communication Plan and Training and Testing.</i></p> <p>PREVENTION:</p> <p>Members of the Operations Team (comprised of the Operations Managers, Program Managers, Nurse Manager, Executive Director, Quality Assurance Manager, Quality Assurance Coordinators and QIDP Manager) will incorporate reviews of the facility's emergency preparedness program into scheduled twice monthly audits to assure all required components are present. Additionally, the agency Safety committee will review and revise the plan as needed but no less than annually.</p>	02/22/2018	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G814	X2) MULTIPLE CONSTRUCTION A. BUILDING: -- B. WING: _____	X3) DATE SURVEY COMPLETED 01/23/2018
--	---	--	---

NAME OF PROVIDER OR SUPPLIER VOCA CORPORATION OF INDIANA	STREET ADDRESS, CITY, STATE, ZIP CODE 8307 CASTLETON BLVD INDIANAPOLIS, IN 46256
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 0000 Bldg. 01	<p>A Life Safety Code Recertification Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j).</p> <p>Survey Date: 01/23/18</p> <p>Facility Number: 010453 Provider Number: 15G814 AIM Number: 201408320</p> <p>At this Life Safety Code survey, Voca Corporation of Indiana was found in compliance with Requirements for Participation in Medicaid, 42 CFR Subpart 483.470(j), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.</p> <p>This one story building was determined to</p>	K 0000	<p>RESPONSIBLE PARTIES: QIDP, Area Supervisor, Residential Manager, Direct Support Staff, Operations Team, Regional Director</p>	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15G814	X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		X3) DATE SURVEY COMPLETED 01/23/2018
NAME OF PROVIDER OR SUPPLIER VOCA CORPORATION OF INDIANA			STREET ADDRESS, CITY, STATE, ZIP CODE 8307 CASTLETON BLVD INDIANAPOLIS, IN 46256		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCY (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
	<p>be fully sprinklered. The facility has a fire alarm system with smoke detection in corridors and all living areas. The facility has smoke detectors hard wired to the fire alarm system installed in all bedrooms. The facility has a capacity of 8 and had a census of 7 at the time of this survey.</p> <p>Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101A, Alternative Approaches to Life Safety, Chapter 6, rated the facility Prompt with an E-Score of 0.8.</p> <p>Quality Review completed on 01/24/18 - DA</p>				