

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/07/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155053	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 03/02/2023
NAME OF PROVIDER OR SUPPLIER WATERS OF RUSHVILLE SKILLED NURSING FACILITY, THE			STREET ADDRESS, CITY, STATE, ZIP CODE 612 E 11TH ST RUSHVILLE, IN 46173	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{E 000}	Initial Comments A Post Survey Revisit (PSR) to the Emergency Preparedness Survey conducted on 01/11/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.73. Survey Date: 03/02/23 Facility Number: 000018 Provider Number: 155053 AIM Number: 100273930 At this PSR Emergency Preparedness survey, The Waters of Rushville Skilled Nursing Facility was found in compliance with Emergency Preparedness Requirements for Medicare and Medicaid Participating Providers and Suppliers, 42 CFR 483.73. The facility has 98 certified beds. At the time of the PSR survey, the census was 47.	{E 000}		
{K 000}	Quality Review completed on 03/06/23 INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 01/11/23 was conducted by the Indiana Department of Health in accordance with 42 CFR 483.90(a). Survey Date: 03/02/23 Facility Number: 000018 Provider Number: 155053 AIM Number: 100273930 At this PSR Life Safety Code survey, The Waters	{K 000}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/07/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155053	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 03/02/2023
NAME OF PROVIDER OR SUPPLIER WATERS OF RUSHVILLE SKILLED NURSING FACILITY, THE			STREET ADDRESS, CITY, STATE, ZIP CODE 612 E 11TH ST RUSHVILLE, IN 46173		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 1</p> <p>of Rushville Skilled Nursing Facility was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.90(a), Life Safety from Fire and the 2012 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p> <p>This one-story facility was determined to be of Type V (000) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors and battery-operated smoke detectors in all resident sleeping rooms. The healthcare portion of the facility has a capacity of 98 and had a census of 47 at the time of this PSR visit.</p> <p>All areas where residents have customary access were sprinklered and all areas providing facility services were sprinklered. The facility had two detached wooden storage buildings which were not sprinklered.</p> <p>Quality Review completed on 03/06/23</p>	{K 000}			