

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/12/2016  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155740</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01, 02</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>09/08/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>TIMBERCREST CHURCH OF THE BRETHERN HOME</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>2201 EAST ST</b> <b>NORTH MANCHESTER, IN 46962</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>INITIAL COMMENTS</p> <p>Paper compliance to the Life Safety Code Recertification and State Licensure Survey conducted on 08/22/16 was completed on 09/08/16.</p> <p>Review Date: 09/08/16</p> <p>Facility Number: 000448 Provider Number: 155740 AIM Number: 100275140</p> <p>Timbercrest Church of The Brethren Home was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2.</p>	{K 000}			
{K 000}	<p>INITIAL COMMENTS</p> <p>Paper compliance to the Life Safety Code Recertification and State Licensure Survey conducted on 08/22/16 was completed on 09/08/16.</p> <p>Review Date: 09/08/16</p> <p>Facility Number: 000448 Provider Number: 155740 AIM Number: 100275140</p> <p>Timbercrest Church of The Brethren Home was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 Edition of the National Fire Protection</p>	{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/12/2016  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155740</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01, 02</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>09/08/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>TIMBERCREST CHURCH OF THE BROTHERS HOME</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>2201 EAST ST</b> <b>NORTH MANCHESTER, IN 46962</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	Continued From page 1 Association (NFPA) 101, Life Safety Code (LSC), Chapter 18, New Health Care Occupancies and 410 IAC 16.2.	{K 000}		