

From: Joann Worthington <jworthington@voltus.co>
Sent: Friday, July 12, 2024 3:09 PM
To: Comments, Urc <URCComments@urc.IN.gov>
Cc: Rao Konidena <rkonidena76@gmail.com>
Subject: Public Comment on Strawman of Amendments to Customer-Generator Interconnection Rule, 170 IAC 4-4.

Thank you for the opportunity to comment on Indiana's Customer-Generator Interconnection Rule, 170 IAC 4-4.3. Voltus is concerned with how the definitional changes will affect co-located resources, namely how solar+storage would be studied. Statements made at the June 11, 2024, stakeholder meeting indicated that injection at max capacity would be studied. Voltus would like the IURC to ensure that only net injection is studied and that storage assets are studied for discharge during peak demand hours not charging during peak demand hours.

--



Joann Worthington- Senior Manager Regulatory Affairs
Voltus, Inc. | Oklahoma City, OK
[405-653-8138](tel:405-653-8138) | jworthington@voltus.co | <http://www.voltus.co/vlog>