

**ORIGINAL**

Commissioner	Yes	No	Not Participating
Huston			√
Bennett	√		
Freeman	√		
Veleta	√		
Ziegner	√		

**INDIANA UTILITY REGULATORY COMMISSION**

Final Rulemaking

LSA #25-368  
IURC RM #24-01

This Final Rulemaking amends 170 IAC 4-4.3-1, 170 IAC 4-4.3-2, 170 IAC 4-4.3-3, 170 IAC 4-4.3-4, 170 IAC 4-4.3-5, 170 IAC 4-4.3-6, 170 IAC 4-4.3-7, 170 IAC 4-4.3-8, 170 IAC 4-4.3-9, 170 IAC 4-4.3-10, 170 IAC 4-4.3-11, and 170 IAC 4-4.3-12 to expand the definition of “customer-generator facility”, to update the performance standards for “customer-facilities”, by incorporating IEEE 1547-2018, *Standard for Interconnection and Interoperability of Distributed Energy Resources and Associated Electric Power Systems Interfaces* and Underwriters Laboratories 1741: *Standards for Inverters, Converters, Controllers and Interconnection System Equipment for Use with Distributed Energy Resources*, and to increase the Level 1 interconnection threshold from 10 kW to 25 kW.

The final rule is effective 30 days after filing with the publisher.

Upon prior publication of notice, a public hearing was held on August 27, 2025, at 10:30 a.m. local time in Judicial Courtroom 222 of the PNC Center, 101 W. Washington Street, Indianapolis, Indiana, as required by the provisions of I.C. 4-22-2-1, et seq.

The Indiana Utility Regulatory Commission previously adopted the proposed rule on June 18, 2025, at 10:00 a.m. local time in Judicial Courtroom 222, PNC Center, Indianapolis, Indiana at which time a majority of members of said Commission were present.

The Secretary is hereby directed to submit the aforesaid final rule to the Attorney General and Governor of Indiana, for their approval of same, and thereafter to submit the aforesaid rule to the publisher, Indiana Register.

**IT IS SO ORDERED.**

**BENNETT, FREEMAN, VELETA, AND ZIEGNER CONCUR; HUSTON ABSENT:**

**APPROVED: SEP 30 2025**

**I hereby certify that the above is a true and correct copy of the Rule as approved.**

\_\_\_\_\_ on behalf of  
**Dana Kosco**  
**Secretary of the Commission**

# TITLE 170 INDIANA UTILITY REGULATORY COMMISSION

## FINAL RULE LSA Document #25-368

SECTION 1. 170 IAC 4-4.3-1 IS AMENDED TO READ AS FOLLOWS:

### 170 IAC 4-4.3-1 Definitions

**Authority: IC 8-1-1-3; IC 8-1-2.4**

**Affected: IC 8-1-2-1**

Sec. 1. (a) The definitions in this section apply throughout this rule.

(b) "Area network" means a type of electric distribution system served by multiple transformers interconnected in an electrical network circuit that is generally used in large metropolitan areas, which are densely populated, ~~in order~~ to provide high reliability of service.

(c) "Commission" means the Indiana utility regulatory commission.

(d) ~~"Customer generator"~~ **"Customer facility"** means an arrangement of equipment for the production of electricity, ~~that~~ **including energy storage systems or technologies, which** is owned and operated by:

- (1) an eligible customer; or
- (2) a third party at the eligible customer's site.

(e) "Eligible customer" means any:

- (1) person;
- (2) firm;
- (3) corporation;
- (4) municipality; or
- (5) other government agency;

that has agreed, orally or otherwise, to pay for electric service received from an investor-owned electric utility and is in good standing with that utility.

(f) "Equipment package" means a group of components connecting ~~an electric generator~~ **a customer facility** with an electric distribution system and includes all interface equipment, including any of the following:

- (1) Switchgear.
- (2) Inverters.
- (3) Other interface devices.

The term includes an integrated generator or electric source.

(g) "Interconnection" or "interconnected" means the physical, parallel connection of a ~~customer generator~~ **customer** facility with a distribution facility of an investor-owned electric utility.

(h) "Investor-owned electric utility" or "utility" means a public utility, as defined in IC 8-1-2-1:

- (1) that provides electricity;
- (2) that is financed by the sale of securities; and
- (3) whose business operations are overseen by a board representing the utility's shareholders.

(i) "Nameplate capacity" means the full-load continuous rating of a ~~generator~~ **customer facility** under specified conditions ~~as~~ designated by the manufacturer.

(j) "Parallel" means the designed operation of the:

- (1) ~~customer generator~~ **customer** facility;
- (2) interconnection equipment; and

(3) investor-owned electric utility's system;

where the instantaneous flow of electrical energy may automatically occur in either direction across the interconnection point between the ~~customer-generator~~ **customer** facility and the electrical utility's distribution system.

(k) "Spot network" means a type of electric distribution system that uses **at least** two (2) intertied transformers to supply an electrical network circuit. A spot network is generally used to supply power to a single customer or a small group of customers.

(l) "System emergency" means a condition on a utility's system reasonably likely to result in any of the following:

- (1) A significant disruption of service to a customer.
- (2) A substantial deviation from a normal service standard.
- (3) An endangerment to life or property.

*(Indiana Utility Regulatory Commission; 170 IAC 4-4.3-1; filed Mar 6, 2006, 9:45 a.m.: 29 IR 2170; readopted filed Jul 12, 2012, 2:12 p.m.: 20120808-IR-170120114RFA; readopted filed Aug 2, 2013, 2:16 p.m.: 20130828-IR-170130227RFA; readopted filed Apr 11, 2019, 9:04 a.m.: 20190508-IR-170190136RFA)*

SECTION 2. 170 IAC 4-4.3-2 IS AMENDED TO READ AS FOLLOWS:

#### **170 IAC 4-4.3-2 Applicability**

**Authority: IC 8-1-1-3; IC 8-1-2.4**

**Affected: IC 8-1-2**

Sec. 2. This rule ~~shall apply~~ **applies** to any investor-owned electric utility, subject to the jurisdiction of the commission, that may now or hereafter be engaged in the:

- (1) production;
- (2) transmission;
- (3) sale; or
- (4) distribution;

of electric service and ~~all customer-generator~~ **the customer** facilities that apply for interconnection with ~~such~~ **those** utilities on or after the effective date of this rule. *(Indiana Utility Regulatory Commission; 170 IAC 4-4.3-2; filed Mar 6, 2006, 9:45 a.m.: 29 IR 2171; readopted filed Jul 12, 2012, 2:12 p.m.: 20120808-IR-170120114RFA; readopted filed Aug 2, 2013, 2:16 p.m.: 20130828-IR-170130227RFA; readopted filed Apr 11, 2019, 9:04 a.m.: 20190508-IR-170190136RFA)*

SECTION 3. 170 IAC 4-4.3-3 IS AMENDED TO READ AS FOLLOWS:

#### **170 IAC 4-4.3-3 Exemptions**

**Authority: IC 8-1-1-3; IC 8-1-2.4**

**Affected: IC 8-1-2**

Sec. 3. (a) ~~Customer-generator~~ **Customer** facilities ~~shall be~~ **are** exempt from revenue requirements and associated regulation under IC 8-1-2 as administered by the commission, ~~except that~~ **but** the commission shall have authority over rates charged by electric utilities to ~~customer-generator~~ **customer** facilities.

(b) ~~Upon~~ **On** the agreement of an eligible customer and the utility, the ~~customer-generator~~ **customer** facility interconnection may be exempt from the requirements of this rule, except for the provisions of section 4(f) and 4(g) of this rule. *(Indiana Utility Regulatory Commission; 170 IAC 4-4.3-3; filed Mar 6, 2006, 9:45 a.m.: 29 IR 2171; readopted filed Jul 12, 2012, 2:12 p.m.: 20120808-IR-170120114RFA; readopted filed Aug 2, 2013, 2:16 p.m.: 20130828-IR-170130227RFA; readopted filed Apr 11, 2019, 9:04 a.m.: 20190508-IR-170190136RFA)*

SECTION 4. 170 IAC 4-4.3-4 IS AMENDED TO READ AS FOLLOWS:

#### **170 IAC 4-4.3-4 General interconnection provisions**

**Authority: IC 8-1-1-3; IC 8-1-2.4**

**Affected: IC 8-1-2**

Sec. 4. (a) ~~Each~~ **An** investor-owned electric utility shall provide each of the following three (3) procedures for applications for ~~the~~ interconnection of ~~customer-generator~~ **customer** facilities and use:

(1) The Level 1 review procedure described in section 6 of this rule for applications to connect inverter-based ~~customer-generator~~ **customer** facilities that:

(A) have a nameplate capacity of ~~ten (10)~~ **not more than twenty-five (25)** kilowatts; ~~or less;~~ and

(B) meet the certification requirements of section 5 of this rule.

(2) The Level 2 review procedure described in section 7 of this rule for applications to connect ~~customer-generator~~ **customer** facilities:

(A) with a nameplate capacity of **not more than two (2)** megawatts; ~~or less;~~ and

(B) that meet the certification requirements of section 5 of this rule.

(3) The Level 3 review procedure described in section 8 of this rule for applications to connect ~~customer-generator~~ **customer** facilities to its distribution system that do not qualify for either Level 1 or Level 2 interconnection review procedures.

(b) Each utility shall designate a contact person or **an** office from which an eligible customer can obtain basic application forms and information through an informal process.

(c) Each utility shall use commission-approved interconnection application and interconnection agreement forms.

(d) The utility may require the applicant to include a disconnect switch as a supplement to the equipment package.

(e) Application and interconnection review fees ~~shall be~~ **are** set as follows:

(1) A utility ~~shall~~ **may** not charge an application **fee**, or **any** other fee, to an applicant that requests Level 1 interconnection review. However, if an application for Level 1 interconnection review is denied because the:

(A) application does not meet the requirements for Level 1 interconnection review; and

(B) applicant resubmits the application under another review procedure;

the utility may impose a fee for the resubmitted application, consistent with this section.

(2) For a Level 2 interconnection review, the utility may charge fees up to fifty dollars (\$50) plus one dollar (\$1) per kilowatt of the ~~customer-generator~~ **customer** facility's nameplate capacity, plus the cost of any minor modifications to the electric distribution system or additional review, if required under section 7(q)(3) of this rule. Costs for minor modifications or additional review ~~shall be~~ **are**:

(A) based on utility estimates; and

(B) subject to review by the commission or its designee.

Costs for engineering work done as part of ~~any~~ **an** additional review ~~shall~~ **may** not exceed one hundred dollars (\$100) per hour.

(3) For a Level 3 interconnection review, the utility may charge fees up to one hundred dollars (\$100) plus two dollars (\$2) per kilowatt of the ~~customer-generator~~ **customer** facility's nameplate capacity, as well as charges for actual time spent on any impact or facilities studies required under section 8 of this rule. Costs for engineering work done as part of ~~any~~ **an** impact or a facilities study ~~shall~~ **may** not exceed one hundred dollars (\$100) per hour. If the utility must install facilities ~~in order~~ to accommodate the interconnection of the ~~customer-generator~~ **customer** facility, the cost of ~~such~~ **those** facilities ~~shall be~~ **is** the responsibility of the applicant.

(f) The interconnection and operation of ~~any customer-generator~~ **a customer** facility is secondary to and ~~shall~~ **may** not interfere with the ability of the utility to meet its primary responsibility of furnishing reasonably adequate service to all customers.

(g) ~~All~~ The ~~customer-generator~~ **customer** facility electrical installations ~~shall~~ **must** conform to the following:

(1) The requirements of local ordinances and inspection authorities.

(2) The applicable requirements of this rule.

*(Indiana Utility Regulatory Commission; 170 IAC 4-4.3-4; filed Mar 6, 2006, 9:45 a.m.: 29 IR 2171; readopted filed Jul 12, 2012, 2:12 p.m.: 20120808-IR-170120114RFA; readopted filed Aug 2, 2013, 2:16 p.m.: 20130828-IR-170130227RFA; readopted filed Apr 11, 2019, 9:04 a.m.: 20190508-IR-170190136RFA)*

SECTION 5. 170 IAC 4-4.3-5 IS AMENDED TO READ AS FOLLOWS:

#### **170 IAC 4-4.3-5 Certification of customer facilities**

**Authority: IC 8-1-1-3; IC 8-1-2.4**

**Affected: IC 8-1-2**

Sec. 5. (a) ~~In order~~ To qualify for the Level 1 and the Level 2 interconnection review procedures described in sections 6 and 7 of this rule, a ~~customer-generator~~ **customer** facility ~~must~~ **shall** be certified as complying with the following standards, as applicable:

(1) **Institute of Electrical and Electronics Engineers (IEEE) 1547-2018**, Standard for ~~Interconnecting~~ **Interconnection and Interoperability of Distributed Energy Resources with Associated Electric Power Systems as amended and supplemented, Interfaces**, which is incorporated by reference herein. IEEE ~~1547- 1547-2018~~ can be obtained through the IEEE at ~~445 Hoes Lane, P.O. Box 1331, Piscataway, New Jersey 08855-1331~~ or at ~~www.ieee.org~~ **www.standards.ieee.org**.

(2) Underwriters Laboratories (UL) ~~Standard on~~ **1741: Standards for Inverters, Converters, and Controllers, and Interconnection System Equipment for Use in Independent Power Systems (January 2001), as amended and supplemented with Distributed Energy Resources (3rd ed. 2021, rev. Oct. 23, 2024)**, which is incorporated by reference herein. UL Standards can be obtained through Underwriters Laboratories at ~~333 Pfingsten Road, Northbrook, Illinois 60062-2096~~ or at ~~www.ul.com~~.

(b) An equipment package ~~shall be~~ **is** considered certified for interconnection operation if it has been tested and listed by a nationally recognized testing and certification laboratory in compliance with subsection (a)(1).

(c) If the equipment package has been tested and listed in accordance with this section as an integrated package that includes a ~~generator or other electric source~~ **the customer facility**:

(1) ~~the~~ equipment package ~~shall be~~ **is** deemed certified; and

(2) ~~the~~ utility shall not require:

(A) further design review;

(B) testing; or

(C) additional certification;

of the listed equipment package.

(d) If the equipment package includes only the interface components, an interconnection applicant must show that the ~~generator or other electric source~~ **customer facility** being ~~utilized~~ **used** with the equipment package is:

(1) compatible with the equipment package; and

(2) consistent with the testing and listing performed by ~~the~~ **a** nationally recognized testing and certification laboratory.

If the ~~generator or electric source~~ **customer facility** being ~~utilized~~ **used** with the equipment package is consistent with the testing and listing performed by ~~the~~ **a** nationally recognized testing and certification laboratory, the equipment package ~~shall be~~ **is** deemed certified, and the utility shall not require further design review, testing, or additional certification of the listed equipment package. (*Indiana Utility Regulatory Commission; 170 IAC 4-4.3-5; filed Mar 6, 2006, 9:45 a.m.: 29 IR 2172; readopted filed Jul 12, 2012, 2:12 p.m.: 20120808-IR-170120114RFA; readopted filed Aug 2, 2013, 2:16 p.m.: 20130828-IR-170130227RFA; readopted filed Apr 11, 2019, 9:04 a.m.: 20190508-IR-170190136RFA*)

SECTION 6. 170 IAC 4-4.3-6 IS AMENDED TO READ AS FOLLOWS:

**170 IAC 4-4.3-6 Level 1 interconnection review**

**Authority: IC 8-1-1-3; IC 8-1-2.4**

**Affected: IC 8-1-2**

Sec. 6. (a) Each investor-owned electric utility shall adopt a Level 1 interconnection review procedure. The utility shall use the Level 1 review procedure for an application to interconnect a ~~customer-generator~~ **customer** facility that:

(1) is inverter-based;

(2) has a nameplate capacity of ~~ten (10)~~ **not more than twenty-five (25)** kilowatts; ~~or less~~; and

(3) is certified in accordance with section 5 of this rule.

(b) For a ~~customer-generator~~ **customer** facility described in subsection (a), the utility shall approve interconnection under the Level 1 review if ~~all of~~ the applicable requirements in subsections (c) ~~through~~ **through** (h) are met. A utility ~~shall~~ **may** not impose additional requirements not specifically authorized under this section.

(c) If a ~~customer-generator~~ **customer** facility is to be connected to a radial distribution circuit, the aggregate generation nameplate capacity connected to the circuit, including the proposed nameplate capacity, ~~shall~~ **may** not exceed five percent (5%) of the circuit annual peak load as most recently measured at the substation; the aggregate generation nameplate capacity

connected to a line section, including the proposed nameplate capacity, ~~shall~~ **may** not exceed ten percent (10%) of the line section annual peak load as most recently measured or estimated based on the most recently measured circuit load at the substation.

(d) The aggregate generation nameplate capacity on the distribution circuit to which the ~~customer-generator~~ **customer** facility will interconnect, including its nameplate capacity, ~~shall~~ **may** not contribute more than ten percent (10%) to the circuit's maximum fault current at the point ~~on which~~ **where** the primary level that is nearest the proposed point of common coupling.

(e) If a ~~customer-generator~~ **customer** facility is to be connected to a single-phase shared secondary, the aggregate generation nameplate capacity connected to the shared secondary, including the proposed nameplate capacity, ~~shall~~ **may** not exceed the lesser of twenty (20) kVA or the nameplate rating of the service transformer.

(f) If a single-phase ~~customer-generator~~ **customer** facility is to be interconnected on a center tap neutral of a two hundred forty (240) volt service, the addition of the ~~customer-generator~~ **customer** facility ~~shall~~ **may** not create an imbalance between the two (2) sides of the two hundred forty (240) volt service more than twenty percent (20%) of the nameplate rating of the service transformer.

(g) The ~~customer-generator~~ **customer** facility point of common coupling ~~shall~~ **may** not be on:

- (1) a transmission line;
- (2) a spot network; or
- (3) an area network.

(h) The ~~customer-generator~~ **customer** facility ~~shall~~ **may** not violate ~~any~~ **the** applicable provisions of ~~IEEE 1547- the~~ **Institute of Electrical and Electronic Engineers 1547-2018**, Standard for ~~Interconnecting~~ **Interconnection and Interoperability of Distributed Energy Resources with Associated Electric Power Systems Interfaces**, as identified by the utility.

(i) The utility shall notify the applicant within ten (10) business days after receiving an application for Level 1 interconnection review as to whether the application is complete. If the application is incomplete, the notification ~~shall~~ **must** include a list detailing the information needed to complete the application.

(j) Within fifteen (15) business days after the utility notifies the applicant that the application is complete, the utility shall notify the applicant that the ~~customer-generator~~ **customer** facility:

- (1) meets ~~all of~~ the criteria in subsections (c) through (h) that apply to the facility, and the interconnection will be finally approved ~~upon on~~ completion of the process set forth in subsections (k) ~~through~~ **through** (m); or
- (2) has failed to meet **at least** one (1) ~~or more~~ of the applicable criteria in subsections (c) through (h), and the interconnection application is denied.

(k) If approved, the utility shall, within ten (10) business days after sending the notice of approval under subsection (j)(1), do the following:

- (1) Notify the applicant if the utility will require inspection of the ~~customer-generator~~ **customer** facility for compliance with this rule before starting operation of the facility.
- (2) Execute and send to the applicant a Level 1 interconnection agreement.

(l) An applicant that receives an interconnection agreement under subsection (k) shall do the following:

- (1) Execute the agreement.
- (2) Return the agreement to the utility at least ten (10) business days before starting operation of the ~~customer-generator~~ **customer** facility.
- (3) Indicate the anticipated start date for operation of the ~~customer-generator~~ **customer** facility.

If the utility requires an inspection of the ~~customer-generator~~ **customer** facility, the applicant ~~shall~~ **may** not begin operating the facility until completion of the inspection.

(m) ~~Upon:~~ **After:**

- (1) ~~receipt of~~ **receiving** the executed interconnection agreement; and
- (2) satisfactory completion of any required inspection;

the utility shall approve the interconnection, conditioned on approval by the electric code officials with jurisdiction over the

interconnection.

(n) If an application for Level 1 interconnection review is denied because it does not meet **at least** one (1) ~~or more~~ of the applicable requirements of this section, an applicant may resubmit the application under **the** Level 2 or Level 3 interconnection review procedure as appropriate. (*Indiana Utility Regulatory Commission; 170 IAC 4-4.3-6; filed Mar 6, 2006, 9:45 a.m.: 29 IR 2172; readopted filed Jul 12, 2012, 2:12 p.m.: 20120808-IR-170120114RFA; readopted filed Aug 2, 2013, 2:16 p.m.: 20130828-IR-170130227RFA; readopted filed Apr 11, 2019, 9:04 a.m.: 20190508-IR-170190136RFA*)

SECTION 7. 170 IAC 4-4.3-7 IS AMENDED TO READ AS FOLLOWS:

**170 IAC 4-4.3-7 Level 2 interconnection review**

**Authority: IC 8-1-1-3; IC 8-1-2.4**

**Affected: IC 8-1-2**

Sec. 7. (a) Each investor-owned electric utility shall adopt a Level 2 interconnection review procedure. The utility shall use the Level 2 review procedure for an application to interconnect a ~~customer-generator~~ **customer** facility that:

- (1) has a nameplate capacity of **not more than** two (2) megawatts; ~~or less~~; and
- (2) is certified in accordance with section 5 of this rule.

(b) For a ~~customer-generator~~ **customer** facility described in subsection (a), the utility shall approve interconnection under the Level 2 review if ~~all of~~ the applicable requirements in subsections (c) through (o) are met. A utility ~~shall~~ **may** not impose additional requirements not specifically authorized under this section.

(c) If a ~~customer-generator~~ **customer** facility is to be connected to a radial distribution circuit, the aggregate generation nameplate capacity connected to the circuit, including the proposed nameplate capacity, ~~shall~~ **may** not exceed fifteen percent (15%) of the line section annual peak load as most recently measured or estimated based on the most recently measured circuit load at the substation.

(d) The aggregate generation capacity on the distribution circuit to which the ~~customer-generator~~ **customer** facility will interconnect, including its capacity, ~~shall~~ **may** not contribute more than ten percent (10%) to the circuit's maximum fault current at the point ~~on which~~ **where** the primary level that is nearest the proposed point of common coupling.

(e) If a ~~customer-generator~~ **customer** facility is to be connected to a single-phase shared secondary, the aggregate generation capacity connected to the shared secondary, including the proposed capacity, ~~shall~~ **may** not exceed the lesser of twenty (20) kVA or the nameplate rating of the service transformer.

(f) If a single-phase ~~customer-generator~~ **customer** facility is to be interconnected on a center tap neutral of a two hundred forty (240) volt service, its addition will not create an imbalance between the two (2) sides of the two hundred forty (240) volt service more than twenty percent (20%) of the nameplate rating of the service transformer.

(g) The aggregate generation capacity on the distribution circuit to which the ~~customer-generator~~ **customer** facility will interconnect, including its capacity, ~~shall~~ **may** not cause any:

- (1) distribution protective equipment; or
- (2) customer equipment on the distribution system;

to exceed ninety percent (90%) of the short circuit interrupting capability of the equipment. In addition, a ~~customer-generator~~ **customer** facility ~~shall~~ **may** not be connected to a circuit that already exceeds ninety percent (90%) of the short circuit interrupting capability.

(h) If there are known or posted transient stability limits to generating units located in the general electrical vicinity of the proposed point of common coupling, for example, three (3) or four (4) transmission voltage level busses, the aggregate generation capacity, including the proposed facility, connected to the distribution low voltage side of the substation transformer feeding the distribution circuit containing the point of common coupling ~~shall~~ **may** not exceed ten (10) megawatts.

(i) If a ~~customer-generator~~ **customer** facility is to be connected to three-phase, three (3) wire primary utility distribution lines, a three-phase or single-phase generator ~~shall~~ **must** be connected phase to phase.

(j) If a ~~customer-generator~~ **customer** facility is to be connected to three-phase, four (4) wire primary utility distribution lines, the generator ~~shall appear~~ **appears** to the primary utility distribution line as an effectively grounded source.

(k) The ~~customer-generator~~ **customer** facility point of common coupling ~~shall~~ **may** not be on a transmission line.

(l) If a ~~customer-generator~~ **customer** facility is to be connected to the load side of spot network protectors, the proposed facility shall:

(1) ~~utilize~~ **use** an inverter-based equipment package; and

(2) together with the aggregated other inverter-based generation, not exceed the smaller of five percent (5%) of a spot network's maximum load or fifty (50) kilowatts.

(m) If a ~~customer-generator~~ **customer** facility is to be connected to any network, the proposed facility **shall use** a protective scheme that will ensure that its current flow will not affect the network protective devices, including reverse power relays or a comparable function. Synchronous ~~customer-generator~~ **customer** facilities ~~shall~~ **may** not be interconnected to a secondary network.

(n) If a ~~customer-generator~~ **customer** facility that:

(1) is an induction generator; or

(2) ~~utilizes~~ **uses** inverter-based protective functions;

both of which include reverse power relays functions, the proposed facility, in aggregate with other generation interconnected on the load side of the network protective devices, will not exceed the lesser of ten percent (10%) of the minimum load on the network or fifty (50) kilowatts.

(o) The ~~customer-generator~~ **customer** facility ~~shall~~ **may** not violate ~~any~~ **the** applicable provisions of **the Institute of Electrical and Electronic Engineers (IEEE) 1547-1547-2018, Standard for Interconnecting Interconnection and Interoperability of Distributed Energy Resources with Associated Electric Power Systems Interfaces**, as identified by the utility.

(p) The utility shall notify the applicant within ten (10) business days after receiving an application for Level 2 interconnection review as to whether the application is complete. If the application is incomplete, the notification ~~shall~~ **must** include a list detailing ~~all~~ **of** the information needed to complete the application.

(q) Within fifteen (15) business days after the utility notifies the applicant that the application is complete, the investor-owned electric utility shall perform an initial review to determine if the applicable requirements of subsections (c) through (o) are met. During the initial review the utility may, at its own expense, conduct any studies or tests it deems necessary to evaluate the proposed interconnection. The initial review shall result in one (1) of the following determinations:

(1) The ~~customer-generator~~ **customer** facility meets the applicable requirements in subsections (c) through (o). In this case, the utility shall:

(A) notify the applicant that the interconnection will be finally approved ~~upon~~ **on** completion of the process set forth in subsections (r) through (t); and

(B) within ten (10) business days after this notice, provide the applicant with an executable interconnection agreement.

(2) The ~~customer-generator~~ **customer** facility has failed to meet **at least** one (1) ~~or more~~ of the applicable requirements in subsections (c) through (o); however, the utility has determined that the ~~customer-generator~~ **customer** facility can be interconnected consistent with safety, reliability, and power quality. In this case, the utility shall:

(A) notify the applicant that the interconnection will be finally approved upon completion of the process set forth in subsections (r) through (t); and

(B) within ten (10) business days after this notice, provide the applicant with an executable interconnection agreement.

(3) The ~~customer-generator~~ **customer** facility has failed to meet **at least** one (1) ~~or more~~ of the applicable requirements in subsections (c) through (o); however, the initial review ~~indicates~~ **shows** that additional review may enable the utility to determine that the ~~customer-generator~~ **customer** facility can be interconnected consistent with safety, reliability, and power quality. In ~~such a~~ **this** case, the utility shall:

(A) offer to perform **an** additional review to determine whether minor modifications to the electrical distribution system would enable the interconnection to be made consistent with safety, reliability, and power quality;

(B) provide to the applicant a nonbinding, good faith estimate of the costs of the additional review or ~~the minor modifications~~ **modification**, or both; and

(C) undertake the additional review or modifications in accordance with subsection (u).

(4) The ~~customer-generator~~ **customer** facility has failed to meet **at least** one (1) ~~or more~~ of the applicable requirements of subsections (c) through (o), and the initial review ~~indicates~~ **shows** that additional review would not enable the utility to determine that the ~~customer-generator~~ **customer** facility can be interconnected consistent with safety, reliability, and power quality. In ~~such a~~ **this** case, the utility shall:

(A) notify the applicant that the interconnection application has been denied; and

(B) provide an explanation of the reason or reasons for the denial, including a list of additional information or modifications, or both, to the ~~customer-generator's~~ **customer's** facility that would be required ~~in order~~ to obtain an approval under Level 2 interconnection procedures.

(r) An applicant that receives an interconnection agreement under subsection (q)(1) or (q)(2) shall do the following:

(1) Execute the agreement.

(2) Return the agreement to the utility at least ten (10) business days before starting operation of the ~~customer-generator~~ **customer** facility.

(3) Indicate to the utility the anticipated start date for operation of the ~~customer-generator~~ **customer** facility.

(s) The utility may:

(1) require an inspection of a ~~customer-generator~~ **customer** facility for compliance with this section before operation; and

(2) require and arrange for witness of commissioning tests, as set forth in IEEE ~~1547-~~ **1547-2018**, Standard for ~~Interconnecting~~ **Interconnection and Interoperability of Distributed Energy Resources with Associated Electric Power Systems Interfaces**.

The utility shall schedule any inspections or tests under this section promptly and within a reasonable time after submittal of the application. The applicant ~~shall~~ **may** not begin operating the ~~customer-generator~~ **customer** facility until after the inspection and testing is completed.

(t) For an applicant that receives an interconnection agreement under subsection (q)(1) or (q)(2), approval of interconnected operation of the ~~customer-generator~~ **customer** facility ~~shall be~~ **is** conditioned on all ~~of~~ the following:

(1) The interconnection has been approved by the electrical code official with jurisdiction over the interconnection.

(2) ~~Any~~ **The** utility inspection or witnessing of commissioning tests arranged under subsection (s) ~~are~~ **is** successfully completed.

(3) The planned start date provided by the applicant under subsection (r)(3) has passed.

(u) For an applicant that pays for additional review under subsection (q)(3), within ten (10) business days ~~from the receipt of~~ **after payment is received**, the utility shall perform any additional review and notify the applicant of the results. If the additional review determines that the ~~customer-generator~~ **customer** facility can be interconnected without adversely affecting safety, reliability, and power quality ~~upon~~ **on** the completion of utility system modifications, the utility shall provide a cost estimate of the modifications with the results. Within twenty (20) business days after ~~receipt of~~ **receiving** the cost estimate, the applicant will either:

(1) send payment to the utility for the estimated cost; or

(2) notify the utility in writing that it does not wish to proceed with the project.

~~Upon receipt of~~ **After payment is received**, the utility shall proceed to schedule and complete the required modifications or new construction. Within five (5) business days after the completion ~~of~~ the modifications or new construction, the utility shall provide the applicant with an executable interconnection agreement and notification that the interconnection will ~~finally~~ **be** approved ~~upon~~ **on** completion of the process set forth in subsections (r) through (t).

(v) If an application for Level 2 interconnection review is denied because it does not meet **at least** one (1) ~~or more~~ of the applicable requirements in this section, an applicant may resubmit the application under the Level 3 interconnection review procedure as appropriate. (*Indiana Utility Regulatory Commission; 170 IAC 4-4.3-7; filed Mar 6, 2006, 9:45 a.m.: 29 IR 2173; readopted filed Jul 12, 2012, 2:12 p.m.: 20120808-IR-170120114RFA; readopted filed Aug 2, 2013, 2:16 p.m.: 20130828-IR-170130227RFA; readopted filed Apr 11, 2019, 9:04 a.m.: 20190508-IR-170190136RFA*)

SECTION 8. 170 IAC 4-4.3-8 IS AMENDED TO READ AS FOLLOWS:

**170 IAC 4-4.3-8 Level 3 interconnection review**

**Authority: IC 8-1-1-3; IC 8-1-2.4**

**Affected: IC 8-1-2**

Sec. 8. (a) Each investor-owned electric utility shall adopt a Level 3 interconnection review procedure. The utility shall use the Level 3 review procedure for an application to interconnect a ~~customer-generator~~ **customer** facility that:

- (1) is connected to its distribution system; and
- (2) does not meet the requirements of section 6 or 7 of this rule.

(b) The utility shall do the following:

- (1) Conduct an initial review of the application.
- (2) Offer the applicant the opportunity to meet with utility staff to discuss the application.

(c) The utility shall provide an impact study agreement to the applicant, which ~~shall include~~ **includes** a good faith estimate of the cost for an impact study to be performed by the utility.

(d) If the proposed interconnection may affect electric transmission or delivery systems other than those controlled by the utility, operators of these systems may require additional studies to determine the impact of the interconnection on these systems. The utility shall coordinate the studies of other operators, but ~~shall~~ not be responsible for their timing. The applicant ~~shall be~~ **is** responsible for the costs of any ~~such~~ additional studies required by other affected system operators. The studies shall be conducted only after the applicant has provided written authorization.

(e) After the applicant has executed the impact study agreement and ~~has~~ paid the utility the amount of the good faith estimate required under subsection (c), the utility shall conduct the impact study and notify the applicant of the results as follows:

- (1) If the impact study indicates that only insubstantial modifications to the utility's electric distribution system are necessary to accommodate the proposed interconnection, the utility shall send the applicant an interconnection agreement that details the following:
  - (A) The scope of the necessary modifications.
  - (B) An estimate of their cost.
- (2) If the impact study indicates that substantial modifications to the utility's electric distribution system are necessary to accommodate the proposed interconnection, the utility shall do the following:
  - (A) Provide a good faith estimate of the cost of the modifications.
  - (B) Offer to conduct a facilities study at the applicant's expense, which will identify the types and cost of equipment needed to safely interconnect the applicant's ~~customer-generator~~ **customer** facility.

(f) If the applicant requests a facilities study under subsection (e)(2), the utility shall provide a facilities study agreement. The facilities study agreement ~~shall describe~~ **describes** the work to be undertaken in the facilities study and ~~shall include~~ **includes** a good faith estimate of the cost to the applicant for completion of the study. ~~Upon~~ **On** execution by the applicant of the facilities study agreement, the utility shall conduct a facilities study, which ~~shall~~ **must** identify the following:

- (1) The facilities necessary to safely interconnect the ~~customer-generator~~ **customer** facility with the utility's electric distribution system.
- (2) The cost of those facilities.
- (3) The time required to build and install those facilities.

(g) ~~Upon~~ **On** completion of the facilities study, the utility shall provide the applicant with the results of the study and an executable interconnection agreement. The agreement ~~shall~~ **must** list the following:

- (1) The conditions and facilities necessary to safely interconnect the ~~customer-generator~~ **customer** facility with the utility's electric distribution system.
- (2) The cost of those facilities.
- (3) The time required to build and install those facilities.

(h) If the applicant wishes to interconnect, the applicant shall do the following:

- (1) Execute the interconnection agreement.
- (2) Provide a deposit of the cost of the facilities identified in the facilities study.
- (3) Complete installation of the ~~customer-generator~~ **customer** facility.

(4) Agree to pay the utility the amount required for the facilities needed to interconnect as identified in the facilities study.

(i) Within fifteen (15) business days after notice from the applicant that the ~~customer-generator~~ **customer** facility has been installed, the utility shall do the following:

(1) Inspect the ~~customer-generator~~ **customer** facility.

(2) Arrange to witness any commissioning tests required under ~~IEEE 1547-~~ **the Institute of Electrical and Electronic Engineers 1547-2018, Standard for Interconnecting Interconnection and Interoperability of Distributed Energy Resources with Associated Electric Power Systems Interfaces.**

The utility and ~~the~~ applicant shall select a date by mutual agreement for the utility to witness commissioning tests.

(j) Provided the ~~customer-generator~~ **customer** facility passes ~~any~~ **the** required commissioning tests satisfactorily, the utility shall notify the applicant in writing, within five (5) business days after the tests, of one (1) of the following:

(1) The interconnection is approved and the ~~customer-generator~~ **customer** facility may begin operation.

(2) The facilities study identified necessary construction that has not been completed, the date ~~upon which~~ **when** the construction will be completed, and the date when the ~~customer-generator~~ **customer** facility may begin operation.

(k) If the commissioning tests are not satisfactory, the ~~customer-generator~~ **customer** facility shall repair or replace the unsatisfactory equipment and reschedule a commissioning test under subsection (i). (*Indiana Utility Regulatory Commission; 170 IAC 4-4.3-8; filed Mar 6, 2006, 9:45 a.m.: 29 IR 2175; readopted filed Jul 12, 2012, 2:12 p.m.: 20120808-IR-170120114RFA; readopted filed Aug 2, 2013, 2:16 p.m.: 20130828-IR-170130227RFA; readopted filed Apr 11, 2019, 9:04 a.m.: 20190508-IR-170190136RFA*)

SECTION 9. 170 IAC 4-4.3-9 IS AMENDED TO READ AS FOLLOWS:

#### **170 IAC 4-4.3-9 Requirements for ongoing operation of customer facilities**

**Authority: IC 8-1-1-3; IC 8-1-2.4**

**Affected: IC 8-1-2**

Sec. 9. (a) The investor-owned electric utility may perform reasonable onsite inspections to verify the proper installation and continuing safe operation of the ~~customer-generator~~ **customer** facility and interconnection facilities:

(1) at reasonable times; and

(2) ~~upon~~ **on** reasonable advance notice to the customer.

The cost of the inspection or inspections ~~shall be~~ **is** at the utility's expense; however, the utility ~~shall be~~ **is** not ~~be~~ responsible for any other cost the customer may incur as a result of the inspection or inspections.

(b) The customer shall install, operate, and maintain the ~~customer-generator~~ **customer** facility in accordance with the manufacturer's suggested practices for safe, efficient, and reliable operation in parallel to the utility's system.

(c) The utility may isolate ~~any customer-generator~~ **a customer** facility if the utility believes continued interconnection with the ~~customer-generator~~ **customer** facility creates or contributes to a system emergency. System emergencies causing discontinuance of interconnection ~~shall be~~ **are** subject to verification by the commission ~~upon~~ **on** a complaint made by the customer in accordance with the commission's consumer complaint rules.

(d) If the utility finds that the ~~customer-generator's~~ **customer's** facility is not in compliance with the requirements of this rule, and the noncompliance adversely affects the safety, reliability, or power quality of the electric distribution system, the utility may require the ~~customer-generator~~ **customer** to disconnect the ~~customer-generator~~ **customer** facility until compliance is achieved. (*Indiana Utility Regulatory Commission; 170 IAC 4-4.3-9; filed Mar 6, 2006, 9:45 a.m.: 29 IR 2176; readopted filed Jul 12, 2012, 2:12 p.m.: 20120808-IR-170120114RFA; readopted filed Aug 2, 2013, 2:16 p.m.: 20130828-IR-170130227RFA; readopted filed Apr 11, 2019, 9:04 a.m.: 20190508-IR-170190136RFA*)

SECTION 10. 170 IAC 4-4.3-10 IS AMENDED TO READ AS FOLLOWS:

#### **170 IAC 4-4.3-10 Liability insurance and indemnity**

**Authority: IC 8-1-1-3; IC 8-1-2.4**

**Affected: IC 8-1-2-33; IC 8-1-2-34**

Sec. 10. (a) The liability insurance and indemnification requirements of a ~~customer-generator~~ **customer** facility that is also a net metering facility, as defined at 170 IAC 4-4.2-1, ~~shall be~~ **are** in accordance with 170 IAC 4-4.2-8.

(b) The liability insurance and indemnification requirements of a ~~customer-generator~~ **customer** facility that is not also a net metering facility, as defined at 170 IAC 4-4.2-1, ~~shall be~~ **are** as follows:

(1) Insurance provisions ~~shall~~ **must** require a party to obtain only reasonable amounts of insurance against risks for which there is a reasonable likelihood of occurrence.

(2) The utility and ~~the~~ customer shall indemnify and hold each other harmless from and against all claims, liability, damages, and expenses, including attorney's fees, based on any injury to any person, including loss of life or damage to ~~any~~ property, including loss of use thereof, ~~arising out of,~~ **caused by,** resulting from, or connected with, or that may be alleged to have ~~arisen out of,~~ **been caused by,** resulted from, or **been** connected with, an act or omission by the other party or its:

- (A) employees;
- (B) agents;
- (C) representatives;
- (D) successors; or
- (E) assigns;

in the construction, ownership, operation, or maintenance of the party's facilities.

*(Indiana Utility Regulatory Commission; 170 IAC 4-4.3-10; filed Mar 6, 2006, 9:45 a.m.: 29 IR 2177; readopted filed Jul 12, 2012, 2:12 p.m.: 20120808-IR-170120114RFA; readopted filed Aug 2, 2013, 2:16 p.m.: 20130828-IR-170130227RFA; readopted filed Apr 11, 2019, 9:04 a.m.: 20190508-IR-170190136RFA)*

SECTION 11. 170 IAC 4-4.3-11 IS AMENDED TO READ AS FOLLOWS:

#### **170 IAC 4-4.3-11 Tariff and reporting requirements**

**Authority: IC 8-1-1-3; IC 8-1-2.4**

**Affected: IC 8-1-2**

Sec. 11. (a) Within sixty (60) days of the effective date of this rule, ~~all~~ investor-owned electric utilities shall submit for approval, ~~via~~ **through** the commission's thirty (30) day filing process, generic interconnection application and interconnection agreement forms for each of the three (3) levels of review.

(b) To assist the commission in monitoring the effectiveness of this rule over time, each investor-owned utility shall file a report with the commission's electricity division before March 2 ~~of~~ each year following the effective date of this rule. The report ~~shall~~ **must** contain the number, size, and type of the following:

(1) ~~Customer-generator~~ **Customer** facilities detailed in ~~all the~~ applications received during the ~~previous~~ **previous** calendar year, and the resolution, for example, granted, denied, **or** withdrawn, of the applications. The report ~~shall~~ **must** include the following:

- (A) The application procedure (Level 1, **Level 2,** or **Level 3**) for all applications.
- (B) The reason or reasons for any denied application or applications.

(2) The number, size, and type of ~~customer-generator~~ **customer** facilities interconnected ~~pursuant to Rule 4.3 under this rule~~ as of December 31 of the previous calendar year.

*(Indiana Utility Regulatory Commission; 170 IAC 4-4.3-11; filed Mar 6, 2006, 9:45 a.m.: 29 IR 2177; readopted filed Jul 12, 2012, 2:12 p.m.: 20120808-IR-170120114RFA; readopted filed Aug 2, 2013, 2:16 p.m.: 20130828-IR-170130227RFA; readopted filed Apr 11, 2019, 9:04 a.m.: 20190508-IR-170190136RFA)*

SECTION 12. 170 IAC 4-4.3-12 IS AMENDED TO READ AS FOLLOWS:

#### **170 IAC 4-4.3-12 Customer complaints**

**Authority: IC 8-1-1-3; IC 8-1-2.4**

**Affected: IC 8-1-2-34.5**

Sec. 12. ~~In the event~~ **If** an investor-owned electric utility and ~~an~~ eligible customer ~~are unable to~~ **cannot** agree on matters relating to ~~customer-generator~~ **customer** facility interconnection, either party may raise a customer complaint to the commission in accordance with the commission's consumer complaint rules. *(Indiana Utility Regulatory Commission; 170 IAC*

4-4.3-12; filed Mar 6, 2006, 9:45 a.m.: 29 IR 2177; readopted filed Jul 12, 2012, 2:12 p.m.: 20120808-IR-170120114RFA; readopted filed Aug 2, 2013, 2:16 p.m.: 20130828-IR-170130227RFA; readopted filed Apr 11, 2019, 9:04 a.m.: 20190508-IR-170190136RFA)

# Rule Signature Page

---

---

Rule #: LSA #25-368  
Agency: Indiana Utility Regulatory Commission  
Subject: Amends 170 IAC 4-4.3 regarding Customer-Generator Interconnection Standards.


## ADOPTED:

By the Indiana Utility Regulatory Commission

Date: SEP 30 2025

Absent

James F. Huston, Chairman

  
Wesley R. Bennett, Commissioner

  
Sarah E. Freeman, Commissioner

  
David E. Veleta, Commissioner

  
David E. Ziegner, Commissioner

## APPROVED AS TO FORM AND LEGALITY:

By: \_\_\_\_\_  
Todd Rokita  
Attorney General, State of Indiana

Date: \_\_\_\_\_

## APPROVED:

By: \_\_\_\_\_  
Mike Braun  
Governor, State of Indiana

Date: \_\_\_\_\_

## ACCEPTED FOR FILING:

By: \_\_\_\_\_  
Indiana Register  
Legislative Services Agency

Date: \_\_\_\_\_