



Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner

N/A
Pearson Mill Assembly
3522 N. 1000 W 27
Converse, IN 46919

Facility

Ark Christian Ministries, Inc.
3522 N. 1000 W 27
Converse, IN 46919
License Number :

The Ark Christian Ministries, Inc. Swimming Pool was inspected on 07/23/2026 by Cassie Leech & Josh Keller.

The pool is in reasonable compliance with 410 IAC 6-2.1 and 675 IAC 20 ; however, the following violations were observed and must be corrected by the opening inspection for 2027 season.

1. The alkalinity of the water was 140ppm. This is out of the acceptable range of least 80 and no more than 120 part per million (mg/l). This is a violation of 410 IAC 6-2.1-30(n).
2. The turnover rate for the pool was 7.29 hours. This is a violation of 410 IAC 6-2.1-32(b) and 675 IAC 20-2-17. The required turnover rate for a pool is 6 hours.
3. Hazardous chemicals such as disinfectants and/or strong acids/basis are being stored in an unlocked room or other area that is reasonably accessible to children. This is a violation of 410 IAC 6-2.1-33(c)
4. A gate or door to the pool enclosure is not effectively self-closing, with a positive self-latching closure mechanism. This presents a serious drowning hazard to young children, who could therefore access the pool enclosure on their own, without an adult caretaker. This is a violation of 410 IAC 6-2.1-26(a) and 675 IAC 20-2-26(f). Gate is locked with a padlock when not in use. Recommend new hinges for the gate.

If violations are not corrected by opening inspection of 2027 season the pool will not open until the violations are corrected.

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level :	6 mg/l	Total Alkalinity :	140 mg/l
Total Disinfectant Level :	N/A	Total Dissolved Solids :	N/A
pH :	7.8	Temperature :	N/A
Combined Chlorine :	0 mg/l	Saturation Index :	N/A
Cyanuric Acid Level :	0 mg/l	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		