



Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner

N/A
City of Gas City
Rogers St.
Gas City, IN 46933

Facility

Gas City Pool
Rogers St.
Gas City, IN 46933
License Number :

The Gas City Pool Gas City Pool was inspected on 05/27/2026 by Cassie Leech & Jeff Couch.

These violations of 410 IAC 6-2.1 and/or 675 IAC 20 was observed and must be corrected by Season Opening 2026.

1. The pH of the pool water was 8. This is out of the acceptable range of 7.2 to 7.8 (inclusive). This is a violation of 410 IAC 6-2.1-30(m).
2. The alkalinity of the water was 260ppm. This is out of the acceptable range of least 80 and no more than 120 part per million (mg/l). This is a violation of 410 IAC 6-2.1-30(n).
3. Operating records for the pool were not available upon request by the department. This is a violation of 410 IAC 6-2.1-38(a).
4. A test kit was not readily available for use by the pool operator. This is a violation of 410 IAC 6-2.1-30(j).
5. The pool deck/ entry stairs have broken concrete in areas that is possible to cause injury. this is a violation of 675 IAC 20-2-13 (b).
6. Visible dirt was observed on the bottom/walls of the pool. This is a violation of 410 IAC 6-2.1-37(a). Visible dirt shall be removed at least every 24 hours or more frequently if required.
7. One unit of lifesaving equipment was not provided for each 2,000 square feet of pool water surface area. This is a violation of 410 IAC 6-2.1-34(h).
8. The depth of the pool water was not plainly and conspicuously marked at or above the water surface/ on the vertical pool wall/ on the top of coping or edge of the deck or wall next to the pool. This is a violation of 410 IAC 6-2.1-34(f) and 675 IAC 20-2-26(c).
9. A life pole or shepherd's crook type of pole was not provided at the pool. This is a violation of 410 IAC 6-2.1-34(a) (1) and 675 IAC 20-2-26(e) (2). The life pole or shepherd's crook must have blunted ends and be a minimum length of 12 feet long.
10. A spine board, with straps and head immobilizer, was not available within the pool enclosure. This is a violation of 410 IAC 6-2.1-34(b). It was stated the straps are available and will be added to the board before opening.
11. Chlorinated isocyanurates or stabilized chlorine shall not be used for breakpoint chlorination. This is a violation of 410 IAC 6-2.1-30(f). All Trichlor must be disposed of properly.

12. The self-contained breathing apparatus is not kept [in a closed cabinet/accessible without a key/located outside of the room in which the chlorinator or chlorine cylinders are located]. This is a violation of 410 IAC 6-2.1-33(a) (3).

13. There is no written emergency plan of action for chlorine gas leaks. This is a violation of 410 IAC 6-2.1-33(a) (5).

14. The emergency plan of action for chlorine leaks has not been [communicated to all employees/posted in a conspicuous place/practiced with annual drills]. This is a violation of 410 IAC 6-2.1-33(a) (5).

15. A copy of the standards and recommendations of The Chlorine Institute, Inc., Pamphlet 82, (1999) were not kept on the premises. This is a violation of 410 IAC 6-2.1-33(a) (1).

16. Diving board is cracked and or broken. This is a violation of 675 IAC 20-2-8. We spoke and the plans are to remove this diving board completely before opening.

The pool may be opened after an inspection verifies the correction of the violations.

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level :	2.75 mg/l	Total Alkalinity :	260 mg/l
Total Disinfectant Level :	N/A	Total Dissolved Solids :	N/A
pH :	8	Temperature :	N/A
Combined Chlorine :	N/A	Saturation Index :	N/A
Cyanuric Acid Level :	0 mg/l	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		