



Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner

N/A
Marion Hotel LLC LLC
4276 W. Ruby Hill Dr.
Orland Park, IL 60462

Facility

Hampton Inn
1502 N. Baldwin Ave.
Marion, IN 46952
License Number :

The Hampton Inn Hampton Inn Pool was inspected on 01/16/2026 by Jeff Couch.

The pool is in reasonable compliance with 410 IAC 6-2.1 and 675 IAC 20; however, the following violations were observed and must be corrected as soon as possible.

1. The expiration date of the yellow top reagents in the pool test kit has expired. This is a violation of 410 IAC 6-2.1-30(j).
2. Operating records for the pool were not [logged daily] \ [kept for a minimum of 1 year] \ [available upon request by the department]. This is a violation of 410 IAC 6-2.1-38(a).
3. A 24 unit first aid kit was not provided within the pool enclosure. This is a violation of 410 IAC 6-2.1-34(d) and 675 IAC 20-2-26(e) (3). The first aid kit must meet American National Standards Institute (ANSI) standard Z308.1-2003 or 2009.
4. The chemicals/items in the chemical storage room are stored less than 6 inches above the floor. This is a violation of 410 IAC 6-2.1-33(b). Chemicals and items must be stored at least 6 inches above the floor to allow for flushing the area in the case of a spill.

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level :	8.5 mg/l	Total Alkalinity :	110 mg/l
Total Disinfectant Level :	N/A	Total Dissolved Solids :	N/A
pH :	7.6	Temperature :	80 F
Combined Chlorine :	0.8 mg/l	Saturation Index :	N/A
Cyanuric Acid Level :	0 mg/l	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		