



Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner

N/A
Marion Hotel LLC LLC
4276 W. Ruby Hill Dr.
Orland Park, IL 60462

Facility

Hampton Inn
1502 N. Baldwin Ave.
Marion, IN 46952
License Number :

The Hampton Inn Hampton Inn Spa was inspected on 01/16/2026 by Jeff Couch.

The pool is in reasonable compliance with 410 IAC 6-2.1 and 675 IAC 20; however, the following violations were observed and must be corrected as soon as possible.

1. The free residual chlorine/bromine concentration in the spa 12.5 ppm which is [greater than] the maximum allowed. This is a violation of 410 IAC 6-2.1-30(b) and 675 IAC 20-2-24.
2. The expiration date of the yellow top reagents in the pool test kit has expired. This is a violation of 410 IAC 6-2.1-30(j).
3. Operating records for the pool were not [logged daily] \ [kept for a minimum of 1 year] \ [available upon request by the department]. This is a violation of 410 IAC 6-2.1-38(a).
4. A 24 unit first aid kit was not provided within the pool enclosure. This is a violation of 410 IAC 6-2.1-34(d) and 675 IAC 20-2-26(e) (3). The first aid kit must meet American National Standards Institute (ANSI) standard Z308.1-2003 or 2009.
5. The chemicals/items in the chemical storage room are stored less than 6 inches above the floor. This is a violation of 410 IAC 6-2.1-33(b). Chemicals and items must be stored at least 6 inches above the floor to allow for flushing the area in the case of a spill.

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level :	12.5 mg/l	Total Alkalinity :	80 mg/l
Total Disinfectant Level :	N/A	Total Dissolved Solids :	N/A
pH :	7.8	Temperature :	100 F
Combined Chlorine :	2 mg/l	Saturation Index :	N/A
Cyanuric Acid Level :	0 mg/l	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		