



Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner

N/A
Indiana Wesleyan University
4201 S. Washington St.
Marion, IN 46953

Facility

Indiana Wesleyan University
4201 S. Washington St.
Marion, IN 46953
License Number :

The Indiana Wesleyan University IWU Pool was inspected on 09/04/2026 by Cassie Leech & Jeff Couch .

This pool is in compliance with 410 IAC 6-2.1 and 675 IAC 20.

* The diving board is missing the permanently affixed label that is required. This is a violation of 675 IAC 20-2-8 (E).

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level :	2.6 mg/l	Total Alkalinity :	70 mg/l
Total Disinfectant Level :	N/A	Total Dissolved Solids :	N/A
pH :	7.5	Temperature :	N/A
Combined Chlorine :	.2 mg/l	Saturation Index :	N/A
Cyanuric Acid Level :	0 mg/l	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		