



Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner

N/A
Grant County Family YMCA
123 Sutter Way
Marion, IN 46952

Facility

Grant County Family YMCA
123 Sutter Way
Marion, IN 46952
License Number :

The Grant County Family YMCA Lap Pool was re-inspected on 08/10/2026 by Cassie Leech & Josh Keller.

The pool is in reasonable compliance with 410 IAC 6-2.1 and 675 IAC 20 ; however, the following violations were observed and must be corrected as soon as possible.

1. The turnover rate for the pool, which was built on or after September 13, 1989, is greater than 6 hours. The turnover rate for the lap pool is 7hrs. and 21 min. This is a violation of 410 IAC 6-2.1-32(b).
2. The pool water was not tested for pH/disinfectant residuals daily (before the pool is open for use and at least 1 other time during the hours of pool use). This is a violation of 410 IAC 6-2.1-30(o) (1).

After the compliance date, if the violations remains uncorrected; an enforcement action may be initiated to obtain the correction of these violations.

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level :	5 mg/l	Total Alkalinity :	20 mg/l
Total Disinfectant Level :	N/A	Total Dissolved Solids :	N/A
pH :	7.2	Temperature :	N/A
Combined Chlorine :	0 mg/l	Saturation Index :	N/A
Cyanuric Acid Level :	0 mg/l	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		