



Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner

N/A
Trent Conaway
PO Box 44
Noblesville, IN 46061

Facility

Mar-brook Campgrounds
6690 E 600 S
Gas City, IN 46933
License Number :

The Mar-brook Campgrounds Swimming pool was inspected on 05/20/2026 by Cassie Leech , Josh Keller & Jeff Couch.

This pool is ordered closed until violations 1,2,3 & 4 of 410 IAC 6-2.1 and/or 675 IAC 20 are corrected and a re-inspection is completed. Violations 5 & 6 must be corrected by June 30, 2026.

1. The pool deck is made of concrete. There are places missing and rough that are a trip hazard and can cause injury. This is a violation of 675 IAC 20-2-13 (b). Attention to this area is important and must be brought to compliance.
2. A telephone or comparable 911 call box was not provided within 200 feet of the pool enclosure. This is a violation of 410 IAC 6-2.1-34(e) and 675 IAC 20-2-26(e) (4). The telephone must be available for emergency use whenever the pool is open.
3. The depth of the pool water was not plainly and conspicuously marked at or above the water surface/ on the vertical pool wall/. This is a violation of 410 IAC 6-2.1-34(f) and 675 IAC 20-2-26(c).
4. Two satisfactory water samples have not been submitted to the health department 1 week prior to set opening date. This is a violation of 410 IAC 6-2.1-31(g).
5. There is a gap or other opening in the southside gate. This presents a serious drowning hazard to young children, who could therefore access the pool enclosure on their own, without an adult caretaker. This gap or opening would certainly allow the passage of a 4" sphere thru the wall/fence. The gate was adjusted down to meet the 4" gap requirements at the bottom during the inspection. Adjusting the gate to meet the requirements altered the height of the gate. The gate must be at least 48" tall. This is a violation of 675 IAC 20-2.
6. The following user sanitation and safety rules were not posted: (1) Anyone who has or has had diarrhea in the past 2 weeks shall not use the pool. (2) Anyone who has an area of exposed subepidermal tissue, open blisters, cuts, etc., is advised not to use the pool. (3) All persons shall take a cleansing shower before using the pool. A bather leaving the pool to use the toilet shall take another cleansing shower before returning to the pool enclosure. (4) Spitting, spouting of water, blowing the nose and similar behavior in the pool is prohibited. (5) No running or rough play is permitted in the pool, on the runways, on diving boards, on floats, on platforms, in dressing rooms, or in showers. (6) Street clothes are not allowed in the pool. (7) All diaper aged children shall use plastic pants with tight fitting elastic at the legs and waist, or swim diapers. (8) Do not change diapers at poolside. This is a violation of 410 IAC 6-2.1-36(b).

The pool may be opened after an inspection verifies the correction of the 1-4 violations.

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level : 6 mg/l
Total Disinfectant Level : N/A
pH : 7.4
Combined Chlorine : 0 mg/l
Cyanuric Acid Level : 0 mg/l
Calcium Hardness : N/A

Total Alkalinity : 250 mg/l
Total Dissolved Solids : N/A
Temperature : N/A
Saturation Index : N/A
Maximum Bather Load : N/A