



Environmental Public Health Division
Indiana Department of Health
2 N Meridian St. 7 - D
Indianapolis, Indiana 46204
317/233-7173 Fax: 317/233-7047
www.eph.in.gov

Swimming Pool Inspection Report

Owner

N/A
Marion Community Schools
750 W. 26th St.
Marion, IN 46953

Facility

Marion High School
750 W. 26th St.
Marion, IN 46953
License Number :

The Marion High School Marion High School Pool was inspected on 03/25/2026 by Steve Yeary, Jeff Couch, and Jessika Stanczak.

These violations of 410 IAC 6-2.1 and/or 675 IAC 20 were observed and must be corrected as soon as possible.

1. A log was not maintained to record the water chemistry tests listed below. This is a violation of 410 IAC 6-2.1-30(o) and (q).

- Free Chlorine concentration upon opening and a second time during the day
- pH upon opening and a second time during the day
- Combined Chlorine at least two times per week
- Alkalinity at least one time per week

2. The Palin test kit was out of calibration as indicated by a pH test that was 0.3 units different than both health department test kits. The backup kit had expired reagents. As a result, the pool's chemical controller was calibrated as if the pH was 7.5 when it was actually 7.2. This is a violation of 410 IAC 6-2.1-30(i).

If you have questions, please contact the Environmental Public Health Division.

Field Data

Free Disinfectant Level :	5.0 mg/l	Total Alkalinity :	100-110 mg/l
Total Disinfectant Level :	N/A	Total Dissolved Solids :	N/A
pH :	7.2	Temperature :	N/A
Combined Chlorine :	<0.2 mg/l	Saturation Index :	N/A
Cyanuric Acid Level :	0 mg/l	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		