



Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner

Northeastern Indiana Nazarene Campground
Association
Northeast Indiana Nazarene Campground Association
1950 S 350 E
Marion, IN 46953

Facility

Shiloh Park Retreat & Conference Center
1734 S 350 E
Marion, IN 46953
License Number :

The Shiloh Park Retreat & Conference Center swimming pool was inspected on 05/26/2026 by Steve Yeary, Jeff Couch and Cassie Leech.

These violations of 410 IAC 6-2.1 and/or 675 IAC 20 were observed and must be corrected as soon as possible. The pH and cleanliness of the pool must be addressed before opening for use.

1. The pH of the pool water was over 8.0. This is out of the acceptable range of 7.2 to 7.8 (inclusive). This is a violation of 410 IAC 6-2.1-30(m). The pool cannot be allowed to open with a pH this high. It should not be allowed to open unless the pH is within the acceptable range.
2. Visible dirt was observed on the pool bottom. This is a violation of 410 IAC 6-2.1-37(a). This needs to be removed before the pool is open for use. This situation is made worse by the fact that the main drains are not on the pool's actual bottom to readily accept the dirt. In addition, there is not an effective way to sweep the pool.
3. A meter to measure the flow of water through the pool water recirculation system was not provided. This is a violation of 410 IAC 6-2.1-32(c). This particular pool will need two meters on the dual return lines and the total flow will be additive. This is needed to evaluate the pool's turnover rate.
4. The gate to the pool enclosure is not effectively self-closing, with a positive self-latching closure mechanism. The hinge is apparently loose. This is a violation of 410 IAC 6-2.1-26(a) and 675 IAC 20-2-26(f). A spring could be added to aid the gate in closing even after the hinge is repaired.
5. A telephone or emergency 911 call box was not provided within 200 feet of the pool enclosure. This is a violation of 410 IAC 6-2.1-34(e) and 675 IAC 20-2-26(e) (4). The telephone must be available for emergency use whenever the pool is open. The facility address must be added to this call box or phone to aid in communication with 911 dispatchers.
6. Signs stating "No Diving" with 4" letters are not posted at the pool side. This is a violation of 410 IAC 6-2.1-36(a) (4). Note that given the lack of depth markings throughout as well as the uniform pool depth, the pool depth should be stated with the no diving signs, as agreed.
7. The applicable pool sanitation signs required in 410 IAC 6-2.1-36(b) have not been posted in a minimum 1" letter size. This is a violation of 410 IAC 6-2.1-36(b).
8. The liquid Chlorine tank and associated disinfectant feeder are setting outside and are not secured within a structure. Thus, they are readily accessible to unauthorized persons via various means (including thru or over the fence). This is a violation of 410 IAC 6-2.1-33(c). This must be stored in a secure structure with a lock of some kind. It will need a stable floor and roof. It could be a very small shed, as discussed. This will also need a "Hazardous Chemicals" sign with 4" letters.

9. The fence surrounding the pool is not 6' high. Such a height would have been required at the time the pool was built. This is a violation of 675 IAC 20-2-26(f).

10. There is no 4" deck surrounding the pool. This is a violation of 410 IAC 6-2.1-26(a) and 675 IAC 20-2-13(d). There is actually no deck immediately adjacent to the pool. This could interfere with emergency rescue efforts (either by lifeguards and/or by first responders).

11. The main drains are not actually at the lowest point of the pool; they are on the wall near the bottom. This interferes with their ability to passively clean the pool. This is a violation of 410 IAC 6-2.1-26(a) and 675 IAC 20-2-20.1(c).

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level :	5.2 mg/l	Total Alkalinity :	N/A
Total Disinfectant Level :	N/A	Total Dissolved Solids :	N/A
pH :	>8.0	Temperature :	N/A
Combined Chlorine :	0 mg/l	Saturation Index :	N/A
Cyanuric Acid Level :	0 mg/l	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		