



Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner

N/A
Grant County Family YMCA
123 Sutter Way
Marion, IN 46952

Facility

Grant County Family YMCA
123 Sutter Way
Marion, IN 46952
License Number :

The Grant County Family YMCA Grant County Family YMCA Spa was re-inspected on 08/10/2026 by Cassie Leech & Josh Keller.

The pool is in reasonable compliance with 410 IAC 6-2.1 and 675 IAC 20; however, the following violations were observed and must be corrected as soon as possible.

1. A meter to measure the flow of water through the pool water recirculation system was not provided. This is a violation of 410 IAC 6-2.1-32(c).
2. The spa water was not tested for pH/disinfectant residuals daily (before the spa is open for use and at least 2 other time during the hours of spa use). This is a violation of 410 IAC 6-2.1-30(p).
3. Floating weirs are missing from a skimmer or skimmers. As a result, surface tension will no longer be able to develop sufficient velocity on the water surface to draw floating wastes into the skimmer or skimmers from the entire pool surface. This is a violation of 410 IAC 6-2.1-26(a) and 675 IAC 20-2-21(c)(4)
4. The alkalinity of the water was 30ppm. This is out of the acceptable range of least 80 and no more than 120 part per million (mg/l). This is a violation of 410 IAC 6-2.1-30(n).

After the compliance date, if the violations remains uncorrected; an enforcement action may be initiated to obtain the correction of these violations.

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level :	2.2 mg/l	Total Alkalinity :	30 mg/l
Total Disinfectant Level :	N/A	Total Dissolved Solids :	N/A
pH :	7.4	Temperature :	N/A
Combined Chlorine :	0 mg/l	Saturation Index :	N/A
Cyanuric Acid Level :	0 mg/l	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		