



Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner

N/A
Attn. Andy Davis City of Marion
2601 S. Adams st.
Marion, IN 46953

Facility

Splash House
2601 S. Adams St.
Marion, IN 46953
License Number :

The Splash House Main Pool was inspected on 05/19/2026 by Jeff Couch, Cassie Leech Josh Keller.

This pool is in compliance with 410 IAC 6-2.1 and 675 IAC 20.

1. The free residual chlorine concentration in the wading pool was 2.4 which is [less than] the minimum 3 ppm allowed. This is a violation of 410 IAC 6-2.1-30(b) and 675 IAC 20-2-24.
2. Sand is collecting on the bottom of the slide runout. This is a violation of 410 IAC 6-2.1-37(a). Broken bottom pipes in the sand filters would be the source of this sand. It is not known when the filter sand was changed last. It will be necessary to remove the sand from the filter to inspect and repair the bottom collection pipes. Visible dirt shall be removed at least every 24 hours or more frequently if required.
3. The Slide-ward (South) side of the perimeter gutter has a trough that is overfull to the point it does not appear to be functioning. This is a violation of 410 IAC 6-2.1-26(a) and 675 IAC 20-2-21.
4. A deck drain at the water slides have rough, sharp edges. This is a violation of 675 IAC 20-2-13(b).

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level :	2.4 mg/l	Total Alkalinity :	80 mg/l
Total Disinfectant Level :	2.4 mg/l	Total Dissolved Solids :	N/A
pH :	7.4	Temperature :	N/A
Combined Chlorine :	0 mg/l	Saturation Index :	N/A
Cyanuric Acid Level :	0 mg/l	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		