



Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner

N/A
Attn. Andy Davis City of Marion
2601 S. Adams st.
Marion, IN 46953

Facility

Splash House
2601 S. Adams St.
Marion, IN 46953
License Number :

The Splash House Wave Pool was inspected on 05/19/2026 by Jeff Couch, Cassie Leech Josh Keller.

This pool is in compliance with 410 IAC 6-2.1 and 675 IAC 20.

1. Visible dirt was observed on the bottom/walls of the pool. This is a violation of 410 IAC 6-2.1-37(a). Visible dirt shall be removed at least every 24 hours or more frequently if required.
2. The chemicals/items in the chemical storage room are stored less than 6 inches above the floor. This is a violation of 410 IAC 6-2.1-33(b). Chemicals and items must be stored at least 6 inches above the floor to allow for flushing the area in the case of a spill.

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level :	4 mg/l	Total Alkalinity :	80 mg/l
Total Disinfectant Level :	4 mg/l	Total Dissolved Solids :	N/A
pH :	7.5	Temperature :	N/A
Combined Chlorine :	0 mg/l	Saturation Index :	N/A
Cyanuric Acid Level :	0 mg/l	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		