



Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner

Heritage At University Village Homeowners Assoc Inc
University Village
3002 E 56th St
Indianapolis, IN 46220

Facility

Heritage at University Village
4343 Thompson Drive Pool House
Marion, IN 46953
License Number :

The Heritage at University Village Heritage at University Village was inspected on 07/23/2026 by Cassie Leech & Josh Keller.

The pool is in reasonable compliance with 410 IAC 6-2.1 and 675 IAC 20 ; however, the following violations were observed and must be corrected by the opening inspection for the 2027 season.

1. The pool water was not tested for pH/disinfectant residuals daily (before the pool is open for use and at least 1 other time during the hours of pool use). This is a violation of 410 IAC 6-2.1-30(o) (1).
2. A meter to measure the flow of water through the pool water recirculation system was not provided. This is a violation of 410 IAC 6-2.1-32(c).
3. Visible dirt was observed on the bottom/walls of the pool. This is a violation of 410 IAC 6-2.1-37(a). Visible dirt shall be removed at least every 24 hours or more frequently if required.
4. The depth of the pool water was not plainly and conspicuously marked at or above the water surface/ on the vertical pool wall. This is a violation of 410 IAC 6-2.1-34(f) and 675 IAC 20-2-26(c).

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level :	6 mg/l	Total Alkalinity :	80 mg/l
Total Disinfectant Level :	N/A	Total Dissolved Solids :	N/A
pH :	7.2	Temperature :	N/A
Combined Chlorine :	0 mg/l	Saturation Index :	N/A
Cyanuric Acid Level :	30 mg/l	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		