



Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner

N/A

Grant County Family YMCA
123 Sutter Way
Marion, IN 46952

Facility

Grant County Family YMCA
123 Sutter Way
Marion, IN 46952
License Number :

The Grant County Family YMCA Lap Pool was inspected on 07/08/2026 by Cassie Leech & Jeff Couch.

The pool is in reasonable compliance with 410 IAC 6-2.1 and 675 IAC 20 ; however, the following violations were observed and must be corrected by August 7, 2026.

1. A copy of Rule 410 IAC 6-2.1, Public and Semi-Public Swimming Pools, is not kept on site at the facility. This is a violation of 410 IAC 6-2.1-25(d).
2. The free residual chlorine/bromine concentration in the lap pool was 18ppm which is greater than maximum allowed. This is a violation of 410 IAC 6-2.1-30(b) and 675 IAC 20-2-24. The lap pool was closed during inspection. This violation was corrected and the lap pool was re-opened while inspection was still taking place.
3. A test kit was not readily available for use by the pool operator. This is a violation of 410 IAC 6-2.1-30(j).
4. The alkalinity of the water was 20ppm. This is out of the acceptable range of least 80 and no more than 120 part per million (mg/l). This is a violation of 410 IAC 6-2.1-30(n).
5. The pool water was not tested for pH/disinfectant residuals daily (before the pool is open for use and at least 1 other time during the hours of pool use). This is a violation of 410 IAC 6-2.1-30(o) (1).
6. The pool water was not tested for combined chlorine at least twice a week. This is a violation of 410 IAC 6-2.1-30(o) (2).
7. The pool water was not tested for total alkalinity at least once a week. This is a violation of 410 IAC 6-2.1-30(o) (3).
8. The pool water was not tested for cyanuric acid at least once a week. This is a violation of 410 IAC 6-2.1-30(o) (4).
9. Operating records for the pool were not [logged daily] \ [kept for a minimum of 1 year] \ [available upon request by the department]. This is a violation of 410 IAC 6-2.1-38(a).
10. The depth of the pool water was not plainly and conspicuously marked at or above the water surface/ on the vertical pool wall. This is a violation of 410 IAC 6-2.1-34(f) and 675 IAC 20-2-26(c).

After the compliance date, if the violations remain uncorrected; an enforcement action may be initiated to obtain the correction of these violations.

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level : >18 mg/l
Total Disinfectant Level : N/A
pH : 7
Combined Chlorine : .5 mg/l
Cyanuric Acid Level : N/A
Calcium Hardness : N/A

Total Alkalinity : 20 mg/l
Total Dissolved Solids : N/A
Temperature : N/A
Saturation Index : N/A
Maximum Bather Load : N/A