



Grant County Health Department
401 South Adams Street
Marion, 46953
Office - (765)651-2401

Swimming Pool Inspection Report

Owner

N/A
Taylor University
236 W. Reade Ave.
Upland, IN 46989

Facility

Taylor University
236 W. Reade Ave.
Upland, IN 46989
License Number :

The Taylor University Eichling Aquatics Wing was inspected on 07/01/2026 by Josh Keller & Cassie Leech.

The pool is currently closed for the season.

1. The pH of the pool water was <7. This is out of the acceptable range of 7.2 to 7.8 inclusive. This is a violation of 410 IAC 6-2.1-30(m).
2. The alkalinity of the water was 20ppm. This is out of the acceptable range of least 80 and no more than 120 part per million (mg/l). This is a violation of 410 IAC 6-2.1-30(n).
3. The pool water was not tested for pH/disinfectant residuals daily (before the pool is open for use and at least 1 other time during the hours of pool use). This is a violation of 410 IAC 6-2.1-30(o) (1).
4. A meter to measure the flow of water through the pool water recirculation system was not provided. This is a violation of 410 IAC 6-2.1-32(c).
5. Floating weirs are missing from a skimmer or skimmers. As a result, surface tension will no longer be able to develop sufficient velocity on the water surface to draw floating wastes into the skimmer or skimmers from the entire pool surface. This is a violation of 410 IAC 6-2.1-26(a) and 675 IAC 20-2-21(c)(4).
6. The chemicals/items in the chemical storage room are stored less than 6 inches above the floor. This is a violation of 410 IAC 6-2.1-33(b). Chemicals and items must be stored at least 6 inches above the floor to allow for flushing the area in the case of a spill.
7. Material Safety Data Sheets (MSDA) for chemicals are not provided at the facility. This is a violation of 410 IAC 6-2.1-33(c).
8. A sign warning "DANGER-HAZARDOUS CHEMICALS" is not posted on or adjacent to the entrance to the pool chemical feed/chemical storage rooms. This is a violation of 410 IAC 6-2.1-36(a) (1).
9. The pool operating records did not contain the following: (1) Disinfectant residuals and combined chlorine concentrations. (2) pH readings. (3) Volume of fresh water added. (4) Operating periods of pool water recirculation pumps and filters and the corresponding rate of flow meter readings. (5) Amounts of chemicals used. (6) Maintenance and malfunctioning of equipment. This is a violation of 410 IAC 6-2.1-38(a).
10. The swimming pool and mechanical equipment should be operated under the close supervision of a competent person, that is qualified and experienced in pool operations and who can assume the responsibility for compliance with all parts of 410 IAC 6-2.1. Note: The operator should be on duty at all times the swimming pool is open.

A follow up inspection must be schedule by Josh Grubbs who is operating the pool currently. The pool may be opened after an inspection verifies the correction of the violation.

If you have questions, please contact the Grant County Health Department.

Field Data

Free Disinfectant Level :	4.2 mg/l	Total Alkalinity :	20 mg/l
Total Disinfectant Level :	N/A	Total Dissolved Solids :	N/A
pH :	<7.0	Temperature :	78 F
Combined Chlorine :	0.6 mg/l	Saturation Index :	N/A
Cyanuric Acid Level :	0 mg/l	Maximum Bather Load :	N/A
Calcium Hardness :	N/A		