



East Chicago Compliance Verification Sampling

Sample Delivery Group	Sample Location	Lead (ppb) 1st Draw	Copper (ppb) 1st Draw	Orthophosphate (PO4) 1st Draw	Lead (ppb) 1 Minute Flush	Copper (ppb) 1 Minute Flush	Lead (ppb) 3 Minute Flush	Copper (ppb) 3 Minute Flush	Orthophosphate (PO4) Flush
13720	Kitchen Sink	<1.0	10.7	1.14	<1.0	1.6	<1.0	1.5	1.23
13721	Bathroom Sink	10.3	2.1	1.32	4.4	1.6	2	1.4	1.35
13722	Kitchen Sink	<1.0	1.7	1.23	1.7	4	<1.0	1.1	1.26
13723	Kitchen Sink	1.4	3.4	1.29	<1.0	1.5	<1.0	1.2	1.32
13724	Kitchen Sink	6.1	3.6	1.35	8.3	1.9	4.4	1.2	1.38
13725	Kitchen Sink	<1.0	4.6	1.23	<1.0	<1.0	<1.0	1	1.32
13726	Kitchen Sink	<1.0	21.6	1.35	<1.0	2	<1.0	1.6	1.32
13727	Kitchen Sink	<1.0	65.6	1.26	7.9	17	<1.0	5.3	1.29
13728	Kitchen Sink	5.2	65.1	1.29	19.1	10.9	3.7	7.1	1.26
13729	Kitchen Sink	1.2	16.5	1.23	1.9	2.6	1.2	2.5	1.23
13730	Kitchen Sink	<1.0	64.6	1.32	<1.0	2.6	<1.0	2.6	1.23
13731	Kitchen Sink	7.4	83.7	1.26	5.2	5.5	3.7	4.4	1.20
13732	Kitchen Sink	<1.0	4.4	1.35	<1.0	<1.0	<1.0	<1.0	1.14
13733	Kitchen Sink	<1.0	56.7	1.35	<1.0	7.9	<1.0	3.1	1.35
13764	Kitchen Sink	<1.0	8.7	0.89	<1.0	1.8	<1.0	1.6	0.80
13765	Kitchen Sink	<1.0	20.7	1.14	<1.0	1.8	<1.0	1.8	1.17
13766	Kitchen Sink	1.2	6.20	1.20	1.9	1.6	<1.0	1.1	0.64
13767	Kitchen Sink	1.1	3.8	1.29	6.4	1.3	<1.0	1	0.92
13768	Kitchen Sink	11.4	41.1	1.23	5.1	2.7	4.4	2.4	1.17
13769	Kitchen Sink	1.6	3.8	1.29	<1.0	5.4	<1.0	2.2	0.71
13770*	Kitchen Sink	4.2	7	1.26	3.2	1.3	2.3	1.1	1.29
13771	Kitchen Sink	<1.0	10.4	1.07	<1.0	1.3	<1.0	1.2	1.11
13772*	Kitchen Sink	<1.0	24.7	1.23	<1.0	2.7	<1.0	2.1	1.29
13773	Kitchen Sink	5.6	6.4	1.23	2.4	38	1.9	5	1.01
13804	Kitchen Sink	1.3	2.4	1.11	1.7	1	<1.0	<1.0	1.17
13805*	Kitchen Sink	<1.0	23.4	1.17	<1.0	36.7	<1.0	8.3	1.14
13836*	Kitchen Sink	2.7	9.1	1.29	1.1	1.4	<1.0	1.2	1.35
13866*	Kitchen Sink	6.4	1.8	1.11	5.2	1.1	2.6	<1.0	1.14
13894*	Kitchen Sink	<1.0	2.6	1.20	<1.0	1	<1.0	<1.0	1.23
13895*	Kitchen Sink	4.2	40.2	1.25	7.9	2.8	1.1	2.3	1.19
13896*	Kitchen Sink	<1.0	48.4	1.22	<1.0	3.8	<1.0	3.5	1.22
13897*	Kitchen Sink	<1.0	10.4	1.22	<1.0	2.3	<1.0	2	1.22
13898*	Kitchen Sink	2.5	16.8	1.27	20.1	1.9	1.3	1.6	1.22
13899*	Kitchen Sink	1.4	116.5	1.32	1.4	1.4	<1.0	1.1	1.19
13900*	Kitchen Sink	1.6	91	1.24	1.3	9.6	1.2	6.1	1.20

*Noncompliance Location