

| TAG | MODEL | AHI | CONDENSING UNIT SCHEDULE | | | | | COMPRESSOR AMPS | NOTES | |
|-----|-------|-----------|--------------------------|--------------------------|-------------|-------|-----|--------------------|-------|---------|
| | | | SUCTION TEMPERATURE | NUMBER OF COMPRESSORS | FANS NO. | DISA. | HP | | | |
| | CU-1A | RAUA 800 | 920 | 450F | 1 | 2 | 48 | 7 8 7.5 | 124 | 1,2,3 |
| | CU-1B | RAUA 800 | 920 | 450F | 1 | 2 | 48 | 7 8 7.5 | 124 | 1,2,3 |
| | CU-1A | RAUA 800 | 920 | 450F | 1 | 2 | 48 | 7 8 7.5 | 124 | 1,2,3 |
| | CU-2B | RAUA 800 | 920 | 450F | 1 | 2 | 48 | 7 8 7.5 | 124 | 1,2,3 |
| | CU-3A | RAUA 800 | 920 | 450F | 1 | 2 | 48 | 7 8 7.5 | 124 | 1,2,3 |
| | CU-3B | RAUA 800 | 920 | 450F | 1 | 2 | 48 | 7 8 7.5 | 124 | 1,2,3 |
| | CU-4A | RAUA 800 | 920 | 450F | 1 | 2 | 48 | 7 8 7.5 | 124 | 1,2,3 |
| | CU-4B | RAUA 800 | 920 | 450F | 1 | 2 | 48 | 7 8 7.5 | 124 | 1,2,3 |
| | CU-5 | RAS 8 | 95 | 450F | 1 | 2 | 20 | 2 8 1 1/2 | 19 | 1,2,3 |
| | CU-6 | RAHA 400 | 480 | 450F | 1 | 4 | 68* | 3 8 7.5 | 76 | 1,2,3,4 |
| | CU-7 | RAUA 1000 | 1200 | 450F | 1 | 5 | 48* | 3 8 7.5 | 155 | 1,2,3,4 |
| | CU-8 | RAUA 1000 | 1200 | 450F | 1 | 5 | 48* | 3 8 7.5 | 155 | 1,2,3,4 |

CONDENSING UNIT SCHEDULE

CONDENSER
FANS
NO.

DISA.

COMPRESSOR
AMPS

NOTES

1. AMBIENT TEMPERATURE 950F DB.

2. 480V, 3 PHASE, 60 HZ UNITS, WITH 1C" HIGH PATE PREABRICATION EQUIPMENT SUPPORTS, EXTENDING PAST UNIT ONE FOOT ON BOTH SIDES.

3. ALL STANDARD EQUIPMENT, IMLET GUARDS, HIGH LOW PRESSURE CUT OFF, CRANK CASE HEATER, ACROSS THE LINE STARTER, CONTROL TRANSFORMER, FAN, CARLIER, YORK.

4. WITH HOT GAS BY PASS CONNECTION, AND BUILT-IN HOT GAS BY-PASS

1.

2.

3.

4.

[illegible]